

SANTA ANA WATERSHED PROJECT AUTHORITY
INLAND EMPIRE BRINE LINE REACH V
REHABILITATION AND IMPROVEMENT PROJECT – PHASE I

ADDENDUM NO. 1

The following addendum is being issued for the above referenced contract(s). Bidders are required to incorporate the information contained herein as if originally issued and included with the contract documents. Pursuant to Section 6 of the Bid Form, Bidders are required to acknowledge receipt of this addendum and confirm all associated impacts from this addendum are included in the Bid. Failure to acknowledge this addendum in the Bid Form will render the Bid non-responsive and will not be considered.

PART 1: RESPONSE TO QUESTIONS

Question received from Sarah King, Charles King Co., Inc., dated Monday September 8, 2014:

1. I am in the process of preparing outreach for the referenced job. In the specifications for the job it asks us to post, 30 days in advance, for the opportunity for M/D/WBEs to participate. There is no further reference to acceptable publications which SAWPA would encourage us to use. Can you please give me a list of publications which will satisfy this requirement for the EPAs CWSRF Outreach requirements, or refer me to a contact for this information.

Response: Posting solicitations for bids or proposals for a minimum of 30 calendar days before the bid opening date in order to make information on forthcoming opportunities available to DBEs is a requirement of the owner. The owner posted the INVITATION TO BID to fulfill this requirement. However, prime contractors ARE REQUIRED to conduct and document outreach that demonstrates a Good Faith Effort to ensure opportunities for DBEs to compete. SAWPA strongly encourages prime contractors to utilize the information found in Appendix D to find Certified MBEs and WBEs. Specifically page 3 of Appendix D states:

“Although OSBP (Office of Small Business Program) does not maintain a list of EPA certified firms, there are several resources available to the public to locate firms that are considered EPA DBE certified.

- 1. State DOT DBE Directories*
- 2. Central Contractor Registration (CCR)*
- 3. SBA Dynamic Small Business Search”*

PART 2: REVISION TO SPECIFICATIONS

1. Specification Section 15121, 2.05A Pages 7-8, Table headings should be revised to read as follows:

Parameter	Reach No. 1	Reach No. 2 & Caltrans Reach	Reach No. 3
Liner Type	Reinforced	Reinforced or Non-reinforced	Non-reinforced
Design Condition	Fully deteriorated host pipe	Fully deteriorated host pipe	Fully deteriorated host pipe
Design Safety Factor	2.0	2.0	2.0
Internal Pressure	60 psi	30 psi	0 psi
Ovality	7%	7%	7%
Groundwater Depth Above Pipe	-2 feet	-2 feet	-2 feet
Soil Depth Above Pipe Crown	18 feet	18 feet	18 feet
Live Load	H20 Highway	H20 Highway	H20 Highway
Soil Density	120 pounds per cubic foot	120 pounds per cubic foot	120 pounds per cubic foot
Soil Modulus	750 psi	750 psi	750 psi
Minimum CIPP Wall Thickness	13.5 mm	13.5 mm	13.5 mm
Retention Factor for Long-Term Flexural Modulus	50%	50%	50%
Retention Factor for Long-Term Tensile Strength	33%	33%	33%

DATED: September 9, 2014

BY: David P. Ruhl
 David P. Ruhl, P.E.
 Program Manager

BY: D. Michael Metts
 D. Michael Metts, P.E.

