



S A W P A

SANTA ANA WATERSHED PROJECT AUTHORITY
 11615 Sterling Avenue, Riverside, California 92503 • (951) 354-4220

| | |
|---|---|
| Meeting Access Via Computer (Zoom): | Meeting Access Via Telephone: |
| <ul style="list-style-type: none"> • https://sawpa.zoom.us/j/86242155577 | <ul style="list-style-type: none"> • 1 (669) 900-6833 |
| <ul style="list-style-type: none"> • Meeting ID: 862 4215 5577 | <ul style="list-style-type: none"> • Meeting ID: 862 4215 5577 |

This meeting will be conducted in person at the address listed above. As a convenience to the public, members of the public may also participate virtually using one of the options set forth above. Any member of the public may listen to the meeting or make comments to the Committee using the call-in number or Zoom link above. However, in the event there is a disruption of service which prevents the Authority from broadcasting the meeting to members of the public, the meeting will not be postponed or rescheduled but will continue without remote participation. The remote participation option is provided as a convenience to the public and is not required. Members of the public are welcome to attend the meeting in-person.

**REGULAR MEETING OF THE
 PROJECT AGREEMENT 24 COMMITTEE
 TUESDAY, FEBRUARY 4, 2025 – 10:00 A.M.**
 (or immediately following the 9:30 a.m. SAWPA Commission meeting)

Committee Members

| | |
|---|---|
| Eastern Municipal Water District | Inland Empire Utilities Agency |
| Director Philip E Paule | Director Jasmin A. Hall |
| Director David J. Slawson (Alt) | Shivaji Deshmukh, General Manager (Alt) |
| San Bernardino Valley Municipal Water District | Western Municipal Water District |
| Director T. Milford Harrison, Chair | Director Mike Gardner, Vice Chair |
| Director Gil Botello (Alt) | Craig Miller, General Manager (Alt) |

AGENDA

1. CALL TO ORDER | PLEDGE OF ALLEGIANCE (T. Milford Harrison, Chair)

2. ROLL CALL

3. PUBLIC COMMENTS

Members of the public may address the Committee on items within the jurisdiction of the Committee; however, no action may be taken on an item not appearing on the agenda unless the action is otherwise authorized by Government Code §54954.2(b).

Members of the public may make comments in-person or electronically for the Committee's consideration by sending them to publiccomment@sawpa.gov with the subject line "Public Comment". Submit your electronic comments by 5:00 p.m. on Monday, February 3, 2025. All public comments will be provided to the Chair and may be read into the record or compiled as part of the record. Individuals have a limit of three (3) minutes to make comments and will have the opportunity when called upon by the Committee.

4. ITEMS TO BE ADDED OR DELETED

Pursuant to Government Code §54954.2(b), items may be added on which there is a need to take immediate action and the need for action came to the attention of the Santa Ana Watershed Project Authority subsequent to the posting of the agenda.

5. CONSENT CALENDAR

All matters listed on the Consent Calendar are considered routine and non-controversial and will be acted upon by the Committee by one motion as listed below.

- A. **APPROVAL OF MEETING MINUTES: DECEMBER 3, 2024**5
Recommendation: Approve as posted.

6. COMMITTEE DISCUSSION/ACTION ITEMS

- A. **OC SAN / SAWPA JOINT POLICY COMMITTEE (PA24#2025.1)**11
Presenter: Jeff Mosher
Recommendation: To appoint two Commissioners to the Orange County Sanitation District (OC San) / Santa Ana Watershed Project Authority (SAWPA) Joint Policy Committee.
- B. **AMENDMENT TO THE PA 24 AGREEMENT – APPOINTMENT OF ALTERNATE REPRESENTATIVES (PA24#2025.2)**13
Presenter: Jeff Mosher
Recommendation: To approve the amendment to the Project Agreement 24 (PA 24 Agreement) dated July 17, 2019, allowing for the appointment of two (2) alternate representatives.
- C. **INLAND EMPIRE BRINE LINE DATA MANAGEMENT SYSTEM REQUEST FOR PROPOSAL (RFP) (PA24#2025.3)**27
Presenter: Lucas Gilbert
Recommendation: To direct staff to release an RFP for Data Management System Software for the Inland Empire Brine Line Pretreatment Program.
- D. **INLAND EMPIRE BRINE LINE MASTER PLAN FINAL (PA24#2025.4)**75
Presenter: David Ruhl
Recommendation: Receive and file.
- E. **CITY OF CHINO EUCLID BRIDGE PROJECT (REACH IV-A AND IV-B) (PA24#2025.5)**313
Presenter: David Ruhl
Recommendation: Receive and file.

7. INFORMATIONAL REPORTS

Recommendation: Receive for information.

- A. **BRINE LINE FINANCIAL REPORT – OCTOBER 2024**319
Presenter: Karen Williams
- B. **BRINE LINE FINANCIAL REPORT – NOVEMBER 2024**325
Presenter: Karen Williams
- C. **GENERAL MANAGER REPORT**
Presenter: Jeff Mosher
- D. **COMMITTEE MEMBERS COMMENTS**
- E. **CHAIR’S COMMENTS/REPORT**

8. COMMITTEE MEMBER REQUESTS FOR FUTURE AGENDA ITEMS

9. CLOSED SESSION

There were no Closed Session items anticipated at the time of the posting of this agenda.

10. ADJOURNMENT

PLEASE NOTE:

In compliance with the Americans with Disabilities Act, if you need special assistance to participate in this meeting, please contact the Clerk of the Board at (951) 354-4220. Notification at least 48 hours prior to the meeting will enable staff to make reasonable arrangements to ensure accessibility to this meeting.

Materials related to an item on this agenda submitted to the Committee after distribution of the agenda packet are available for public inspection during normal business hours at the SAWPA office, 11615 Sterling Avenue, Riverside, and available at www.sawpa.org, subject to staff's ability to post documents prior to the meeting.

Declaration of Posting

I, Sara Villa, Clerk of the Board of the Santa Ana Watershed Project Authority declare that on January 30, 2025, a copy of this agenda has been uploaded to the SAWPA website at www.sawpa.gov and posted at SAWPA's office, 11615 Sterling Avenue, Riverside, California.

2025 Project Agreement 24 Committee Regular Meetings

Inland Empire Brine Line

First Tuesday of Every Month

(Note: All meetings begin at 10:00 a.m., or immediately following the 9:30 a.m. SAWPA Commission meeting, whichever is earlier, unless otherwise noticed, and are held at SAWPA.)

| | |
|--|--|
| January 1/7/25 Regular Committee Meeting [cancelled] | February 2/4/25 Regular Committee Meeting |
| March 3/4/25 Regular Committee Meeting | April 4/1/25 Regular Committee Meeting |
| May 5/6/25 Regular Committee Meeting | June 6/3/25 Regular Committee Meeting |
| July 7/1/25 Regular Committee Meeting | August 8/5/25 Regular Committee Meeting |
| September 9/2/25 Regular Committee Meeting | October 10/7/25 Regular Committee Meeting |
| November 11/4/25 Regular Committee Meeting | December 12/2/25 Regular Committee Meeting |

Page Intentionally Blank



PROJECT AGREEMENT 24 COMMITTEE
Inland Empire Brine Line
REGULAR MEETING MINUTES
December 3, 2024

COMMITTEE MEMBERS PRESENT

Gil Botello, San Bernardino Valley Municipal Water District Governing Board
Mike Gardner, Vice Chair, Western Municipal Water District Governing Board
David Slawson, Alternate, Eastern Municipal Water District Governing Board
Jasmin A. Hall, Inland Empire Utilities Agency Governing Board [via - zoom]

COMMITTEE MEMBERS ABSENT

None.

ALTERNATE COMMITTEE MEMBERS PRESENT [Non-Voting]

T. Milford Harrison, Chair, San Bernardino Valley Municipal Water District Governing Board [via - zoom]
Joe Mouawad, Eastern Municipal Water District General Manager [via - zoom]

STAFF PRESENT

Jeff Mosher, Karen Williams, David Ruhl, Dean Unger, John Leete, Rick Whetsel, Sara Villa,
Shavonne Turner, Marie Jauregui

OTHERS PRESENT

Andrew D. Turner, Lagerlof, LLP; Michael Barber, Inland Empire Utilities Agency; Julio Im,
Inland Empire Utilities Agency; Derek Kawaii, Western Municipal Water District; Bruce
Whitaker, Orange County Water District; Jeremy Jungreis, Orange Water County District; Leo
Ferrando, San Bernardino Valley Municipal Water District; Joe Zoba, Yucaipa Valley Water
District; Alison

1. CALL TO ORDER | PLEDGE OF ALLEGIANCE

The Regular Meeting of the PA 24 Committee was called to order at 10:49 a.m. by Vice Chair Mike Gardner on behalf of the Santa Ana Watershed Project Authority, 11615 Sterling Avenue, Riverside, CA 92503 and Commissioner T. Milford Harrison located at JW Marriott Desert Springs, 74-855 Country Club Drive, Room #483, Palm Desert, CA 92260

2. ROLL CALL

3. PUBLIC COMMENTS

There were no public comments; there were no public comments received via email.

4. ITEMS TO BE ADDED OR DELETED

There were no items to be added or deleted.

5. CONSENT CALENDAR

A. APPROVAL OF MEETING MINUTES: NOVEMBER 5, 2024

Recommendation: Approve as posted.

MOVED, to approve the Consent Calendar as posted.

| | |
|----------------|----------------------------------|
| Result: | Adopted by Roll Call Vote |
| Motion/Second: | Botello/Hall |
| Ayes: | Gardner, Hall, Harrison, Slawson |
| Nays: | None |
| Abstentions: | None |
| Absent: | None |

6. COMMITTEE DISCUSSION/ACTION ITEMS

A. AGREEMENT TO PURCHASE TREATMENT AND DISPOSAL CAPACITY RIGHTS (PA24#2024.24)

David Ruhl provided a presentation titled Agreement to Purchase Treatment and Disposal Capacity Rights, contained in the agenda packet on pages 11-22. The proposed agreement involves a capacity purchase arrangement between San Bernardino Valley Municipal Water District (Valley District) and SAWPA.

Orange County Sanitation District (OC San) has a treatment facility with a total capacity of 30 MGD. Currently, 17 MGD of this capacity has been purchased, based on the needs of our member agencies. Capacity is sold in 1 MGD increments, and we are required to purchase additional capacity when usage exceeds 17 MGD. The process works as follows: either a sub-agency or a member agency will request capacity from SAWPA, and we will notify OC San of the intent to purchase. This request is then brought to the PA 24 Committee, where an agreement between the member agency and SAWPA will be reviewed and approved. Additionally, the member agency will establish a separate agreement with their sub-agency to purchase the capacity.

Yucaipa Valley Water District (YVWD) dischargers RO concentrate from the Wochholz Regional Water Recycling Facility (Facility) to the Brine Line. YVWD is expanding their Facility and has requested from SAWPA through Valley District to purchase 0.505 million gallons per day (MGD) of Treatment and Disposal Capacity Right (Capacity). They are looking to purchase 0.505 MGD of capacity, with the project expected to be completed by 2026. SAWPA staff has reached out to OC San to see if they would be willing to sell capacity outside the current agreement, but they declined. OC San confirmed that additional capacity would only be available once we exceed the 17 MGD threshold, and we are currently at 12.2 MGD. As a result, we needed to develop an alternative solution to sell capacity to our member agencies.

While SAWPA has sold the 17 MGD of capacity to our member agencies, we are not consistently using all of it, which means there is unused capacity available for sale. We must maintain this capacity for our dischargers, but given that it is not being fully utilized, we have the opportunity to sell it to other agencies.

Mr. Ruhl referenced the pertinent points of the Capacity Purchase agreement as follows:

- Valley District acquires a Capacity right of 0.505 MGD at a wastewater strength of 20 mg/L Biological Oxygen Demand (BOD) and 20 mg/L of Total Suspended Solids (TSS), also expressed as 84.23 lbs./day BOD and 84.23 lbs./day TSS.
- The Calculated Purchase Price is \$4,485,896.77 and due upon execution of agreement.
- The Calculated Purchase Price is the current cost from OC San to purchase Capacity inflated to a point in time SAWPA is required to purchase Capacity from OC San.
- Inflated price is based on the historical increase in price from OC San, estimated at 1.5%.
- Estimated timeline when the Brine Line average flow will exceed SAWPA's currently owned Capacity is 5 years and is based upon the findings in the draft Brine Line Master Plan.

- SAWPA would hold the funds, and any interest earned, in the Brine Line Reserves until such time it is required to purchase Capacity from OC San (Final Purchase Price).
- The Valley District would pay the difference in the Final Purchase Price and the Calculated Purchase Price.
- Interest earnings may be used to offset the Final Purchase Price.
- If the calculated purchase price is overestimated, interest in the overestimated amount will be returned in addition to the amount overpaid.
- SAWPA will provide an annual accounting statement to Valley detailing interest earnings in the Reserve and the 0.25% deducted annually on the balance of funds to be retained by SAWPA.

Committee member Gil Botello commended Joe Zoba and his staff of Yucaipa Valley Water District on the guardrails built into the agreement, especially the provisions for changes in cost or interest. Committee Member Milford Harrison thanked staff for the continued relationship and noted he is in full support. Leo Ferrando of Valley District noted that over the past few weeks, staff have been collaborating on developing the agreements, both the one under consideration and the one between Valley District and YVWD. Valley District will present both agreements to the board for review and approval on December 17th.

Mr. Zoba highlighted his appreciation for the collaboration with both SAWPA and Valley District.

MOVED, to authorize the General Manager to execute a Treatment and Disposal Capacity Purchase Agreement with San Bernardino Valley Municipal Water District (Valley District), subject to minor, non-substantive changes contingent on concurrence by legal counsel.

| | |
|----------------|----------------------------------|
| Result: | Adopted by Roll Call Vote |
| Motion/Second: | Botello/Hall |
| Ayes: | Gardner, Hall, Harrison |
| Nays: | None |
| Abstentions: | None |
| Absent: | None |

B. LICENSE AGREEMENT WITH AT&T (PA24#2024.25)

Daniel Vasquez provided a presentation titled License Agreement with AT&T, contained in the agenda packet on pages 31-41. SAWPA is seeking approval to execute a license agreement with AT&T for the removal of existing telecommunications poles and the installation of a new conduit on SAWPA's fee property on Reach IV.

Mr. Vasquez noted that Phase 6 of the Santa Ana River Trail involves the construction of 1.5 miles of multi-use trail. SAWPA signed a Memorandum of Understanding (MOU) confirming participation in planning efforts, with subsequent amendments. In 2014, an Operations and Maintenance Agreement was signed between SAWPA and RivCo Parks for the construction of the Santa Ana River Trail below Prado Dam, extending to the Green River Golf Course for a 25-year period upon completion. Throughout the process, SAWPA has provided feedback in construction meetings with RivCo Parks, to ensure the preservation of the ongoing operations and maintenance of the brine line, as well as to account for any potential future construction, relocation, or replacement needs.

To accommodate the new Santa Ana River Trail railroad bridge crossing, AT&T has requested a license agreement to relocate its utilities within a strip of property we own. The new bridge will span these tracks, connecting the Green River Golf Course parking lot to the Santa Ana River Trail. AT&T proposes to remove existing poles and relocate their facilities underground to the northeast, across our fee property. Additionally, Southern California Edison has

proposed relocation of facilities, which we will present to the PA 24 Committee in a future meeting.

Mr. Vasquez noted that the license agreement is recommended to protect SAWPA's interests in the operation and maintenance of the brine line. Unlike an easement, this agreement does not relinquish our rights. It preserves our ability to negotiate relocation of facilities in the future, maintain access to our property, and be notified when work is being performed on our fee property. The license agreement specifically limits the use of our property to the relocation and upkeep of the proposed telecommunications facilities. There was no discussion.

MOVED, to authorize the General Manager to execute a License Agreement with AT&T to remove existing telecommunication poles and install a new telecommunication conduit in SAWPA's fee property on Reach IV.

| | |
|----------------|----------------------------------|
| Result: | Adopted by Roll Call Vote |
| Motion/Second: | Botello/Slawson |
| Ayes: | Gardner, Hall, Harrison |
| Nays: | None |
| Abstentions: | None |
| Absent: | None |

7. **INFORMATIONAL REPORTS**

Recommendation: Receive and file the following oral/written reports/updates.

A. **BRINE LINE FINANCIAL REPORT – JULY 2024**

B. **FINANCIAL REPORT FOR THE INLAND EMPIRE BRINE LINE ENTERPRISE/CIP FOR THE FOURTH QUARTER ENDING JUNE 30, 2024**

Karen Williams noted that we have more revenue than anticipated, which is always positive, and the expenditure is lower than projected. A more detailed verbal presentation will be provided as we move further into the year.

C. **GENERAL MANAGER REPORT**

Jeff Mosher noted that the PA 24 Committee meeting scheduled for January 7th will be cancelled, and the next meeting will be held on February 4, 2025.

D. **COMMITTEE MEMBERS COMMENTS**

Committee Member Harrison noted that we should pay closer attention to the calendars of our partner agencies, for instance, ACWA and CSDA, to avoid conflicts like the one that is being faced today. It is becoming cumbersome, and it is challenging to accommodate everything happening at once, but we should do everything we can to minimize these conflicts moving forward.

E. **CHAIR'S COMMENTS/REPORT**

There were no comments/reports from the Chair.

8. **COMMITTEE MEMBER REQUESTS FOR FUTURE AGENDA ITEMS**

There were no requests for future Agenda items.

9. **CLOSED SESSION**

There was no Closed Session.

10. **ADJOURNMENT**

There being no further business for review, Committee Vice Chair Mike Gardner adjourned the Regular meeting at 11:30 a.m.

Approved at a Regular Meeting of the Project Agreement 24 Committee on February 4, 2025.

T. Milford Harrison, Chair

Attest:

Sara Villa, Clerk of the Board

Page Intentionally Blank

PA 24 COMMITTEE MEMORANDUM NO. 2025.1

DATE: February 4, 2025

TO: Project Agreement 24 Committee
(Inland Empire Brine Line)

SUBJECT: OC San / SAWPA Joint Policy Committee

PREPARED BY: Jeff Mosher, General Manager

RECOMMENDATION

That the Project Agreement 24 Committee appoint two Commissioners to the Orange County Sanitation District (OC San) / Santa Ana Watershed Project Authority (SAWPA) Joint Policy Committee.

DISCUSSION

The OC San/SAWPA Joint Policy Committee meets annually with designated OC San Board Members to consider present and future policy matters. Discussions have included strategic planning, collaboration on legislative issues impacting brine discharge, emerging constituents, and funding opportunities. Staff requests the appointment of two Commissioners to serve on this Committee.

RESOURCE IMPACTS

None

Page Intentionally Blank

PA 24 COMMITTEE MEMORANDUM NO. 2025.2

DATE: February 4, 2025

TO: Project Agreement 24 Committee
(Inland Empire Brine Line)

SUBJECT: Amendment to the PA 24 Agreement – Appointment of Alternate Representatives

PREPARED BY: Jeff Mosher, General Manager

RECOMMENDATION

It is recommended that the PA 24 Committee approve the amendment to the Project Agreement 24 (PA 24 Agreement) dated July 17, 2019, allowing for the appointment of two (2) alternate representatives.

DISCUSSION

Currently, the PA 24 Agreement document dated July 17, 2019, allows for one (1) alternate representative to the PA 24 Committee. To ensure consistent representation, facilitate continuity, and enhance decision-making capabilities during times when primary members may be unavailable, it is recommended that the PA 24 Agreement be amended to allow a PA 24 Committee Member to appoint at its sole discretion up to two of the following to act as alternates to the PA 24 Committee: any member of its governing board, its general manager, and/or a senior-level manager who holds a leadership position within the organization.

- **Designation of Alternates:** Each PA 24 Committee member may have two (2) alternates (senior staff representatives) who are familiar with committee topics and decision-making responsibilities.
- **Scope of Responsibilities:** Alternates will have the authority to participate fully in committee discussions and decisions when serving in the absence of the primary member.
- **Documentation Requirements:** Each appointment, including the designated alternates, should be documented in writing and submitted to the PA 24 Committee Secretary.

On January 21, 2025, the SAWPA Commission approved the recommendation of amending the PA 24 Agreement dated July 17, 2019, allowing for the appointment of two (2) alternate representatives.

RESOURCE IMPACTS.

None.

Attachments:

1. Amendment No. 1
2. PA 24 Agreement

Page Intentionally Blank

**AMENDMENT NO. 1 TO THE
SANTA ANA WATERSHED PROJECT AUTHORITY
PROJECT AGREEMENT 24
INLAND EMPIRE BRINE LINE**

RECITALS

WHEREAS, the Santa Ana Watershed Project Authority (“SAWPA”), a joint powers agency and the following Member Agencies of SAWPA, referred to hereinafter as Project Agreement 24 (“PA 24”) Committee Members: Eastern Municipal Water District (“EASTERN”); Inland Empire Utilities Agency (“IEUA”); San Bernardino Valley Municipal Water District (“VALLEY”); and Western Municipal Water District (“WESTERN”).

WHEREAS, the Member Agencies of SAWPA desire to amend the PA 24 Agreement to provide for a more efficient governing structure.

NOW, THEREFORE, the PA 24 Committee and the governing boards of each of its Member Agencies hereby amend the PA 24 Agreement as follows:

- A. Section 1 entitled “Covenants” of the PA 24 Agreement is hereby amended to supersede the existing language with the following replacement language:
- “ 1. The PA 24 Committee is hereby established for the purpose of establishing policy and providing oversight of the Brine Line operations, maintenance, planning, administration, implementation, and improvement of the Brine Line, including but not limited to rate-setting and revenue collection, permit issuance and enforcement, and usage of the Brine Line Enterprise Fund. In accordance with Section 18 of the SAWPA Joint Powers Agreement, a PA 24 Committee Member may appoint at its sole discretion any member of its governing board or its general manager as its primary representative. Additionally, a PA 24 Committee Member may appoint at its sole discretion up to two of the following to act as alternates to the PA 24 Committee: any member of its governing board, its general manager, and/or a senior-level manager who holds a leadership position within the organization. The PA 24 Committee will appoint SAWPA’s two Commissioners to the Joint Policy Committee with OCSD.”
- B. Effective Date. This Amendment No. 1 may be executed in counterparts and shall become effective when the governing boards of SAWPA’s Member Agencies have authorized the execution of, and subsequently executed, this Amendment. Except as otherwise provided for in this Amendment No. 1, the remaining terms and conditions of the PA 24 Agreement shall remain in full force and effect.

IN WITNESS WHEREOF, the signatories hereto have executed this Amendment No. 1 to the PA 24 Agreement to be effective on the day and year hereinafter indicated.

SANTA ANA WATERSHED PROJECT AUTHORITY

By _____ Date _____

Its _____

EASTERN MUNICIPAL WATER DISTRICT

By _____ Date _____

Its _____

INLAND EMPIRE UTILITIES AGENCY

By _____ Date _____

Its _____

SAN BERNARDINO VALLEY MUNICIPAL WATER DISTRICT

By _____ Date _____

Its _____

WESTERN MUNICIPAL WATER DISTRICT

By _____ Date _____

Its _____

SANTA ANA WATERSHED PROJECT AUTHORITY

PROJECT AGREEMENT 24

INLAND EMPIRE BRINE LINE

THIS AGREEMENT is made on July 17, 2019, by and between the **SANTA ANA WATERSHED PROJECT AUTHORITY (“SAWPA”)**, a joint powers agency created pursuant to Government Code Section 6500 et seq., and the following Member Agencies of SAWPA, referred to hereinafter as Project Agreement 24 (“PA24”) Committee Members: **EASTERN MUNICIPAL WATER DISTRICT (“EASTERN”); INLAND EMPIRE UTILITIES AGENCY (“IEUA”); SAN BERNARDINO VALLEY MUNICIPAL WATER DISTRICT (“VALLEY”);** and **WESTERN MUNICIPAL WATER DISTRICT (“WESTERN”)**. The PA24 Committee members and SAWPA are jointly referred to herein as the “Parties.”

RECITALS

- A. The PA24 Committee Members are all special districts with broad authority over water resources, including powers to develop, protect, and enhance water supply and reliability within the region and to protect and preserve the quality of the surface and subsurface water supplies within their respective boundaries.
- B. The SAWPA Joint Powers Agreement, as amended, provides for SAWPA’s exercise of the shared powers of the Member Agencies, and recognizes SAWPA shall function through the identification and implementation of specific projects. The JPA establishes that such specific projects will be administered through individual project agreements and by project committees (“Project Committees”) when less than all of the SAWPA member agencies are participating.
- C. SAWPA owns and operates the Inland Empire Brine Line (“BRINE LINE”). The BRINE LINE is a wastewater pipeline conveyance system and was constructed for the transmission of non-reclaimable wastewater. The pipeline extends from its connection to the Orange County Sanitation District’s (“OCSD”) Santa Ana River Interceptor (“SARI”) at the Riverside County-Orange County boundary into the upper Santa Ana River watershed. As of the date of this Agreement SAWPA owns a 30-million gallons per day capacity right in the SARI that is subject to certain payment obligations and other terms and conditions including a Waste Water Interceptor Capacity Agreement with OCSD dated April 12, 1972 and subsequently amended.
- D. SAWPA member agencies formed a number of separate project agreements pursuant to Section 18 of the SAWPA Joint Powers Agreement for the study, design, or construction of parts of the BRINE LINE. Some of those project agreements also purported to address maintenance. In practice, SAWPA has operated the BRINE LINE as one infrastructure system as components were completed and added on, and currently none of the earlier project agreements or project committees related to BRINE LINE development remain active.

- E. As of the date of this Agreement SAWPA also owns a treatment and disposal capacity right of 17 million gallons per day, with a right to purchase additional capacity, in certain wastewater treatment and disposal facilities owned by OCSD. This treatment and disposal right is subject to certain payment obligations and other terms and conditions including a Treatment and Disposal Capacity Agreement with OCSD dated July 24, 1996.
- F. Since the early 1980s, SAWPA has entered into various written agreements with EASTERN, IEUA, VALLEY, WESTERN, and Orange County Water District (OCWD) regarding purchase and sale of pipeline capacity rights and treatment and disposal rights in the SARI and BRINE LINE.
- G. BRINE LINE policies are established by Ordinances and Resolutions that have been adopted by the SAWPA Commission, including Ordinance No. 8: "An Ordinance of the Santa Ana Watershed Project Authority Establishing Regulations for the Use of the Inland Empire Brine Line." Current Resolutions establish local limits on discharges, establish the purchase price for treatment and disposal capacity rights, and establish rates. SAWPA implements a comprehensive pretreatment program and issues or directly oversees issuance of permits to all dischargers. SAWPA complies with its agreements with OCSD through implementation of a 1991 MOU, which clarified roles and responsibilities in that relationship. In terms of water quality compliance, SAWPA's program documents clearly recognize OCSD as the Control Authority for discharges to the BRINE LINE, and SAWPA as the Delegated Control Authority. SAWPA and OCSD formed a Joint Policy Committee in 2013 to provide a regular forum to discuss and coordinate policy positions and avoid or manage conflicts. Two SAWPA Commissioners are appointed by SAWPA to serve on the Joint Policy Committee.
- H. SAWPA complies with the State Water Resources Control Board Order No. 2006-0003, a General Waste Discharge Requirement for all publicly owned sanitary sewer collection systems in California with more than one mile of sewer pipe. One component of Order No. 2006-0003 is the development and implementation of a Sewer System Management Plan ("SSMP") that defines provisions for management of the system to limit Sanitary Sewer Overflows. SAWPA adopted its SSMP in April 2009 and has been implementing its provisions since then.
- I. SAWPA maintains insurance policies covering BRINE LINE operations, including risks of wastewater spills and property damage.
- J. Operating the BRINE LINE is complex, requiring short- and long-term planning regarding future use and flows, capital improvements, financial modeling, recurring and nonrecurring operations and maintenance, regulatory compliance, relations with OCSD, marketing and community relations, and other evolving issues. Consistent with the requirements of the SAWPA Joint Powers Agreement, a Project Committee is required to oversee the administration and implementation of these and other project-related activities for the BRINE LINE.

- K. By this Agreement, the Parties wish to supersede and replace Project Agreement 21, originally executed on December 21, 2010, per Section 18 of the SAWPA Joint Powers Agreement. The Parties hereto desire to create Project Committee 24 to provide policy direction and oversight of the BRINE LINE.

COVENANTS

Based on the foregoing facts, and in consideration of the mutual covenants of the PA24 Committee Members and SAWPA, it is agreed that:

1. The PA24 Committee is hereby established for the purpose of establishing policy and providing oversight of the BRINE LINE operations, maintenance, planning, administration, implementation, and improvement of the BRINE LINE, including but not limited to rate-setting and revenue collection, permit issuance and enforcement, and usage of the Brine Line Enterprise Fund. In accordance with Section 18 of the SAWPA Joint Powers Agreement, a PA24 Committee Member may appoint at its sole discretion any member of its governing board or its general manager as its representative and/or alternate to the PA 24 Committee. The PA24 Committee will appoint SAWPA's two Commissioners to the Joint Policy Committee with OCSD.
2. Facilities constructed for the purposes of this Project Agreement will be owned by SAWPA for the benefit of the PA24 Committee. The PA24 Committee shall approve any necessary agreements that specify how existing BRINE LINE infrastructure and all future facility improvements will be financed, designed, constructed, operated, and maintained.
3. The PA24 Committee will be operated as a distinct account within SAWPA's accounting system for the administration by SAWPA of Brine Line Enterprise Funds and for any other funds that may be made available to the PA24 Committee for actions within the Committee's purpose.
4. The PA24 Committee will constitute the executive authority through which SAWPA shall act for purposes of this Project Agreement.
5. All budget and operating decisions of the PA24 Committee will be made by unanimous consent of the PA24 Committee Members. The Parties agree that "operating decisions" are those that involve significant, system-wide decisions about how the BRINE LINE will function, including decisions concerning: physical repairs or alterations that could result in an impairment of use of the BRINE LINE. "Operating decisions" are not intended to include those involving day-to-day functioning, implementing the provisions of the SSMP, , or matters mandated by law, regulation, or permits, or in response to emergencies. Authority is hereby delegated to the SAWPA General Manager, up to the expenditure authority provided by SAWPA's Procurement Policy, to take such actions.
6. The PA24 Committee will have, without further ratification by the PA24 Committee Members or SAWPA, such authority as may be necessary to implement the provisions of this Project Agreement so long as expenditures are within the PA24 budget. Consistent with Section 26 of the SAWPA Joint Powers Agreement, any expenditure or contractual commitment which exceeds the PA24 budget must be approved by unanimous consent of the PA 24 Committee Members. Any expenditures or contractual commitments within the designations and


limitations of the approved PA24 budget shall be made on the authorization of a majority of the PA24 Committee. This section does not limit the authority the SAWPA General Manager has to respond to emergencies.

7. SAWPA funds all aspects of BRINE LINE operations, maintenance, planning, administration, and improvements through rates set as described herein that are paid by the Parties and other contractual dischargers as a fee for service. SAWPA has used debt financing for some BRINE LINE improvements that is guaranteed by a pledge of rate revenue for repayment. Rates that are established by the PA24 Committee and approved by a majority of SAWPA commissioners representing PA24 members, take effect upon approval and are not dependent on the approval of the PA24 budget. OCWD is not a member of PA24 and will not vote on Brine Line rates at the Commission. With four members voting, a split vote of two members in favor and two members in opposition is insufficient for approval as it does not represent a majority. Under such circumstances the proposed rates will be returned to the PA24 Committee for additional study and development of a revised rate recommendation. Approval of the proposed rates shall not be unreasonably withheld by the SAWPA commissioners representing PA24 members. Should rates not be approved by a majority of SAWPA commissioners representing PA24 members, the most recently approved rates shall stay in effect.
8. In conjunction with each SAWPA budget, SAWPA shall prepare a budget for the PA24 BRINE LINE project (PA24 budget) that shall address the sources and uses of funds and the respective financial obligations and functions of the PA24 Committee Members, including the matching funds included in any grant agreements. The budget shall include costs for SAWPA support of the PA24 Committee. If any PA24 Committee Member fails or refuses to approve any PA24 budget, said budget shall be returned to the PA24 Committee for restudy and revision. In the event a budget acceptable to all of the PA24 Committee members is not obtained prior to the start of the fiscal year, SAWPA shall continue to operate the BRINE LINE at the level of total expenditure authorized by the last approved PA24 budget for administrative, operations and maintenance activities, and shall continue with the construction of contractually authorized capital improvement projects included in the last approved PA24 budget. The PA24 Committee Members shall be obligated to fund such administrative, operations and maintenance activities to the same extent as in the previously approved budget, and to fund capital improvement projects under contract at previously authorized expenditure and contracting limits. For administrative convenience, the PA24 budget shall be included with the SAWPA budget for approval by the PA 24 Committee Members' governing boards per the SAWPA Joint Powers Agreement. Approval of the proposed PA24 budget shall not be unreasonably withheld by the SAWPA PA 24 Committee Members. SAWPA shall provide a quarterly report to the PA24 Committee of actual expenses relative to the approved budget.
9. The PA24 Committee Members shall be solely financially responsible for all liabilities and expenses, including administrative, consultant and legal expenses incurred in connection with PA24 activities, and to the extent necessary shall reimburse SAWPA for any and all such costs and expenses that are incurred on behalf of the PA24 Committee to the extent not otherwise covered by PA24 revenues or funds, or SAWPA's liability insurance. Unless otherwise specified by unanimous Committee action, PA24 Committee Members shall have an equal share in such financial obligation.

10. The PA24 Committee Members will indemnify and hold harmless SAWPA and any SAWPA member agency not then participating as a member of the PA24 Committee from any and all financial liability, including claims or disputes, arising from or in connection with the operation, maintenance, or repair of the BRINE LINE and other PA24 facilities, and any project-related contracts or actions, to the extent such liability is not fully covered by budgeted PA24 revenues or funds, or SAWPA's insurance.
11. PA24 Committee Members may withdraw from this Project Agreement at any time upon not less than 60 days written notice to the other members. Obligations of the withdrawing agency, including any liabilities related to any grant agreement or other financing commitment associated with PA24, will be determined according to the PA24 budget then in effect or by the PA24 Committee. Pursuant to Section 8 of the SAWPA Joint Powers Agreement, no withdrawal shall relieve the withdrawing agency from financial obligations theretofore incurred by it under this Agreement.
12. No right, duty, or obligation of whatever kind or nature created herein will be assigned by any party to this Project Agreement without the prior written consent of SAWPA.
13. This Project Agreement shall inure to the benefit of and bind the successors and assigns of the parties hereto.
14. Each signatory hereto warrants that the execution of this Project Agreement represents the approval of that Agency's board of directors of this Agreement.
15. This Project Agreement may be executed in counterparts.
16. The Recitals are incorporated herein and made an operative part of this Agreement.
17. Except as otherwise specifically provided for in this Agreement, the provisions of the SAWPA Joint Powers Agreement, as amended, shall be controlling in regard to the performance of this Agreement.

IN WITNESS WHEREOF, the signatories hereto have executed this Project Agreement to be effective as of the day and year first written above.

SANTA ANA WATERSHED PROJECT AUTHORITY

By 
Richard E. Haller, P.E.
Its General Manager

EASTERN MUNICIPAL WATER DISTRICT

By _____

Its _____

- 10. The PA24 Committee Members will indemnify and hold harmless SAWPA and any SAWPA member agency not then participating as a member of the PA24 Committee from any and all financial liability, including claims or disputes, arising from or in connection with the operation, maintenance, or repair of the BRINE LINE and other PA24 facilities, and any project-related contracts or actions, to the extent such liability is not fully covered by budgeted PA24 revenues or funds, or SAWPA's insurance.
- 11. PA24 Committee Members may withdraw from this Project Agreement at any time upon not less than 60 days written notice to the other members. Obligations of the withdrawing agency, including any liabilities related to any grant agreement or other financing commitment associated with PA24, will be determined according to the PA24 budget then in effect or by the PA24 Committee. Pursuant to Section 8 of the SAWPA Joint Powers Agreement, no withdrawal shall relieve the withdrawing agency from financial obligations theretofore incurred by it under this Agreement.
- 12. No right, duty, or obligation of whatever kind or nature created herein will be assigned by any party to this Project Agreement without the prior written consent of SAWPA.
- 13. This Project Agreement shall inure to the benefit of and bind the successors and assigns of the parties hereto.
- 14. Each signatory hereto warrants that the execution of this Project Agreement represents the approval of that Agency's board of directors of this Agreement.
- 15. This Project Agreement may be executed in counterparts.
- 16. The Recitals are incorporated herein and made an operative part of this Agreement.
- 17. Except as otherwise specifically provided for in this Agreement, the provisions of the SAWPA Joint Powers Agreement, as amended, shall be controlling in regard to the performance of this Agreement.

IN WITNESS WHEREOF, the signatories hereto have executed this Project Agreement to be effective as of the day and year first written above.

SANTA ANA WATERSHED PROJECT AUTHORITY

By _____

Its _____

EASTERN MUNICIPAL WATER DISTRICT

By *[Signature]*

Its *General Manager*

INLAND EMPIRE UTILITIES AGENCY

By Shivaji Deshmukh

Its Shivaji Deshmukh, General Manager

SAN BERNARDINO VALLEY MUNICIPAL WATER DISTRICT

By _____

Its _____

WESTERN MUNICIPAL WATER DISTRICT

By _____

Its _____

INLAND EMPIRE UTILITIES AGENCY

By _____

Its _____

SAN BERNARDINO VALLEY MUNICIPAL WATER DISTRICT

By  _____

Its Board President _____

WESTERN MUNICIPAL WATER DISTRICT

By _____

Its _____

INLAND EMPIRE UTILITIES AGENCY

By _____

Its _____

SAN BERNARDINO VALLEY MUNICIPAL WATER DISTRICT

By _____

Its _____

WESTERN MUNICIPAL WATER DISTRICT

By *Ray Miller*

Its *General Manager*

Page Intentionally Blank

PA 24 COMMITTEE MEMORANDUM NO. 2025.2

DATE: February 4, 2025

TO: Project Agreement 24 Committee
(Inland Empire Brine Line)

SUBJECT: Inland Empire Brine Line Data Management System Request for Proposal (RFP)

PREPARED BY: Lucas Gilbert, Manager of Permitting and Pretreatment

RECOMMENDATION

That the Project Agreement 24 Committee direct staff to release an RFP for Data Management System Software for the Inland Empire Brine Line Pretreatment Program.

DISCUSSION

The purpose of the RFP is to obtain a Data Management System (DMS) to replace the current system that will no longer be supported after December of 2025. SAWPA's Pretreatment Program has used a DMS software called iPACS since 2014. The iPACS system is built on the Microsoft.net framework, which is being sun-setted by Microsoft in December of 2025. The iPACS system will not have support for its framework beyond that date. The DMS is necessary to administer SAWPA's industrial pretreatment program in accordance with the requirements of the Code of Federal Regulations (§40CFR403). The RFP is to provide software development and configuration, to install and test the application, provide training and documentation, provide ongoing technical support, and other tasks as described in the Technical Specifications (Attachment E of the RFP). The application will be accessible remotely through the internet by Member Agencies and other agencies that are part of SAWPA's Pretreatment Program. Additionally, the new DMS will have improvements to streamline data entry demands of SAWPA and agency staff with CROMERR certification to allow for electronic reporting of pretreatment submittals. CROMERR stands for Cross-Media Electronic Reporting Rule and provides the legal framework by which EPA will accept electronic reports from regulated agencies. A copy of the RFP is attached.

Tentative Schedule:

| | |
|---------------------------|------------------|
| Issue RFP | February 4, 2025 |
| Receive Proposals | March 13, 2025 |
| Contract Award | April 2025 |
| Implement Use of Software | October 1, 2025 |

RESOURCE IMPACTS

Funds to cover the software are included in the Fiscal Year (FY) 2024-25 and FY 2025-26 Budget Fund 240 (Brine Line Enterprise).

Attachments:

1. RFP
2. Power Point Presentation

Page Intentionally Blank



SANTA ANA WATERSHED PROJECT AUTHORITY

REQUEST FOR PROPOSALS

FOR

**DATA MANAGEMENT SYSTEM SOFTWARE
FOR THE INLAND EMPIRE BRINE LINE
PRETREATMENT PROGRAM**

February 2025

**REQUEST FOR PROPOSALS
FOR
SANTA ANA WATERSHED PROJECT AUTHORITY
DATA MANAGEMENT SYSTEM SOFTWARE FOR THE INLAND EMPIRE
BRINE LINE PRETREATMENT PROGRAM**

NOTICE TO SUBMITTING FIRMS

Proposals submitted in response to this RFP as described herein, will be submitted to Planet Bids at: <https://pbsystem.planetbids.com/portal/52676/portal-home>

1. Submit electronically, as a single Adobe Acrobat (PDF) file, with search capability to ensure readability and compatibility, **not more than 10 pages long** (not including cover letter, exhibits, and resumes), and **not more than 10 megabytes in size**.
2. All proposals must be received by **3:00 p.m. (PST) on Thursday, March 13, 2024**.
3. Prospective Offerors are required to submit all RFP questions, clarifications, or comments through Planet Bids' Q&A system at:
<https://pbsystem.planetbids.com/portal/52676/portal-home>.
Questions, clarifications, or comments must be received no later than **Monday, March 3, 2025, at 4:00 pm PST**.
4. Any changes to this RFP are invalid unless specifically modified by SAWPA and issued as a separate addendum document. Should there be any question as to changes to the content of this document, SAWPA's copy shall prevail. It is the submitting firm's sole responsibility to ensure that their submittal, inclusive of any or all addenda, is received at the proper place at the proper time. SAWPA will not accept submittals after the due date/time listed above.

**REQUEST FOR PROPOSALS
FOR
DATA MANAGEMENT SYSTEM SOFTWARE FOR THE INLAND EMPIRE
BRINE LINE PRETREATMENT PROGRAM**

1) Introduction

Agency Background

The Santa Ana Watershed Project Authority (SAWPA) was formed in 1972 to plan and build facilities to protect water quality in the Santa Ana River Watershed. SAWPA is a Joint Powers Authority (JPA) comprised of five (5) member agencies: Eastern Municipal Water District (EMWD), Inland Empire Utilities Agency (IEUA), Orange County Water District (OCWD), San Bernardino Valley Municipal Water District (SBVMWD), and Western Municipal Water District (WMWD). To learn more about SAWPA please visit www.sawpa.gov

Background

SAWPA's Inland Empire Brine Line Pretreatment Program has used a Database Management System (DMS) software since 2014. SAWPA is requesting proposals to replace or otherwise update this system with a new DMS. The DMS is necessary to administer SAWPA's industrial pretreatment program in accordance with the requirements of the Code of Federal Regulations (§40CFR403). The software system is configurable. This configurability allows SAWPA staff to make changes (application data, reports and forms) without requiring programming support from the vendor. This feature allows SAWPA to customize the software quickly and without additional cost for programming by the vendor.

Project Description

The project is to provide software development and configuration, to install and test the application, provide training and documentation, provide ongoing technical support, and other tasks as described in the RFP. The application will be accessible remotely through the internet by Member Agencies and other agencies that are part of SAWPA's Pretreatment Program. Additionally, the new DMS will have improvements to streamline data entry demands of SAWPA and agency staff with CROMERR certification to allow for electronic reporting of pretreatment submittals.

Services

The general requirements for services of the DMS shall include: 1) standardized software specific to industrial pretreatment; 2) software system configurability; 3) software ease-of-use; 4) portal for electronic reporting and compliance with CROMERR and 5) pretreatment market longevity.

2) Schedule

| | |
|---|---|
| February 5, 2025 | Issue Request for Proposals |
| March 13, 2025 | Proposals due (3:00 p.m.) |
| April 2025 | Contract Award |
| July 1, 2025 | Deliver completed information management system application to SAWPA including all project specific tailoring |
| July 31, 2025 | Provide documentation and complete training |
| August 1, 2025 | Support trial use of software |
| October 1, 2025 | Implement use of software |
| Annual software updates and ongoing technical support | |

3) Proposal Instructions and Conditions

- a) **Pre-Contractual Expenses** - Pre-Contractual expenses are defined as expenses incurred by prospective bidders in:

- Preparing a proposal in response to the RFP.
- Submitting that proposal to SAWPA.
- Negotiating with SAWPA in any matter related to this RFP, proposal, and/or contractual agreement.
- Any other expenses incurred by the prospective bidder prior to the date of an executed contract.

SAWPA will not, in any event, be liable for any pre-contractual expenses incurred by any prospective bidder. In addition, no prospective bidder shall include any such expenses as part of the price proposed to perform the requested services.

- b) **Authority to Withdraw RFP and/or Not Award Contract** – SAWPA reserves the right to withdraw the RFP at any time without prior notice. Further, SAWPA makes no representations that any agreement will be awarded to any prospective bidder responding to this RFP. SAWPA expressly reserves the right to postpone the opening of proposals for its own convenience and to reject any and all proposals in response to this RFP without indicating any reasons for such rejection(s).
- c) **Right to Reject Proposal** – SAWPA reserves the right to reject any or all proposals submitted. Any award made for this engagement will be made to the firm/s, which, in the opinion of SAWPA, is best qualified to perform the services and represents the best value and effectiveness.
- d) **Discrepancies in Proposal Documents** – Should prospective firms find discrepancies in, or omissions from the RFP, or if the intent of the RFP is not clear, and if provisions of the specifications restrict any prospective firm from proposing, they may request in writing that the deficiency(s) be modified. Such request must be received by SAWPA at least ten (10) working days before the proposal due date. All registered firms will be notified by addendum of any approved changes in the request for proposal documents.

- e) **Oral Statements** - SAWPA is not responsible for oral statements made by any of its employees or agents concerning the RFP. If the prospective firm requires specific information, a written request must be submitted to SAWPA.

4) **Scope of Work**

The software proposal will include, but not be limited to the following tasks:

- a) The general requirements include: 1) standardized off-the-shelf software specific to industrial pretreatment; 2) software system configurability; 3) software ease-of-use and 4) pretreatment market longevity.
 - i) The software shall be a proven industrial pretreatment software program, readily deliverable with a minimum of vendor education and has already been through several versions. Software shall be upgradable in a cost effective manner as new features are made available. The vendor shall provide a mature software product specific to industrial pretreatment program management, tracking and reporting.
 - ii) The software shall be configurable. The configurability requirement must allow SAWPA staff to make changes (application data, reports and forms) without requiring programming support from the vendor. This feature shall allow SAWPA to customize the software quickly and without additional cost for programming by the vendor.
 - iii) The software shall be easy to use. "Easy-to-use" software is defined to promote and facilitate use while requiring less training for SAWPA pretreatment personnel. Ease of use shall promote efficiency in managing, reporting and distributing information between SAWPA and other associated staff, both internal and external to the SAWPA organization.
 - iv) The software shall have industrial pretreatment market longevity. As long-term use is required, the vendor shall provide industrial pretreatment software upgrades and support necessary to keep the software current with existing and emerging federal, state and local pretreatment laws and regulations. SAWPA will work with a vendor who can demonstrate that the vendor will be in a position to provide future software upgrades that are consistent with trends in the industrial pretreatment market.
 - v) The software shall work within the existing SAWPA IT standards and environment. Any potential conflicts shall be noted and a description of how the conflicts will be overcome will be included with the Vendor's proposal.
- b) The specific requirements of the software includes:
 - i) Web/Cloud based: Software shall have the ability for SAWPA, its contributing agencies, and other approved agencies, to use a browser or other dashboard application to login as appropriate remotely for entry, editing, and/or viewing of information.

- ii) Software shall have the ability to export all data (permit, inspection, enforcement, sample, or other data) into various formats such as MS Excel, MS Word, PDF, etc.
 - iii) Software shall allow a minimum of Twenty-five (25) concurrent users and be able to be increased in the future as needed without additional programming by the Vendor.
 - iv) Software shall have the ability to support wireless interfaces to mobile devices (such as cell phones, tablets, and lab notebooks). The software shall have the minimum technical requirements for mobile devices to operate proficiently.
 - v) Software shall fully comply with CROMERR requirements for electronic reporting, including but not limited to:
 1. Secure user authentication (multi-factor authentication preferred).
 2. Data integrity measures, including digital signatures, audit trails, and tamper-evident controls.
 3. Submission tracking to confirm receipt and maintain records of all transactions.
 4. Long-term data retention capabilities that meet federal and state requirements.
 5. Includes documentation of CROMERR certification by the EPA or the ability to obtain certification during implementation.
 - vi) Software shall support integration with other systems, including APIs for data exchange.
 - vii) Software shall have high availability, with robust backup, recovery, and disaster recovery capabilities.
- c) Industry Management
- i) The software shall, as a minimum, be able to store, access, edit, and filter by permit the stored information as identified in SAWPA Permit and Permit Application Documents.
 - ii) The software shall, as a minimum, be able to store, access, edit, and filter by permit the stored information for Liquid Waste Haulers as identified in SAWPA Permit and Permit Application Documents.
 - iii) The software shall allow the user to re-issue permits and change permit numbers and/or names, while maintaining relationships to existing limits, samples, results, violations and history.
 - iv) The software shall be able to store and access multiple outfalls and sample points, and associated parameter limits for the facilities, including QA/QC sampling (blanks, duplicates, etc) and special sampling requirements for SAWPA at the SARI Metering Station (SMS) located at the Orange County line (entry point for wastewater to Orange County Sanitation District's system).
 - v) The software shall be able to store effective dates for all parameter limits, thereby insuring that changing a compliance parameter limit does not affect past sample results compliance limits.
 - vi) The software shall be able to track multiple facilities per site and provide filtering capabilities on site identification.

- vii) The software shall have configurable Notes and Note Types per facility.
 - viii) The software shall be able to store unlimited SIC, Federal Categorical and NAICS Codes per facility.
 - ix) The software shall generate permits with real-time data. Permit templates, as well as Permit Fact Sheet templates, shall be completely modifiable by user to meet users permitting needs. Multiple templates shall be stored for each permit section. The software shall have the ability to import and use existing permit templates.
 - x) The software shall provide validation routines to ensure all required fields are populated.
 - xi) The software shall maintain historical information for all data fields.
 - xii) The software shall maintain audit trail for certain critical data.
- d) Facility Discharge Limits and Requirements
- i) User shall be able to enter basic information on sampling locations, including but not limited to:
 1. Location.
 2. Description of sampling location.
 3. Representative production flow base.
 4. Designate the constituents that apply to the sample point.
 5. Ability to have more than one sample point for one permit but a one to one relationship for each constituent.
 6. Photo storage.
 7. GPS location.
 - ii) User shall be able to enter special condition requirements with due dates and multiple due dates, including:
 1. Schedule follow-up inspections, samples, or submittals to verify task completion.
 2. Ability to extend due dates for task completion.
 3. Track all conditions, due dates and extensions.
 - iii) User shall be able to enter discharge limits for each sampling location as well as the following information:
 1. Maintain historical record of wastewater discharge limits for each sampling point.
 2. Each sampling location shall have multiple choices of limits, federal and local, that apply to a particular constituent and the more stringent limit should be applied unless overridden by a combined waste stream and/or production based discharge limit value.
 3. Support many limit types, both calculated and non- calculated, including instantaneous max, daily max, 4-day averages, thirty day average, monthly average concentration limits; daily max, 4-day averages, thirty day average, monthly average mass based

- limits; daily max, 4-day averages, thirty day average, monthly average production limits and/or combined waste stream limits.
 - 4. Enter Federal Categories for facilities with zero-discharge.
 - 5. Override standard limits for exceptional cases.
 - 6. Results from specific analytes to compare against specific limits using specific and different criteria (e.g. TTOs, PCBs, Pesticides).
 - 7. Information relative to acceptable methods, special sample/hold times, preservatives, bottles, flags, analyst, RDIs/MDLs, Sample # (SAWPA's and Lab's), Lab name.
- iv) User shall be able to manage self-monitoring reporting requirements on a sample location, including:
- 1. Track compliance at a pollutant level.
 - 2. Support various reporting intervals and due-dates per location per constituent.
 - 3. If the constituent reporting intervals are modified to be more restrictive the effective date for the new limits shall be able to manually be moved to first day of the month beyond 45 days of the constituent reporting intervals change notification.
 - 4. Support one-time requirements as well as recurring requirements.
 - 5. Special frequencies for enforcement schedules and special circumstances.
 - 6. Ability to distinguish pollutant groups and the ability to handle individual pollutants within each group, e.g., total metals and copper.
- v) User shall be able to enter non-discharge reporting requirements at both a facility level and sampling location level, e.g., meter reading, BMPs, progress reports and water bills, and shall be able to:
- 1. Support various reporting intervals and due-dates per location.
 - 2. Support one-time requirements as well as recurring requirements.
- vi) User shall be able to add, change or delete constituents.
- vii) Software shall support temporary or one-time limits and requirements due to enforcement actions.
- viii) Software shall track historical information, e.g., logging changes and authentication.
- ix) Changes to limits and/or requirements shall be able to be reflected in new versions of permit documents and will present existing limits and future new limits and/or requirements.
- x) Software shall generate tasks and notifications for staff based on permitting criteria.
- e) Samples and Results
- i) The software shall have data trending capabilities based on Groups of Industries, Groups of Samples and Groups of Results. All data shall be exportable to the latest version of MS Excel and displayed in reports, which can be exported to the latest version of MS Word.

- ii) Collection method, sample flow, sample start and stop dates shall be stored on a result level as to give user the flexibility to accurately identify the sampling activity on a parameter level.
 - iii) Software shall include Lab Data Entry capabilities which facilitate and increase the efficiency of the Laboratory Data entry process. The data import file format will be provided by the software.
 - iv) The software shall be able to compare single results to permit limits then notify user of a violation if the result is over the daily limit. The software shall allow the user to create a violation when a result is over the limit.
 - v) The software shall be able to compare required hold times against actual sample hold times.
 - vi) The software shall be able to generate a configurable COC and sample bottle labels.
 - vii) Software shall be able to import laboratory sample and result data from LIMS and Excel.
 - viii) LIMS import process shall be flexible enough to address naming convention changes of parameters, collection methods and industry names.
 - ix) Software shall be able to handle flow information entered separate from sample information. User shall be able to enter measured as well as adjusted flow values.
- f) Compliance Calculations: The software shall have, as a minimum, the following capabilities:
- i) Perform TRC and Chronic Significant Non-Compliance calculations and generate Significant Non-Compliance (SNC) Reports that comply with 40 CFR 403.
 - ii) Allow the user to select whether to combine or keep separate outfall calculations. User must be able to calculate flow proportioned concentrations to check compliance for more than one outfall. For example, one compliance point is flow proportioned concentration from two outfalls; the software shall have the capability to calculate this flow proportioned concentration to check for compliance.
 - iii) Allow the user to select all or individual parameters for compliance calculations. For example, if a single lab analysis tests for 45 constituents but only eight are needed for compliance calculations, the User shall be able to select and sum only the eight needed for the compliance calculation.
 - iv) Calculate monthly and 4-day averages and compare them against limits.
 - v) Calculate NC and SNC for scheduled events.
 - vi) Automatically generate violations when calculating SNC Technical Review Criteria (TRC), SNC Chronic and monthly averages.
- g) Grouping and Filtering:
- i) The software shall be able to filter industries, samples, results, events and violations into groups to keep them organized. These groups will

- be customized and stored by the end user and presented in a manner, which facilitates reporting.
- ii) The software shall be able to distinguish and filter by Control Authority and Self-monitoring data.
 - iii) Groups of industries shall be savable and usable when viewing and creating events, violations, compliance reports, monthly reports, quarterly reports, semi-annual reports and annual reports, all with different formats.
 - iv) The software shall be able to group industries by fields such as trunk line, industry classification, receiving plant, street and expiration date.
 - v) Users shall be able to view all results, events and violations based on facilities discharging to a particular trunk line or map category.
 - vi) The software shall be able to schedule and track sampling events, inspections, reporting requirements, and Industrial Pretreatment Program (IPP) enforcement actions.
 - vii) The software shall be able to automatically generate events based on frequencies set on an industry level as well as an event level, thus allowing a user to create a schedule of events for an entire year all at once.
 - viii) Software shall notify users when events are due.
 - ix) The software shall have the ability to set a date range for information retrieval.
- h) Automatic Task Scheduling: The software shall be capable of automatically scheduling the following activities:
- i) Internal electronic notifications
 1. Use a calendar function, with user-defined rules, to check for tasks due, reports due, and violations that have occurred and report back to the user.
 2. Regular tasks shall be scheduled automatically.
 3. When automatically scheduling recurrent tasks, if the due date is a weekend or holiday, the due date shall be automatically moved to the next business day.
 - ii) External reminders
 1. On predefined dates, the system shall automatically generate reminder notifications such as self-monitoring notifications, special conditions, contingency plans, no discharge, flow meter calibration, application reminders to send, due dates, among others.
 2. Validate that notifications are created.
 - a. Store electronic notifications on file server or database application.
 - b. Ability to run report showing what notifications have been created.
 - c. Ability to create paper output of reminder notifications.
 3. User shall be able to manually enter special condition requirements with due dates and multiple due dates, including:

- a. Schedule follow-up inspections, samples, or submittals to verify task completion.
- b. Ability to extend due dates for task completion.
- c. Track all conditions, due dates and extensions.

i) Violations:

- i) The software shall be able to generate NOV letters and other enforcement documents, including, but not limited to, warning letters, Administration Orders, and late notices, that may be customized by the end user without an additional reporting software package.
- ii) The software shall be able to store unlimited, customizable and savable templates for NOV letters and other enforcement documents.
- iii) A single NOV letter shall be able to enforce multiple violation actions even if the violations occurred on different days.
- iv) The software shall track industry violations, IPP enforcement actions and all subsequent compliance actions. These activities shall be displayed in a single location providing the user with a single view to monitor and modify the violation escalation process.
- v) Software shall give users the ability to instantly see a list of violations, which have not yet been enforced.
- vi) Software shall provide ability to enter other enforcement actions manually.
- vii) Software shall provide ability to enter reason for escalation or leniency for each violation.
- viii) Software shall have ability to close out violations, enter due dates, pre-enter timeliness information, add time extensions, as well as enter violation determination date and who determined.

j) Reporting:

- i) Reports shall be customizable by the end user, and allow new reports to be created from existing reports. These reports shall then be stored as templates and used throughout the software. Customizing reports shall not require services by the vendor.
- ii) The software shall be capable of exporting data to Microsoft Excel as a minimum.
- iii) The software shall be able to generate reports in Microsoft Word and Excel, as a minimum.
- iv) Sample types, inspection types, violation types and enforcement types shall be able to be selectable within the monthly, quarterly, semi-annual and annual report generation process. Selected items shall be counted and displayed on each report type.
- v) Software shall give the user the ability to select which contact type to send a letter to enabling the user to easily generate letters specific to the contacts for a given industry.
- vi) Software shall have the ability to merge current data with existing Microsoft Word documents.

- k) LIMS and Self-Monitoring Interfaces. The software shall be able to do the following, as a minimum:
- i) Accept approved sampling data from SAWPA's and other LIMS application. Sampling data shall be received in standardized format from all recipients.
 - 1. Validate facility, sampling point, and pollutant data.
 - 2. Respect data system primacy (LIMS or pretreatment software).
 - 3. Allow multiple test methods to be mapped to one pollutant.
 - ii) Provide a method/interface to enter self-monitoring results into the system by SAWPA staff.
 - 1. Ability to pre-scheduled single day and multi-day self-monitoring.
 - 2. Ability to process voluntary self-monitoring that is received on an ad hoc basis.
 - 3. Ability upload supporting documentation by in-house staff.
 - 4. Ability to upload other types of permittee submissions, including, but not limited to, flow data, meter calibration, self-monitoring reports).
 - iii) Provide the ability to enter self-monitoring sampling data via a secure configurable internet interface for SAWPA's agents.
 - iv) Provide validation functions for all LIMS data entered manually.
 - 1. Validate all lab, facility, sampling point, and pollutant data against database to ensure that the results are rational and units are appropriate, and approved EPA test method.
 - 2. Populate each sampling location's pollutant list from appropriate reporting requirements in application. Allow addition and deletion of pollutants from that list. User shall have ability to control permission for users who can add and delete pollutants.
 - 3. Populate results which are below detection limits from specified defaults.
 - 4. Require Chain-of-Custody and authorization forms to be included with submittal ("yes/no" field).
 - 5. Ability to mark a sample as submitted but incomplete and to code the sample using one or more choices of explanations pertaining to why it is incomplete.
 - 6. Interface should not allow agency provided lab data to be modified.
 - v) Wastewater Analysis Report (WWAR) and Resample Requirement
 - 1. Ability to generate a cover letter which will conditionally present the 30 day resample requirement if there was a violation in the analysis report.

2. Provide the ability to generate a WWAR following a monitoring event
3. WWAR to report non-compliance of a discharge requirement.
 - a. If non-compliant, how intense is the violation.
 - b. Ability to generate resample records in LIMS and self-monitoring system.

l) Security:

- i) Proposal shall include description of security settings employed including, but not limited to encryption, data integrity, etc.
- ii) Software shall authorize system users with at least two fields (username and password) or use Microsoft Windows Active Directory, and keep a log of all access attempts and successes.
- iii) Software shall provide role-based security and restrict access to application features using the roles. Allow only authorized user roles to perform certain tasks (view, update, insert, delete) and certain functions (permitting, enforcement, maintenance of application dictionaries) based on user role relative to the applications' functional segment, user interface, and/or data field within the functional segment/user interface. User interfaces include desktop computing, mobile computing, outward facing internet content, and printed output.
- iv) Software shall have permission settings, adjustable by authorized users, to limit specific users' abilities to enter, edit and/or view data, to restrict one agency's ability to alter the data of another agency.
- v) Software shall administration of user roles shall be based on a service account that is not permitted to edit any data.
- vi) Software shall provide secure screens for maintenance of application dictionaries to authorized Application Administration roles only.
- vii) Software shall provide functionality to assign a single user to more than one role.
- viii) Software shall provide data logging of permit information and query tables.
- ix) Software shall provide mechanisms to update sampling event attributes from this system when the proper role is used. Corrections to sampling analysis results are only made within the Laboratory application and re-transferred to the pretreatment software to maintain integrity between the two systems.

m) General:

- i) Proposal shall include description of security settings employed including, but not limited to encryption, data integrity, etc. The Vendor shall be responsible for the proper installation of all software components. Installation of software components and interconnections between software components and other SAWPA software/hardware shall be in accordance with and under the guidance of the SAWPA IT Department.

- n) Installation and Configuration
 - i) Vendor shall install, configure, and implement, fully functional development, testing, training and production environments as part of this project, including all tasks required to support full integration into the SAWPA environment, as required by and in accordance with SAWPA staff direction. The integration may require additional software and/or hardware for full installation and integration and the Vendor shall supply necessary software/hardware in accordance with SAWPA staff coordination and approval. Vendor shall provide all necessary resources to successfully complete all tasks.

- o) Testing
 - i) A comprehensive formal testing process and test environment shall be developed by the Vendor and approved by SAWPA. Vendor shall develop a test plan for each component/module or system function establishing roles/responsibilities of team members for each test plan. Vendor shall develop and load test data into a test system and facilitate the completion of each test plan, coordinating efforts with the SAWPA Project Manager and the SAWPA Technical Lead. All testing procedures shall be produced by Vendor and approved by SAWPA no less than two weeks before testing begins.
 - ii) Prior to moving the system into a production environment, Vendor shall remedy all known defects and install and test the most current available fix pack(s) and remedy all problems and deficiencies that may surface during that process. All tests will be performed on-site at SAWPA on standard computers and servers with SAWPA standard software and hardware.
 - iii) Tests will not be considered complete until the SAWPA Project Manager and assigned personnel are satisfied that the software and data performed properly and are compliant with SAWPA standards. All training will be completed prior to go-live.
 - iv) Upon successful completion of testing and written certification by the Vendor that the system is complete in all respects, and all known defects have been remedied by the Vendor, the system shall be prepared for live operations. Vendor shall provide on-site support during go-live for not less than five (5) consecutive days. If defects surface during that period, SAWPA reserves the right to require Vendor to remain on site until the system is stable and material defects have been remedied.

- p) Training
 - i) Training shall occur no later than three weeks prior to go-live operations. Vendor shall identify SAWPA staff member or Contributing Agency training based on role, responsibility, or project involvement. Training shall be tailored for inside vs. outside facing tools. Vendor shall also develop customized end user training and reference materials for SAWPA staff providing information and examples of SAWPA usage of the accepted solution.

q) Documentation

- i) All project-related documentation shall be updated and provided to SAWPA prior to training. Project documentation shall include, but not be limited to, hardware configuration, software configuration, security administration, training manuals, collected data, installation procedures, and testing procedures.
- ii) All documentation shall be delivered in the form of electronic files. The final documentation deliverable shall consist of a complete set of electronic user manuals and electronic system administration manuals. The manuals shall include, but not be limited to, the content of the knowledge transfer sessions, including a table of contents.
- iii) Contents shall include, but not be limited to:
 1. System/Application configuration.
 2. System/Application disaster recovery procedure.
 3. System/Application installation process.
 4. System/Application administration procedures.
 5. System/Application security administration procedures.
 6. System/Application workflow documentation.
 7. System/Application test plans and test plan results.
 8. All other documentation generated by other project tasks (i.e. status reports, logs, training materials).

5) Proposal Requirements

Responses to this RFP must be made according to the requirements set forth in this section for content and sequence. Firms must demonstrate their capabilities, background, and expertise, for SAWPA to effectively evaluate the submittals, and select the firm(s) that provide the best value to SAWPA based on the selection criteria. Failure to adhere to these requirements or the inclusion of conditions, limitations, or misrepresentations may be cause for rejection of the proposal. Any correction and resubmission by the proposer will not extend the time for evaluation of the proposal.

Responses to this RFP shall be prepared as concisely as possible. The proposal should be formatted for legibility by the reviewers, and **no more than ten (10) pages long** (not including cover letter, exhibits and resumes), and **not more than 10 megabytes in size**.

All proposals must include at a minimum the following information:

- **Cover letter**, including **Proposer's Signature Block**, as outlined in [Exhibit A](#).
- **Proposal Table of Contents**.
- **Understanding of the Project** – The Proposer shall provide a brief description of its approach and understanding of the important Project elements, as well as technical considerations of the Project.
- The Proposer shall provide the following:
 - **Scope of Work** describing work tasks proposed to implement the Project. Identify any materials and/or equipment to be used to implement the Project.
 - **Cost proposal** in tabular format, as outlined in [Exhibit B](#), indicating tasks, task hours by labor category, hourly billing rates for each labor category, costs for sub-consultants, and reimbursable expenses. The rates shall be valid for the term of the contract. Note SAWPA will not pay for travel time. In

addition to the summary cost proposal shown in Exhibit B, proposers must provide a detailed cost estimate of the project scope of work.

- **Schedule** for implementing the Project. The schedule shall show each scope of work task and its activity duration.
- **Project Team & Qualifications** – The Proposer shall provide an organization chart showing proposed management and project team including a complete list of personnel, including subcontractors that will be dedicated to this project. The Proposer may include resumes of key team members. The Proposer may be required to furnish statements of their financial resources.
- **Experience** – The Proposer shall provide a description of similar projects, services and/or relevant work experience undertaken by the proposer. Projects must be within the last five (5) years, and preferably involve the staff identified in the list of personnel.
- **References** – The Proposer shall provide references from a minimum of three (3) former clients, as outlined in **Exhibit C**, for whom comparable services have been performed within the last five years.
- Consultant and Sub-consultant Business Information, as outlined in **Exhibit D**.
- Additions, Deletions and/or Exceptions, as outlined in **Exhibit E**, compliance with SAWPA's contractual terms and/or RFP requirements. The firm shall note any additions, deletions and/or exceptions to the contractual terms and/or RFP requirements. If there are no exceptions taken, note in writing that there are none. An Agreement for Services template is attached to this RFP (**Attachment A**) that the consultant/firm will be required to sign; the respondent must identify any exceptions to that draft agreement as an element of the proposal submitted for review and consideration.

6) Submittals

Submit only an electronic copy (via email, Dropbox, etc.) of the proposal and related information as a single .pdf file to Planet Bids at:

<https://pbsystem.planetbids.com/portal/52676/portal-home>

Proposals must be received by **3:00 p.m. PST on Thursday, March 13, 2025**. Proposals received after the stated time will be deleted and not considered. SAWPA is not responsible for any failure to receive files transmitted electronically or which fail to open properly upon receipt.

7) Proposed Schedule

The following table identifies the estimated dates for receipt, evaluation, and award of this RFP. Please note the following key dates when preparing your response to this RFP.

| | |
|------------------|---|
| February 5, 2025 | Issue Request for Proposals |
| March 13, 2025 | Proposals due (3:00 p.m.) |
| April 2025 | Contract Award |
| July 1, 2025 | Deliver completed information management system application to SAWPA including all project specific tailoring |
| July 31, 2025 | Provide documentation and complete training |
| August 1, 2025 | Support trial use of software |
| October 1, 2025 | Implement use of software |

8) Selection Criteria

The criteria for selection shall be based on, but not limited to, the following:

- Responsiveness to the RFP.
- Project approach and understanding of project needs.
- Qualifications and experience of the firm(s) in performing similar projects.
- Cost Proposal (**Exhibit B**) and detailed cost breakdown.
- References (**Exhibit C**).
- Exceptions Taken to RFP (**Exhibit E**).
- Anticipated value and quality of services received.

If additional information is needed, submit questions clarifications, or comments through Planet Bids': <https://pbsystem.planetbids.com/portal/xxx/portal-home> Responses will be provided through Planet Bids'.

SAWPA reserves the sole right to evaluate and select the successful proposal(s) and may choose to award a contract to one or more qualified consultants.

9) General Requirements

1. All proposers are hereby advised that this RFP is an informal solicitation and is not a commitment or offer to enter into an agreement or engage into any competitive bidding or negotiation pursuant to any statute, ordinance, rule, or regulation. SAWPA reserves the right to negotiate with any qualified source. SAWPA reserves the right to reject any or all proposals for any reason or for no reason at all.
2. SAWPA reserves the right to request further information from the proposer either in writing or orally. Such request will be addressed to that person or persons authorized by the proposer to represent the proposer.
3. SAWPA reserves the sole right to judge the proposers' representations, either written or oral.
4. Proposers understand and agree that submission of a proposal constitutes acknowledgement and acceptance of, and a willingness to comply with, the terms, conditions, and criteria contained in this RFP.
5. False, incomplete, or unresponsive statements in connection with a proposal may be sufficient cause for the rejection of the proposal. The valuation and determination of the fulfillment of the above requirement will be SAWPA's responsibility and its decision shall be final.
6. SAWPA reserves the right to interpret or change any provisions of this RFP at any time prior to the proposal submission date. Such interpretations or changes will be in the form of addenda to this RFP. Such an addenda will become part of this RFP and may become part of any resultant contract. Such addenda will be made available to each person or organization that has received an RFP to the extent known. Should such addenda require additional information not previously requested, a proposer's failure to address the requirements of such addenda might result in the proposal not being considered.
7. All proposals submitted in response to this RFP will become the exclusive property of SAWPA. At such time as SAWPA's recommendation to the SAWPA Board relative to proposal selection appears on the Board Agenda, all such proposals become a matter of public record, and shall be regarded as public records, with the exception of those parts of each proposal which are defined by the proposer as business or trade secrets, and so marked, as "confidential" or "proprietary." SAWPA shall not in

any way be liable or responsible for the disclosure of any such proposals or any part thereof if disclosure of any such proposals or any part thereof if disclosure is required under the Public Records Act.

8. SAWPA shall not in any way be liable for any costs incurred in connection with the preparation of any proposal submitted in response to this RFP.

EXHIBIT A
PROPOSER'S SIGNATURE BLOCK

| | | | |
|-----------------------|--|------------------|--|
| Name of Firm: | | Title: | |
| Authorized Signature: | | Date: | |
| Printed/Typed Name: | | Mailing Address: | |
| Phone: | | City, State, Zip | |
| Fax: | | E-Mail Address: | |

Your signature on this document, should you be awarded a contract as defined in this RFP, signifies that you have fully read and understood this proposal and will comply with all specifications, conditions, unit prices, terms, and delivery of the proposal unless otherwise noted in the "exceptions" portion of the proposal.

EXHIBIT B
COST PROPOSAL

| Task | Description | Cost |
|---------------|--|-------------|
| 1 | Provide software in accordance with the scope of work | |
| 2 | Provide testing using a comprehensive formal testing process | |
| 3 | Provide user documentation and agency training | |
| 4 | Provide technical support during trial use period | |
| 5 | Final System Acceptance – 10% of the sum of items 1 through 4 will be withheld until the system is accepted in accordance with the scope of work | |
| 6 | Software updates and ongoing technical support from implementation of software to June 30, 2026 | |
| 7 | Software updates and ongoing technical support July 1, 2026, to June 30, 2027 (Optional) | |
| 8 | Software updates and ongoing technical support July 1, 2027, to June 30, 2028 (Optional) | |
| 9 | Software updates and ongoing technical support July 1, 2028, to June 30, 2029 (Optional) | |
| 10 | Software updates and ongoing technical support July 1, 2029, to June 30, 2030 (Optional) | |
| 11 | Software updates and ongoing technical support July 1, 2030, to June 30, 2031 (Optional) | |
| Total: | | |

The Project shall begin immediately upon receipt of order or notice to proceed.

For each Task include costs for **all** labor, equipment, materials, transportation, overhead, travel, profit, insurance, sales and other taxes, licenses, incidentals, and all other related costs necessary to meet the work requirements. Note SAWPA will not pay for travel time. In addition to the summary cost proposal shown in Exhibit B, proposers must provide a detailed cost estimate for the project scope of work.

EXHIBIT C

REFERENCES

Proposer shall provide a **minimum of three (3)** Customer References for whom comparable services have been performed within the last five (5) years. Local and similar size contract references are preferred.

REFERENCE #1

| | |
|--------------------------|--------|
| NAME OF AGENCY | |
| ADDRESS | |
| CITY, STATE, ZIP CODE | |
| TELEPHONE # | () |
| E-MAIL ADDRESS | |
| CONTACT | |
| PROJECT NAME | |
| COMPLETION DATE | |
| APPROX. COST | |

REFERENCE #2

| | |
|--------------------------|--------|
| NAME OF AGENCY | |
| ADDRESS | |
| CITY, STATE, ZIP CODE | |
| TELEPHONE # | () |
| E-MAIL ADDRESS | |
| CONTACT | |
| PROJECT NAME | |
| COMPLETION DATE | |
| APPROX. COST | |

REFERENCE #3

| | |
|--------------------------|--------|
| NAME OF AGENCY | |
| ADDRESS | |
| CITY, STATE, ZIP CODE | |
| TELEPHONE # | () |
| E-MAIL ADDRESS | |
| CONTACT | |
| PROJECT NAME | |
| COMPLETION DATE | |
| APPROX. COST | |

EXHIBIT D

**PROPOSER'S BUSINESS
INFORMATION**

All proposers shall submit the information as requested below.

1. Length of time your firm has been in business:

2. Length of time at current location:

.

3. List types and business license number(s):

.

4. California State Contractor's License number: _____

5. Names and titles of all officers of the firm:

.

6. Is your firm a sole proprietorship doing business under a different name? YES or NO

7. If yes, please indicate sole proprietorship name and the name you are doing business under: _____

8. Please indicate your Federal Tax Number:

9. Is your firm incorporated? YES or NO

10. Name and remittance address that will appear on invoices:

11. Physical Address: _____

EXHIBIT E

ADDITIONS, DELETIONS AND/OR EXCEPTIONS

Please state any and all Additions, Deletions and Exceptions that you are taking to any portion of this proposal and General Services Agreement (GSA) and Task Order (Attachment A). If not addressed below, then Santa Ana Watershed Project Authority assumes that the vendor will adhere to all terms and conditions listed.

SAWPA will issue an Agreement in its standard form to the successful firm(s) for the services contemplated herein; a copy of which is attached hereto and incorporated herein. Any deletion, exception, or modification taken to Agency contract terms and conditions will be evaluated, in addition to the specified criteria; and may, itself, result in non-acceptance by the Agency. Any request for deletion, exception, or modification, if so taken, must be submitted at the time of proposal.

Attachment A

Agreement for Services template



*SANTA ANA WATERSHED PROJECT AUTHORITY
GENERAL SERVICES AGREEMENT FOR SERVICES BY INDEPENDENT
CONSULTANT*

This Agreement is made this ____ day of _____, **20**__ by and between the Santa Ana Watershed Project Authority ("SAWPA") located at 11615 Sterling Ave., Riverside, California, 92503 and _____ ("Consultant") whose address is _____.

RECITALS

This Agreement is entered into on the basis of the following facts, understandings, and intentions of the parties to this Agreement:

- SAWPA desires to engage the professional services of Consultant to perform such professional consulting services as may be assigned, from time to time, by SAWPA in writing;
- Consultant agrees to provide such services pursuant to, and in accordance with, the terms and conditions of this Agreement and has represented and warrants to SAWPA that Consultant possesses the necessary skills, qualifications, personnel, and equipment to provide such services; and
- The services to be performed by Consultant shall be specifically described in one or more written Task Orders issued by SAWPA to Consultant pursuant to this Agreement.

AGREEMENT

Now, therefore, in consideration of the foregoing Recitals and mutual covenants contained herein, SAWPA and Consultant agree to the following:

ARTICLE I

TERM OF AGREEMENT

1.01 This agreement shall become effective on the date first above written and shall continue until **December 31, 20**__, unless extended or sooner terminated as provided for herein.

ARTICLE II

SERVICES TO BE PERFORMED

2.01 Consultant agrees to provide such professional consulting services as may be assigned, from time to time, in writing by the Commission and the General Manager of SAWPA. Each assignment shall be made in the form of a written Task Order. Each such

Task Order shall include, but shall not be limited to, a description of the nature and scope of the services to be performed by Consultant, the amount of compensation to be paid, and the expected time of completion.

2.02 Consultant may at Consultant's sole cost and expense, employ such competent and qualified independent professional associates, subcontractors, and consultants as Consultant deems necessary to perform each assignment; provided that Consultant shall not subcontract any work to be performed without the prior written consent of SAWPA.

ARTICLE III

COMPENSATION

3.01 In consideration for the services to be performed by Consultant, SAWPA agrees to pay Consultant as provided for in each Task Order.

3.02 Each Task Order shall specify a total not-to-exceed sum of money and shall be based upon the regular hourly rates customarily charged by Consultant to its clients.

3.03 Consultant shall not be compensated for any services rendered nor reimbursed for any expenses incurred in excess of those authorized in any Task Order unless approved in advance by the Commission and General Manager of SAWPA, in writing.

3.04 Unless otherwise provided for in any Task Order issued pursuant to this Agreement, payment of compensation earned shall be made in monthly installments after receipt from Consultant of a timely, detailed, corrected, written invoice by SAWPA's Project Manager, describing, without limitation, the services performed, when such services were performed, the time spent performing such services, the hourly rate charged therefore, and the identity of individuals performing such services for the benefit of SAWPA. Such invoices shall also include a detailed itemization of expenses incurred. Upon approval by an authorized SAWPA employee, SAWPA will pay within 30 days after receipt of a valid invoice from Consultant.

ARTICLE IV

CONSULTANT OBLIGATIONS

4.01 Consultant agrees to perform all assigned services in accordance with the terms and conditions of this Agreement including those specified in each Task Order. In performing the services required by this Agreement and any related Task Order Consultant shall comply with all local, state, and federal laws, rules, and regulations. Consultant shall also obtain and pay for any permits required for the services it performs under this Agreement and any related Task Order.

4.02 Except as otherwise provided for in each Task Order, Consultant will supply all personnel and equipment required to perform the assigned services.

4.03 Consultant shall be solely responsible for the health and safety of its employees, agents, and subcontractors in performing the services assigned by SAWPA.

4.04 Insurance Coverage: Consultant shall procure and maintain for the duration of this Agreement insurance against claims for injuries or death to persons or damages to property which may arise from or in connection with the performance of the work hereunder and the results of that work by the Consultant, its agents, representatives, employees, or sub-contractors.

4.04(a) Coverage - Coverage shall be at least as broad as the following:

1. **Commercial General Liability (CGL)** - Insurance Services Office (ISO) Commercial General Liability Coverage (Occurrence Form CG 00 01) including products and completed operations, property damage, bodily injury, personal and advertising injury with limit of at least two million dollars (\$2,000,000) per occurrence or the full per occurrence limits of the policies available, whichever is greater. If a general aggregate limit applies, either the general aggregate limit shall apply separately to this project/location (coverage as broad as the ISO CG 25 03, or ISO CG 25 04 endorsement provided to SAWPA) or the general aggregate limit shall be twice the required occurrence limit.
2. **Automobile Liability** – (if necessary) Insurance Services Office (ISO) Business Auto Coverage (Form CA 00 01), covering Symbol 1 (any auto) or if Consultant has no owned autos, Symbol 8 (hired) and 9 (non-owned) with limit of one million dollars (\$1,000,000) for bodily injury and property damage each accident.
3. **Workers' Compensation Insurance** - as required by the State of California, with Statutory Limits, and Employer's Liability Insurance with limit of no less than \$1,000,000 per accident for bodily injury or disease.
4. **Professional Liability** - (Also known as Errors & Omission) Insurance appropriate to the Consultant profession, with limits no less than \$1,000,000 per occurrence or claim, and \$2,000,000 policy aggregate.
5. **Cyber Liability Insurance (Technology Professional Liability – Errors and Omissions)** – If Consultant will be providing technology services, limits not less than \$2,000,000 per occurrence or claim, and \$2,000,000 aggregate or the full per occurrence limits of the policies available, whichever is greater. Coverage shall be sufficiently broad to respond to the duties and obligations as is undertaken by Consultant in this Agreement and shall include, but not be limited to, claims involving infringement of intellectual property, including but not limited to infringement of copyright, trademark, trade dress, invasion of privacy violations, information theft, damage to or destruction of electronic information, release of private information, alteration of electronic information, extortion and network security. The policy shall provide coverage for breach response costs as well as regulatory fines and penalties as well as credit monitoring expenses with limits sufficient to respond to these obligations.

If the Consultant maintains broader coverage and/or higher limits than the minimums shown above, SAWPA requires and shall be entitled to the broader coverage and/or higher limits maintained by the Consultant. Any available insurance proceeds in excess of the specified minimum limits of insurance and coverage shall be available to SAWPA.

4.04(b) If Claims Made Policies:

1. The Retroactive Date must be shown and must be before the date of the contract or the beginning of contract work.
2. Insurance must be maintained and evidence of insurance must be provided **for at least five (5) years after completion of the contract of work.**
3. If coverage is canceled or non-renewed, and not **replaced with another claims-made policy form with a Retroactive Date** prior to the contract effective date, the Consultant must purchase “extended reporting” coverage for a minimum of **five (5)** years after completion of contract work.

4.04(c) Waiver of Subrogation: The insurer(s) named above agree to waive all rights of subrogation against SAWPA, its elected or appointed officers, officials, agents, authorized volunteers and employees for losses paid under the terms of this policy which arise from work performed by the Named Insured for the Agency; but this provision applies regardless of whether or not SAWPA has received a waiver of subrogation from the insurer.

4.04(d) Other Required Provisions - The general liability policy must contain, or be endorsed to contain, the following provisions:

1. **Additional Insured Status:** SAWPA, its directors, officers, employees, and authorized volunteers are to be given insured status (at least as broad as ISO Form CG 20 10 10 01), with respect to liability arising out of work or operations performed by or on behalf of the Consultant including materials, parts, or equipment furnished in connection with such work or operations.
2. **Primary Coverage:** For any claims related to this project, the Consultant’s insurance coverage shall be primary at least as broad as ISO CG 20 01 04 13 as respects to SAWPA, its directors, officers, employees, and authorized volunteers. Any insurance or self-insurance maintained by the Member Water Agency its directors, officers, employees and authorized volunteers shall be excess of the Consultant’s insurance and shall not contribute with it.

4.04(e) Notice of Cancellation: Each insurance policy required above shall provide that coverage shall not be canceled, except with notice to SAWPA.

4.04(f) Self-Insured Retentions - Self-insured retentions must be declared to and approved by SAWPA. SAWPA may require the Consultant to provide proof of ability to pay losses and related investigations, claim administration, and defense expenses within the retention. The policy language shall provide, or be endorsed to provide, that the self-insured retention may be satisfied by either the named insured or SAWPA.

4.04(g) Acceptability of Insurers - Insurance is to be placed with insurers having a current A.M. Best rating of no less than A: VII or as otherwise approved by SAWPA.

4.04(h) Verification of Coverage – Consultant shall furnish SAWPA with certificates and amendatory endorsements or copies of the applicable policy language effecting coverage required by this clause. All certificates and endorsements are to be received and approved by SAWPA before work commences. However, failure to obtain the required documents prior to the work beginning shall not waive the Consultant’s obligation to provide them.

SAWPA reserves the right to require complete, certified copies of all required insurance policies, including policy Declaration pages and Endorsement pages.

4.04(i) Subcontractors - Consultant shall require and verify that all subcontractors maintain insurance meeting all the requirements stated herein, and Consultant shall ensure that SAWPA, its directors, officers, employees, and authorized volunteers are additional insureds on Commercial General Liability Coverage.

4.05 Consultant hereby covenants and agrees that SAWPA, its officers, employees, and agents shall not be liable for any claims, liabilities, penalties, fines or any damage to property, whether real or personal, nor for any personal injury or death caused by, or resulting from, or claimed to have been caused by or resulting from, any negligence, recklessness, or willful misconduct of Consultant. To the extent permitted by law, Consultant shall hold harmless, defend at its own expense, and indemnify SAWPA, its directors, officers, employees, and authorized volunteers, against any and all liability, claims, losses, damages, or expenses, including reasonable attorney's fees and costs, arising from all acts or omissions of Consultant or its officers, agents, or employees in rendering services under this Agreement and any Task Order issued hereunder; excluding, however, such liability, claims, losses, damages or expenses arising from SAWPA's sole negligence or willful acts.

4.06 In the event that SAWPA requests that specific employees or agents of Consultant supervise or otherwise perform the services specified in each Task Order, Consultant shall ensure that such individual(s) shall be appointed and assigned the responsibility of performing the services.

4.07 In the event Consultant is required to prepare plans, drawings, specifications and/or estimates, the same shall be furnished with a registered professional engineer's number and shall conform to local, state, and federal laws, rules, and regulations. Consultant shall obtain all necessary permits and approvals in connection with this Agreement, any Task Order or Change Order. However, in the event SAWPA is required to obtain such an approval or permit from another governmental entity, Consultant shall provide all necessary supporting documents to be filed with such entity, and shall facilitate the acquisition of such approval or permit.

4.08 Consultant shall comply with all local, state, and federal laws, rules and regulations including those regarding nondiscrimination and the payment of prevailing wages, if required by law.

ARTICLE V

SAWPA OBLIGATIONS

5.01 SAWPA shall:

5.01a Furnish all existing studies, reports, and other available data pertinent to each Task Order that are in SAWPA's possession;

5.01b Designate a person to act as liaison between Consultant and the General Manager and Commission of SAWPA.

ARTICLE VI

ADDITIONAL SERVICES, CHANGES AND DELETIONS

6.01 During the term of this Agreement, the Commission of SAWPA may, from time to time and without affecting the validity of this Agreement or any Task Order issued pursuant thereto, order changes, deletions, and additional services by the issuance of written Change Orders authorized and approved by the Commission of SAWPA.

6.02 In the event Consultant performs additional or different services than those described in any Task Order or authorized Change Order without the prior written approval of the Commission of SAWPA, Consultant shall not be compensated for such services.

6.03 Consultant shall promptly advise SAWPA as soon as reasonably practicable upon gaining knowledge of a condition, event, or accumulation of events, which may affect the scope and/or cost of services to be provided pursuant to this Agreement. All proposed changes, modifications, deletions, and/or requests for additional services shall be reduced to writing for review and approval or rejection by the Commission of SAWPA.

6.04 In the event that SAWPA orders services deleted or reduced, compensation shall be deleted or reduced by a comparable amount as determined by SAWPA and Consultant shall only be compensated for services actually performed. In the event additional services are properly authorized, payment for the same shall be made as provided in Article III above.

ARTICLE VII

CONSTRUCTION PROJECTS: CONSULTANT CHANGE ORDERS

7.01 In the event SAWPA authorizes Consultant to perform construction management services for SAWPA, Consultant may determine, in the course of providing such services, that a Change Order should be issued to the construction contractor, or Consultant may receive a request for a Change Order from the construction contractor. Consultant shall, upon receipt of any requested Change Order or upon gaining knowledge of any condition, event, or accumulation of events, which may necessitate issuing a Change Order to the construction contractor, promptly consult with the liaison, General Manager and Commission of SAWPA. No Change Order shall be issued or executed without the prior approval of the Commission of SAWPA.

ARTICLE VIII

TERMINATION OF AGREEMENT

8.01 In the event the time specified for completion of an assigned task in a Task Order exceeds the term of this Agreement, the term of this Agreement shall be automatically extended for such additional time as is necessary to complete such Task Order and thereupon this Agreement shall automatically terminate without further notice.

8.02 Notwithstanding any other provision of this Agreement, SAWPA, at its sole option, may terminate this Agreement at any time by giving 10 day written notice to Consultant, whether or not a Task Order has been issued to Consultant.

8.03 In the event of termination, the payment of monies due Consultant for work performed prior to the effective date of such termination shall be paid after receipt of an invoice as provided in this Agreement.

ARTICLE IX

CONSULTANT STATUS

9.01 Consultant shall perform the services assigned by SAWPA in Consultant's own way as an independent contractor, in pursuit of Consultant's independent calling and not as an employee of SAWPA. Consultant shall be under the control of SAWPA only as to the result to be accomplished and the personnel assigned to perform services. However, Consultant shall regularly confer with SAWPA's liaison, General Manager, and Commission as provided for in this Agreement.

9.02 Consultant hereby specifically represents and warrants to SAWPA that the services to be rendered pursuant to this Agreement shall be performed in accordance with the standards customarily applicable to an experienced and competent professional consulting organization rendering the same or similar services. Furthermore, Consultant represents and warrants that the individual signing this Agreement on behalf of Consultant has the full authority to bind Consultant to this Agreement.

ARTICLE X

AUDIT AND OWNERSHIP OF DOCUMENTS

10.01 All draft and final reports, plans, drawings, specifications, data, notes, and all other documents of any kind or nature prepared or developed by Consultant in connection with the performance of services assigned to it by SAWPA are the sole property of SAWPA, and Consultant shall promptly deliver all such materials to SAWPA. Consultant may retain copies of the original documents, at its option and expense. Use of such documents by SAWPA for project(s) not the subject of this Agreement shall be at SAWPA's sole risk without legal liability or exposure to Consultant. SAWPA agrees to not release any software "code" without prior written approval from the Consultant.

10.02 Consultant shall retain and maintain, for a period not less than four years following termination of this Agreement, all time records, accounting records, and vouchers and all other records with respect to all matters concerning services performed, compensation paid and expenses reimbursed. At any time during normal business hours and as often as SAWPA may deem necessary, Consultant shall make available to SAWPA's agents for examination of all such records and will permit SAWPA's agents to audit, examine and reproduce such records.

ARTICLE XI

MISCELLANEOUS PROVISIONS

11.01 This Agreement supersedes any and all previous agreements, either oral or written, between the parties hereto with respect to the rendering of services by Consultant for SAWPA and contains all of the covenants and agreements between the parties with respect to the rendering of such services in any manner whatsoever. Any modification of this Agreement will be effective only if it is in writing signed by both parties.

11.02 Consultant shall not assign or otherwise transfer any rights or interest in this Agreement without the prior written consent of SAWPA. Unless specifically stated to the contrary in any written consent to an assignment, no assignment will release or discharge the assignor from any duty or responsibility under this Agreement.

11.03 In the event Consultant is an individual person and dies prior to completion of this Agreement or any Task Order issued hereunder, any monies earned that may be due Consultant from SAWPA as of the date of death will be paid to Consultant's estate.

11.04 Time is of the essence in the performance of services required hereunder. Extensions of time within which to perform services may be granted by SAWPA if requested by Consultant and agreed to in writing by SAWPA. All such requests must be documented and substantiated and will only be granted as the result of unforeseeable and unavoidable delays not caused by the lack of foresight on the part of Consultant.

11.05 SAWPA expects that Consultant will devote its full energies, interest, abilities, and productive time to the performance of its duties and obligations under this Agreement, and shall not engage in any other consulting activity that would interfere with the performance of Consultant's duties under this Agreement or create any conflicts of interest. If required by law, Consultant shall file a Conflict of Interest Statement with SAWPA.

11.06 Any dispute which may arise by and between SAWPA and the Consultant, including the Consultants, its employees, agents, and subcontractors, shall be submitted to binding arbitration. Arbitration shall be conducted by a neutral, impartial arbitration service that the parties mutually agree upon, in accordance with its rules and procedures. The arbitrator must decide each and every dispute in accordance with the laws of the State of California, and all other applicable laws. Unless the parties stipulate to the contrary prior to the appointment of the arbitrator, all disputes shall first be submitted to non-binding mediation conducted by a neutral, impartial mediation service that the parties mutually agree upon, in accordance with its rules and procedures.

11.07 During the performance of the Agreement, Consultant and its subcontractors shall not unlawfully discriminate, harass, or allow harassment against any employee or applicant for employment because of sex, race, color, ancestry, religious creed, national origin, physical disability (including HIV and AIDS), mental disability, medical condition (cancer), age (over 40), marital status and denial of family care leave. Consultant and its subcontractors shall insure that the evaluation and treatment of their employees and applicants for employment are free from such discrimination and harassment. Consultant and its subcontractors shall comply with the provisions of the Fair Employment and Housing Act (Government Code, Section 12290 et seq.) and the applicable regulations

promulgated there under (California Code of Regulations, Title 2, Section 7285 et seq.). The applicable regulations of the Fair Employment and Housing Commission implementing Government Code Section 12990 et seq., set forth in Chapter 5 of Division 4 of Title 2 of the California Code of Regulations, are incorporated into this Agreement by reference and made a part hereof as if set forth in full. Consultant and its subcontractors shall give written notice of their obligations under this clause to labor organizations with which they have a collective bargaining or other agreement. Consultant shall include the non-discrimination and compliance provisions of this clause in all subcontracts to perform work under the Agreement.

11.08 Contractor’s employees, agents and subcontractors shall adhere to, and comply with, the California Drug Free Workplace Act at Government Code, Sections 8350 through 8357.

In witness whereof, the parties hereby have made and executed this Agreement as of the day and year first above-written.

SANTA ANA WATERSHED PROJECT AUTHORITY

_____ Date
Jeffrey J. Mosher, General Manager

(CONSULTANT NAME)

_____ Date Typed/Printed Name
(Signature)



Inland Empire Brine Line Data Management System Request for Proposal

PA 24 Committee
Agenda Item No. 6.C
Lucas Gilbert

Manager of Permitting and Pretreatment
February 4, 2025

Recommendation

- That the Project Agreement 24 Committee direct staff to release an RFP for Data Management System Software for the Inland Empire Brine Line Pretreatment Program.

Pretreatment Program Summary

- SAWPA is the OC San's Delegated Control Authority for the Pretreatment Program in the Brine Line service area
- SAWPA administers the program along with its Member Agencies (4) and contract agencies (4)

Pretreatment Program Organization



Pretreatment Program Summary

- SAWPA, along with the Agencies, permit 49 industrial facilities that discharge to the Brine Line along with an additional 8 Liquid Waste Haulers

| Permits | Number |
|---------------------|-----------|
| Direct | 33 |
| Indirect | 16 |
| Liquid Waste Hauler | 8 |
| Total | 57 |

Pretreatment Program Summary

| Monitoring and Inspections | Number |
|----------------------------|--------|
| Sampling Events | 412 |
| Parameters Sampled | 310 |
| Analytical Results | 12,621 |
| Inspections | 165 |

- Regulatory oversight of these permitted facilities include sampling of the discharge to the Brine Line and inspection of each facility.
- All of these regulatory functions develop a considerable amount of records that must be stored properly to ensure adequate access and security.
- Since July 1, 2024, around 1,200 documents have been created by the pretreatment program.

Document Management System - iPACS

- Since July 1, 2014, SAWPA has employed a software called iPACS.
- SAWPA and Agency staff use iPACS to create tasks, manage pretreatment items, and upload and store records for each task for ready access by all appropriate staff.
- 24 active users across SAWPA and the Agencies use iPACS for the Brine Line Pretreatment Program

Document Management System - iPACS

- iPACS was developed on the Microsoft.Net framework, which is being sun-setted by Microsoft in December of 2025.
- iPACS will no longer be supported by Microsoft and therefore can no longer be employed as the Brine Line Database Management System (DMS).
- To ensure continued support of the pretreatment program a new DMS software needs to be selected and implemented before December 2025.

Document Management System - RFP

Technical Specifications

- DMS software must be accessible remotely through the Internet by the agencies.
- DMS software will have improvements to streamline data entry demands of SAWPA and agency staff with CROMERR certification to allow for electronic reporting of pretreatment submittals.
- Provide software development and configuration
- Install and test the application
- Provide training and documentation
- Provide ongoing technical support.

Tentative Schedule

Tentative Schedule:

Issue RFP

February 4, 2025

Receive Proposals

March 13, 2025

Contract Award

April 2025

Implement Use of Software

October 1, 2025

Recommendation

- That the Project Agreement 24 Committee direct staff to release an RFP for Data Management System Software for the Inland Empire Brine Line Pretreatment Program.

Questions?

Lucas Gilbert
Santa Ana Watershed Project Authority
Office (951) 354-4245 | Cell (951) 415-5572
lgilbert@sawpa.gov
sawpa.gov



PA 24 COMMITTEE MEMORANDUM NO. 2025.4

DATE: February 4, 2025

TO: Project Agreement 24 Committee
(Inland Empire Brine Line)

SUBJECT: Inland Empire Brine Line Master Plan Final

PREPARED BY: David Ruhl, Executive Manager of Engineering and Operations

RECOMMENDATION

Receive and file.

DISCUSSION

The purpose of the Brine Line Master Plan is to determine how best to manage and implement the growth and expansion of the Brine Line in a manner that best serves the Santa Ana River Watershed, Member Agencies, and Brine Line dischargers. The Master Plan also has the purpose of addressing infrastructure needs to convey and manage increasingly higher salinity discharges, as well as increasing regulatory requirements.

The objectives of the master plan are to identify the potential regional market for future dischargers, evaluate the capacity of the Brine Line system under a variety of anticipated flow conditions, and develop system improvements to address identified deficiencies. In addition, the master plan identifies potential projects and studies to include in the Brine Line Capital Improvement Program (CIP) and the next 2-year Budget to address deficiencies and maximize regional use of the Brine Line.

In November 2022, the PA 24 Committee approved a contract with Dudek to prepare the Brine Line Master Plan. In August 2024, staff provided an update on the draft Master Plan activities to the PA 24 Committee. A workshop with Member Agency staff was conducted in September 2024 and comments received were included in the Final Master Plan. The information provided below is organized by section of the master plan and provides a summary of the work, key findings and recommended improvement projects and studies.

Hydraulic Model Update and Calibration. The hydraulic model was updated and calibrated to fully represent the existing Brine Line system.

Market Assessment, Member Agency Coordination, and Future Growth Projections.

Member Agency and stakeholder meetings were conducted over a one-year period from February 2023 through February 2024. Information was obtained on the brine management needs of each agency including groundwater desalination, wastewater desalination and industries that have a high salinity discharge.

Information obtained from the stakeholder meetings was used to quantify the discharge projections over a defined period. Discharge projections were broken down into the Near – Term (1 – 10 years), Long – Term (11 – 35 years) and Build – Out (greater than 35 years). Table 1 shows the discharger projections by flow type and planning period.

Table 1: Discharge Projections by Flow Type and Planning Period

| Flow Type | Current June 2023 | | Near – Term 2024 - 33 | | Long – Term 2033 - 58 | | Build – Out 2058 | |
|-----------------------------|----------------------|-----|--------------------------|-----|--------------------------|-----|---------------------|-----|
| Water Supply Desalting | 10.1 | 74% | 11.6 | 62% | 16.9 | 63% | 19.1 | 59% |
| Wastewater Desalination | 1.0 | 7% | 4.5 | 24% | 5.9 | 22% | 7.2 | 22% |
| Industrial | 1.7 | 12% | 1.9 | 10% | 2.3 | 9% | 2.9 | 9% |
| Power Generation | 0.5 | 4% | 0.6 | 3% | 0.6 | 2% | 0.7 | 2% |
| Dry Weather Flow Diversions | 0.0 | 0% | 0.0 | 0% | 1.0 | 4% | 2.0 | 7% |
| Commercial | 0.3 | 2% | 0.3 | 2% | 0.3 | 1% | 0.4 | 1% |
| Total | 13.5 MGD | | 18.8 MGD | | 27.0 MGD | | 32.3 MGD | |

Key findings with respect to the market assessment and future growth expectations include:

- Potable water production and RO concentrate from groundwater desalters and ion exchange desalters maintain the largest discharge to the Brine Line by volume for all planning periods.
- Wastewater desalination, which includes RO treatment of recycled water for discharge or indirect potable recharge increases by 500% over the planning period.
- Dry weather flow diversions that have a high salinity is a potential discharge to the Brine Line.
- Industrial discharges have a moderate increase while power generation and domestic flows remain about the same through the planning period.
- Additional treatment and disposal capacity will be required to accommodate future growth. It is projected that further capacity purchases will be needed in 2026, 2034, 2042, and 2051.
- Future growth in two (2) Member Agency services areas is expected to exceed their current capacity in the Brine Line.

Brine Line System Capacity Analysis. Existing and future system conditions were modeled utilizing the calibrated hydraulic model, growth projections and planning periods previously defined.

Key findings with respect to existing and projected Brine Line discharges include:

- Potential infrastructure improvements due to higher flows were identified on Reach IV, Reach IV-A lower and Reach IV-D (Table 2: Cap – 1, CAP – 2 and Cap – 3).
- The Brine Line system has the capacity for the projected flow conditions. However, real-time monitoring of critical segments should be implemented to proactively manage and mitigate surcharging and overflows (Table 2: FM – 2).
- Dischargers will need to reduce maximum flows and manage discharges more consistently to stay within their allocated capacities.

Monitoring critical infrastructure and infrastructure improvement projects were identified to address system capacity needs. Table 2 shows these projects, planning scenario for implementation and estimated cost. Project planning scenarios should be evaluated regularly, and adjustments made based on infrastructure needs, market conditions and higher flows.

Table 2: Brine Line System Capacity Improvement Projects

| ID | Project | Planning Scenario | Cost Estimate |
|-------|---|-------------------------|---------------|
| CAP-1 | Reach IV Parallel Pipeline (Below Prado). Construct a 10,200 LF, 30-inch parallel line. | Build-out (Beyond 2048) | \$19,520,000 |
| CAP-2 | Reach IV-A Pipeline Relocation (Prado). Replace 18,000 LF of existing 36-inch pipe with 48-inch pipe. | Build-out (Beyond 2048) | \$55,114,000 |
| CAP-3 | Reach IV-D Parallel Pipeline (City of Chino). Construct a 5,9000 LF, 36-inch parallel line. | Build-out (Beyond 2048) | \$13,526,500 |
| FM-2 | Smart MAS Covers. Install smart covers at 6 locations. | Near-Term (2025-2034) | \$175,000 |

Capacity Management (30 MGD System), and Long-Term Planning Efforts. Potential long-term initiatives to improve management and performance of the Brine Line system were investigated and identified, including a reliability and redundancy analyses, real-time data collection, brine minimization and anticipated PFAS regulations and PFAS treatment options for the Brine Line system.

To improve system reliability and reduce impacts on dischargers during outages a system of storage reservoirs was investigated. The proposed plan includes seven reservoirs, strategically spaced throughout the system. These reservoirs would facilitate Brine Line shutdowns for maintenance and have the potential to provide additional system capabilities, such as capturing dry weather flows and supporting future brine minimization efforts.

To enhance monitoring and control of the Brine Line system a Supervisory Control and Data Acquisition (SCADA) based system was investigated. This system would provide remote, automated flow and water quality data collection, reducing staff time and improving compliance efforts.

With projected tributary flows expected to exceed the 30-mgd capacity limitation to OC San by approximately 2065, brine minimization strategies were investigated. These include potential implementation of secondary brine concentration processes at groundwater desalination facilities and advanced treatment technologies like Flow Reversal Reverse Osmosis (FRRO) and Ceramic Membrane with Electrodialysis Reversal (EDR).

As regulatory pressure for PFAS management intensifies, various treatment processes to remove PFAS from the Brine Line were investigated, including Novel Adsorbent Systems, Electro-oxidation, and Granular Activated Carbon.

Key findings and recommendations with respect to capacity management and long-term planning efforts include:

- Brine minimization is necessary by 2065.
- In-line centralized brine concentration approach was not considered to be feasible. However, advancements in treatment technologies and treatment requirements for emerging constituents of concern could change this finding.
- It may be more economical to remove PFAS from a few select dischargers rather than treating the Brine Flow at a centralized treatment facility.

- Evaluate the viability of point source PFAS treatment using a smaller scalable system, after performing PFAS sampling from individual dischargers.
- Conduct future study to more thoroughly assess the feasibility of Brine Line storage reservoirs. (Table 3: FM – 1, CAP – 4)
- Develop Work Plan to provide remote, automated flow and water quality data collection. (Table 3: FM – 6, CAP – 5)
- Conduct future studies and pilot projects to evaluate brine management technologies. (Table 3: FM – 4A, FM – 4B, CAP – 18)
- Conduct a pilot study to better understand and manage PFAS concentrations in the Brine Line. (Table 3: FM – 5)

Long-term initiatives, projects and studies to improve management and performance of the Brine Line were identified to address capacity management. Table 3 shows these projects, planning scenario for implementation and estimated cost. Project planning scenarios should be evaluated regularly, and adjustments made based on infrastructure needs, market conditions and higher flows.

Table 3: Capacity Management Projects and Studies

| ID | Project | Planning Scenario | Cost Estimate |
|--------|---|-------------------------------|---------------|
| FM-1 | Off-line Storage Feasibility Study | Near-Term (FY 26 & FY 27) | \$190,000 |
| CAP-4 | Off-line Storage. Construct six 2 MG and one 0.5 MG off-line storage reservoirs | Near/Long Term (2032-2048) | \$109,278,000 |
| FM-4A | Evaluate brine management technologies | Near-Term (FY 26 & FY 27) | \$80,000 |
| FM-4B | Brine Minimization Study. Evaluate brine management technologies | Near-Term (2025-2034) | \$190,000 |
| CAP-18 | Capacity Management Facility (Brine Minimization) | Build-out (Beyond 2048) | \$35,000,000 |
| FM-5 | PFAS Study. PFAS monitoring and treatment of PFAS in brine. | Near-Term (FY 26 & FY 27) | \$200,000 |
| FM-6 | SCADA System Work Plan (Real-time flow and quality data collection). | Near-Term (FY 26 & FY 27) | \$130,000 |
| CAP-5 | SCADA System. Install SCADA system in 3 – 5 phases (master station, in-line monitoring, existing discharger sites). | Near-Term (FY 26 & FY 27) | \$1,820,000 |

Multi-Use Benefits for the Future. The Brine Line is a pivotal component of SAWPA's multi-use benefit system. It transports brine from desalination and water recycling facilities and regional industrial discharges to the ocean, providing an environmentally responsible and cost-effective solution for brine disposal. This system helps mitigate environmental impacts, improve water quality, and support groundwater recharge, stormwater capture, and water reuse. The Brine Line system also promotes water conservation, public awareness, and regulatory compliance, reinforcing its role as a critical multi-use benefit infrastructure.

In exploring future opportunities, SAWPA has investigated integrating renewable energy technologies within the Brine Line system, including in-pipe hydroelectric facilities and green hydrogen production from brine flows.

Key findings and recommendations with respect to multi-use benefits include:

- In – pipe hydroelectric facilities are not economically viable at this time. However, ongoing research and development could unlock future potential.
- Green hydrogen production from brine flows has the potential to increase revenues from selling brine and manage capacity by reducing discharges to OC San.
- Conduct future study to determine if producing green hydrogen from brine is viable. (Table 4: FM – 3)

Table 4 shows a Green Hydrogen Feasibility Study, planning scenario for implementation and estimated cost.

Table 4: Multi-Use Benefits - Studies

| ID | Project | Planning Scenario | Cost Estimate |
|------|---|------------------------------|---------------|
| FM-3 | Green Hydrogen Feasibility Study. Evaluate the feasibility of Brine for Green Hydrogen. | Near-Term (FY 26 & FY 27) | \$200,000 |

Future Facilities, Improvements & Expansion. A list of recommended Brine Line future facilities and improvement projects have been developed and are included in the Capacity Analysis, Capacity Management and Multi-use section of the report and identified above.

Policy Considerations. As brine discharges increase, SAWPA faces the challenge of maintaining and/or expanding the Brine Line system. To address this a variety of policy measures may be necessary to improve brine management and efficiency. These policies would address environmental, economic, and regulatory considerations to ensure sustainable and equitable brine management.

Key policy areas for consideration include:

- **Environmental Policies.** Enhancing monitoring and reporting capabilities for continuous monitoring of brine discharges. Limits on brine discharge concentrations and constituents may be needed, particularly with emerging concerns (i.e., PFAS). Policies are intended to promote projects that restore and protect natural habitats, mandate advanced brine treatment technologies, and support stricter permitting processes for industries discharging brine.

- **Economic Policies.** Current practices require dischargers to bear the cost of facilities necessary for brine disposal, which can be cost-prohibitive. SAWPA may consider cost-sharing mechanisms, financial assistance programs, and infrastructure investments to upgrade brine treatment facilities. Incentives for sustainable brine management practices and revised fee structures to encourage reduction in brine discharge volumes may also be explored.
- **Regulatory Policies.** Updating permitting processes to include more requirements for brine management can help control Brine Line flows. Enhancing interagency collaboration and establishing a regional task force to coordinate efforts and share best practices can improve compliance and enforcement. Policies are intended to support innovative salinity control measures and advanced desalination or demineralization technologies.

Next Steps and Schedule

- | | |
|---|---------------|
| • Receive Final Master Plan | Feb 2025 |
| • Incorporate identified projects in next 2-year Budget | Jan–June 2025 |
| • Issue RFP for SCADA work Plan | Mar–Apr 2025 |
| • Incorporate long-term projects into CIP | Complete |

RESOURCE IMPACTS

Sufficient funds for consultant services are included in the Fiscal Year 25 Budget Fund 240 (Brine Line Enterprise).

Attachments:

1. PowerPoint Presentation
2. Brine Line Master Plan



Inland Empire Brine Line Master Plan

David Ruhl, Executive Manager of Engineering and Operations

PA 24 Committee Meeting

February 4, 2025



Purpose and Objectives

Master Plan Purpose and Objectives

Purpose

- Management and implementation of needed improvements that support ongoing growth and expansion of the Brine Line, and best serves SAWPA, it's Member Agencies, and Brine Line dischargers
- Address infrastructure needs to convey and manage increasingly higher salinity discharges, as well as address increasing regulatory requirements

Objectives

- Identify the regional market for brine management needs
- Evaluate the capacity of the Brine Line system
- Develop system improvements to address identified deficiencies
- Identify capacity management activities that may be implemented to maximize regional use of the Brine Line
- Include identified projects and studies in Brine Line CIP and 2- year budget as appropriate and implement based on infrastructure needs and market conditions (increased flows)



Report Organization

Master Plan Report Organization

- **Market Assessment & Future Flow Projections**
 - Summarizes ownership capacities, anticipated growth in the Brine Line service area, and discharger loadings used to develop existing and future capacity analysis scenarios.
- **Hydraulic Model Update & Calibration**
 - Describes updates to and calibration of the existing Brine Line hydraulic model to recent (June 2023) flow monitoring data
- **Brine Line System Capacity Analysis**
 - Presents the results of the capacity analyses performed on the Brine Line system under existing, near-term, long-term, buildout, and ownership discharge conditions
- **Capacity Management & Long-Term Planning Efforts**
 - Summarizes potential long-term initiatives to improve management and performance of the Brine Line system, including reliability and redundancy analyses, real-time data collection, and brine minimization. Also addresses current and anticipated PFAS regulations and PFAS treatment options for the Brine Line system.
- **Brine Line Multi-Use Benefits**
 - Describes how the Brine Line system is a multi-use benefit to the entire Santa Ana Watershed, enabling groundwater desalination, advanced recycled water treatment, industrial non-reclaimable water disposal, and a variety of other community-wide benefits
- **Future Facilities, Improvements & Expansion**
 - Presents a prioritized list of recommended Brine Line improvement projects and their estimated costs, organized into a 10-year CIP



Market Analysis and Future Flow Projections

Market Analysis and Future Flow Projections

Member Agency / Stakeholder Meetings

| Date | Agency |
|--------------------------|---|
| February 23, 2023 | San Bernardino Valley Municipal Water District |
| February 23, 2023 | San Bernardino Municipal Water Department |
| February 23, 2023 | City of Redlands |
| February 23, 2023 | East Valley Water District |
| March 8, 2023 | Eastern Municipal Water District |
| March 16, 2023 | Western Municipal Water District |
| March 30, 2023 | Inland Empire Utilities Agency |
| March 19, 2023 | Chino Basin Desalter Authority |
| May 4, 2023 | City of Corona |
| June 12, 2023 | Elsinore Valley Municipal Water District |
| June 15, 2023 | Jurupa Community Services District |
| June 15, 2023 | Yucaipa Valley Water District |
| June 21, 2023 | City of Colton |
| June 22, 2023 | Riverside County Flood Control District |
| July 13, 2023 | City of Beaumont |
| August 16, 2023 | City of Chino |
| August 17, 2023 | Temescal Valley Water District |
| August 17, 2023 | City of Riverside |
| August 24, 2023 | Rubidoux Community Services District |
| February 28, 2024 | Rancho California Water District |

Market Analysis and Future Flow Projections

Discharge Projections by Flow Type

| Flow Type | Flow Monitoring June 2023 | | Near – Term 2024 - 2033 | | Long – Term 2034 - 2048 | | Build – Out >2048 | |
|------------------------|------------------------------|-----|----------------------------|-----|----------------------------|-----|----------------------|-----|
| Water Supply Desalting | 10.1 | 74% | 11.6 | 62% | 16.9 | 63% | 19.1 | 59% |
| Wastewater Desalting | 1.0 | 7% | 4.5 | 24% | 5.9 | 22% | 7.2 | 22% |
| Industrial | 1.7 | 12% | 1.9 | 10% | 2.3 | 9% | 2.9 | 9% |
| Power Generation | 0.5 | 4% | 0.6 | 3% | .6 | 2% | 0.7 | 2% |
| Dry Weather Flow | 0.0 | 0% | 0.0 | 0% | 1.0 | 4% | 2.0 | 7% |
| Commercial | 0.3 | 2% | 0.3 | 2% | 0.3 | 1% | 0.4 | 1% |
| Total | 13.5 MGD | | 18.8 MGD | | 27.0 MGD | | 32.3 MGD | |

Market Analysis and Future Flow Projections

Potential Projects and Discharge Amount by Agency

| Future Brine Line Discharger / Project | Discharge Amount (gpd) |
|---|------------------------|
| EMWD | |
| Perris II Desalter Expansion | 900,000 |
| Ranch California Water District | 2,000,000 |
| Industrial | 125,000 |
| IEUA | |
| Chino Basin Program / New Industrial | 150,000 |
| Intertie with NRS | Undefined |
| SBVMWD | |
| YVWD | 1,161,000 |
| Regional Recycled Water Facilities Project | 1,550,000 |
| Industrial | 100,000 |
| WMWD | |
| Rubidoux CSD Desalter Facility | 2,000,000 |
| Riverside County Flood Control District DWF | 2,000,000 |
| Elsinore Valley MWD IPR | 1,200,000 |
| Temescal Valley Water District IPR | 225,000 |
| Temescal Desalter | 250,000 |
| JCSD Desalter | 4,000,000 |
| City of Riverside Recycled Water Desalination Plant | 1,000,000 |
| Industrial | 160,000 |

Market Analysis and Future Flow Projections

Key information / concerns (1 of 2)

- Ownership capacity:

| Agency | Current Ave Flows (mgd) | Current Max Flows (mgd) | Treatment and Disposal Capacity (mgd) | Pipeline Capacity (mgd) | Projected Future Need (mgd) |
|--------------|-------------------------|-------------------------|---------------------------------------|-------------------------|-----------------------------|
| CDA | 3.35 | 3.67 | 3.35 | 3.670 | 3.67 |
| EMWD | 3.53 | 4.04 | 3.548* | 5.946 | 7.0 |
| IEUA | 0.48 | 1.61 | 2.25 | 4.130 | 1.1 |
| SBVMWD | 1.56 | 2.02 | 1.639 | 7.738 | 4.8 |
| WMWD | 4.60 | 6.42 | 6.213 | 11.084 | 15.7 |
| Total | 13.52 | 17.75 | 17.0 | 32.568 | 32.27 |


* EMWD leases 0.5 MGD of T&D capacity for a total T&D Capacity of 4.048 mgd

- Capacity Management

- Dischargers need to manage discharges more consistently and not exceed maximum flows
- Future growth in 2 Member Agency services areas expected to exceed their purchased capacity

Market Research and Future Flow Projections

Key information / concerns (2 of 2)




Future investments:
Treatment and disposal capacity purchases will be needed in 2026, 2034, 2042, and 2051



Hydraulic Model Development and Calibration

Hydraulic Model Development and Calibration






Brine Line System Capacity Analysis

Brine Line System Capacity Analysis

Build-out Maximum Discharge Scenario – Max Pipeline d/D



| Reach | Segment Exceeding Capacity (ft) | % of Reach Exceeding Capacity | % of Brine Line System Exceeding Capacity |
|----------------------------|---------------------------------|-------------------------------|---|
| Reach IV | 8,250 | 53% | 2.2% |
| Reach IV-A | 12,600 | 77% | 3.3% |
| Reach IV-D | 5,850 | 5% | 1.5% |
| Total (All Reaches) | 26,750 | | 7.0% |

Brine Line Capacity Analysis

Anticipated improvements to address findings

- Potential infrastructure improvements due to higher flows identified on Reach IV, Reach IV – A lower (Prado inundation area) and Reach IV-D
- Implement smart manhole covers for real-time monitoring of critical segments to proactively manage and mitigate potential overflows and system failures
- Implement SCADA system for real-time monitoring of each discharger’s flow to resolve capacity exceedance issues

| ID | Project | Planning Scenario | Cost Estimate | Benefits | | | Funding | | |
|-------|---|-------------------------|---------------|----------|-----|------------|---------|----------|------------|
| | | | | Capacity | O&M | Regulatory | Rates | Reserves | Loan/Grant |
| CAP-1 | Reach IV Parallel Pipeline (Below Prado). Construct a 10,200 LF, 30-inch parallel line. | Build-out (Beyond 2048) | \$19,520,000 | x | | X | | x | x |
| CAP-2 | Reach IV-A Pipeline Relocation (Prado). Replace 18,000 LF of existing 36-inch pipe with 48-inch pipe. | Build-out (Beyond 2048) | \$55,114,000 | x | | x | | x | x |
| CAP-3 | Reach IV-D Parallel Pipeline (City of Chino). Construct a 5,9000 LF, 36-inch parallel line. | Build-out (Beyond 2048) | \$13,526,500 | X | | x | | x | x |
| FM-2 | Smart MAS Covers. Install smart covers at 6 locations. | Near-Term (2025-2034) | \$175,000 | X | x | x | | x | |



Capacity Management and Long-Term Planning Efforts

Capacity Management and Long-Term Planning Efforts

- Summarizes potential long-term initiatives to improve management and performance of the Brine Line system
 - Reliability and redundancy analyses
 - Enhanced monitoring and control
 - Brine minimization
 - Anticipated PFAS regulations


Capacity Management and Long-Term Planning Efforts

Reliability and Redundancy – Off-line Storage (1 of 3)

Project Description

- Seven (7) reservoirs, capable of storing a minimum 8 – hours of Brine Line flow at Build-out
- Extended storage capacity during earlier planning horizons (21 – hours at current conditions and 16 – hours at near-term conditions)

| Reach | Build-out 8 hrs of flow (MG) | Recommended Sizing (MG) |
|------------|------------------------------------|-------------------------------|
| IV-A | 0.24 | 0.5 |
| IV-B and V | 3.48 | 4.0 (2 at 2 MG) |
| IV-D | 1.88 | 2.0 |
| IV-D | 1.89 | 2.0 |
| IV-D | 1.16 | 2.0 |
| IV-E | 1.51 | 2.0 |
| Total | 10.16 | 12.5 |



Capacity Management and Long-Term Planning Efforts

Reliability and Redundancy – Off-line Storage (2 of 3)

Benefits

- Improve system reliability and reduce impacts on dischargers during outages
- Facilitate Brine Line shutdowns for maintenance, system improvements, evaluation or potentially system failure
- Provide additional system capabilities, such as capturing DWF, supporting brine minimization efforts and green hydrogen production
- Extended storage capacity during earlier planning horizons (21 – hours at current conditions and 16 – hours at near-term conditions)
- Manage peak flows
- Reduce impacts to public and environment in the event of a Brine Line Spill

Capacity Management and Long-Term Planning Efforts

Reliability and Redundancy – Off-line Storage (3 of 3)

Implementation

- Future study to more thoroughly assess the feasibility of the proposed off-line storage concept

| ID | Project | Planning Scenario | Cost Estimate | Benefits | | | Funding | | |
|-------|---|---------------------------------|---------------|----------|-----|------------|---------|----------|------------|
| | | | | Capacity | O&M | Regulatory | Rates | Reserves | Loan/Grant |
| FM-1 | Off-line Storage Feasibility Study | Near-Term (FY 26 & FY 27) | \$190,000 | x | x | x | x | | |
| CAP-4 | Off-line Storage. Construct six 2 MG and one 0.5 MG off-line storage reservoirs | Near / Long-Term (2032-2048) | \$109,278,000 | x | x | x | | x | x |

Capacity Management and Long-Term Planning Efforts

Enhanced Monitoring and Control – SCADA System (1 of 3)

Project Description

- SCADA System (Real-time flow and quality data collection) to provide remote, automated flow and water quality data collection
- Data collection and transmittal devices installed at each discharger location and at each in-line flow monitoring location

| Phase | Description of Work |
|-------|---|
| 1 | Construction and installation of Master Station, operator workstation, setup, integration of programming and automation |
| 2 | Construction and installation of first 12 discharger sites with the highest flow |
| 3 | Construction and installation of next 12 discharger sites with medium flow |
| 4 | Construction and installation of last 12 discharger sites with low flow |
| 5 | Construction and installation of up to five (5) in-line flow monitoring stations |

Capacity Management and Long-Term Planning Efforts

Enhanced Monitoring and Control – SCADA System (2 of 3)

Benefits

- Increase ability to monitor, operate and control the Brine Line system
- Reducing staff time
- Improving compliance efforts by recording potential discharge violations and facilitating future pretreatment enforcement
- Understanding of each discharger's flow and strength characteristics will allow for a more equitable distribution of costs between dischargers
- Allow for ability to resolve capacity exceedance issues
- Allows for maintenance of the Brine Line hydraulic model
- Identify potential Inflow and Infiltration

Capacity Management and Long-Term Planning Efforts

Enhanced Monitoring and Control – SCADA System (3 of 3)

Implementation

- Initiate Work Plan to develop the technical specifications, identify work area requirements, refine the cost estimate and phasing of the work

| ID | Project | Planning Scenario | Cost Estimate | Benefits | | | Funding | | |
|-------|--|------------------------------|---------------|----------|-----|------------|---------|----------|------------|
| | | | | Capacity | O&M | Regulatory | Rates | Reserves | Loan/Grant |
| FM-6 | SCADA System Work Plan (Real-time flow and quality data collection). | Near-Term (FY 26 & FY 27) | \$130,000 | x | x | x | x | | |
| CAP-4 | SCADA System. Install SCADA system in 3 – 5 phases (master station, in-line monitoring, existing discharger sites) | Near-Term* (2025-2034) | \$1,820,000 | x | x | x | | x | |


Initial phases may be completed in FY 2026-2027 determination pending completion of Work Plan.

Capacity Management and Long-Term Planning Efforts

Brine Minimization (1 of 2)

Project description

- Brine minimization facilities to assure discharges to OC San remain below the 30 mgd capacity right
- Pursue implementation of a secondary brine concentration processes at desalination facilities
- In-line downstream centralized brine concentration approach was not considered to be feasible
 - Advancements in treatment technologies and treatment requirements for emerging constituents of concern could change this conclusion



Capacity Management and Long-Term Planning Efforts

Brine Minimization (2 of 2)

Benefits

- Manage maximum flows and oversold capacity
 - Brine Line projected total flow will exceed the 30 MGD Brine Line discharge limitation to OC San
 - SAWPA Member Agencies own 32.5 MGD of pipeline capacity
- Potential to treat for emerging constituent of concern

Implementation

- Future studies and pilot projects to evaluate brine management technologies

| ID | Project | Planning Scenario | Cost Estimate | Benefits | | | Funding | | |
|--------|---|------------------------------|---------------|----------|-----|------------|---------|----------|------------|
| | | | | Capacity | O&M | Regulatory | Rates | Reserves | Loan/Grant |
| FM-4A | Evaluate brine management technologies | Near-Term (FY 26 & FY 27) | \$80,000 | x | | x | x | | |
| FM-4B | Brine Minimization Study. Evaluate brine management technologies. | Near-Term (2025-2034) | \$190,000 | x | | x | x | | |
| CAP-18 | Capacity Management Facility (Brine Minimization) | Build-out (Beyond 2048) | \$ 35,000,000 | x | | x | | x | x |

Capacity Management and Long-Term Planning Efforts

Address increasing regulatory requirements – PFAS (1 of 2)

- PFAS present in Brine Line

| Parameter | Result | Ave | Units |
|-------------------------------------|----------|-----|-------|
| Perfluorooctanoic Acid (PFOA) | 89 – 130 | 106 | ng/L |
| Perfluorooctanesulfonic Acid (PFOS) | 97 – 170 | 136 | ng/L |

- Future regulation of OC San’s biosolids and ocean discharge?
- OC San has provided advanced notice of possible PFAS limits
- Investigate PFAS treatment options for brine flows
 - No specific regulations for PFAS in wastewater currently
 - Two scenarios for PFAS effluent limits (5x PFAS MCL and 10x PFAS MCL)
 - 15 MGD capacity

| Item | Alternative 1: Novel Adsorbent Media | Alternative 2: EOX Systems | Alternative 3: Granular Activated Carbon |
|-----------------------------------|---|-------------------------------|---|
| 10 Year Capital Net Present Worth | \$70 – \$83 million | \$109 – \$129 million | \$39 – \$46 million |
| 10 Year O&M Net Present Worth | \$674 – \$796 million | \$3.3 – \$3.9 billion | \$62 – \$73 million |
| Total 10 Year Net Present Worth | \$744 – \$879 million | \$3.4 – \$4 billion | \$100 – \$118 million |

Capacity Management and Long-Term Planning Efforts

Address increasing regulatory requirements – PFAS (2 of 2)

Key findings and recommendations

- It may be more economical to remove PFAS from a few select dischargers rather than treating the entire Brine Line flow at a centralized treatment facility.
 - Assess dischargers that would be expected to have higher PFAS concentrations
- Continue to monitor PFAS regulations as they pertain to wastewater disposal and operations at OC San

Future studies

- Perform additional PFAS sampling
- Evaluate the viability of point source PFAS treatment using a smaller scalable system
- Conduct a pilot study to better inform estimates of PFAS treatment requirements and costs

| ID | Project | Planning Scenario | Cost Estimate | Benefits | | | Funding | | |
|------|---|------------------------------|---------------|----------|-----|------------|---------|----------|------------|
| | | | | Capacity | O&M | Regulatory | Rates | Reserves | Loan/Grant |
| FM-5 | PFAS Study. PFAS monitoring and treatment of PFAS in brine. | Near-Term (FY 26 & FY 27) | \$200,000 | | | x | x | | |



Multi-Use Benefits for the Future

Multi-Use Benefits for the Future

- Brine Line is a multi-use benefit system
 - Supports a variety of water recycling and desalination activities
- Improve system reliability and reduce impacts on dischargers during outages
- Integrating renewable energy technologies within the Brine Line system
 - In-pipe hydroelectric facilities (project not economically viable)
 - Green hydrogen production from brine flows
 - Future study to determine if producing green hydrogen from brine is viable
- Capture of dry weather runoff

Multi-Use Benefits for the Future

Project description

- Green hydrogen production from brine flows

Benefits

- Revenues from selling brine reduce Brine Line rates
- Reduce costs from OC San to treat and dispose of Brine
- Manage capacity by reducing discharges to OC San and remain below the 30 mgd capacity right
- Brine minimization facilities unnecessary eliminating future capital cost

Implementation

- Future study to determine if producing green hydrogen from brine is viable

| ID | Project | Planning Scenario | Cost Estimate | Benefits | | | Funding | | |
|------|---|------------------------------|---------------|----------|-----|------------|---------|----------|------------|
| | | | | Capacity | O&M | Regulatory | Rates | Reserves | Loan/Grant |
| FM-3 | Green Hydrogen Feasibility Study. Evaluate the feasibility of Brine for Green Hydrogen. | Near-Term (FY 26 & FY 27) | \$200,000 | x | | | x | | |




Future Facilities, Improvements and Expansion

Future Facilities, Improvements and Expansion

- Pipeline Capacity Improvement Projects (system capacity analysis)
- Operation and Maintenance Projects (capacity management)
- System Monitoring Projects (capacity management)
- Expansion Areas
 - EMWD / WMWD Service Area: Southern Riverside County Regional Brine Line
 - IEUA Service Area: Intertie with North System and Chino Basin Program
 - SBVMWD Service Area: Regional Recycled Water Facilities Project
 - WMWD Service Area: City of Riverside Recycled Water Desalination Plant

Future Facilities, Improvements and Expansion





Policy Considerations

Policy Considerations

- **Environmental and Regulatory Policies**

- With increasing regulatory requirements and the potential for emerging constituents of concern, SAWPA may be faced with the need to establish stricter limits on concentration and/or constituents in brine discharges
- Enhancing interagency collaboration and establishing a regional work group to coordinate efforts and share best practices can improve compliance and enforcement.

- **Economic Policies**

- Many agencies and industries have expressed concerns that the construction of brine conveyance facilities can be cost prohibitive.
- SAWPA and its Member Agencies may consider future mechanisms for cost-sharing and or funding facilities that provide a regional benefit to the watershed



Summary of Projects and Studies

| ID | Project | Planning Scenario | Cost Estimate | Benefits | | | Funding | | |
|--------|---|----------------------------|---------------|----------|-----|------------|---------|----------|------------|
| | | | | Capacity | O&M | Regulatory | Rates | Reserves | Loan/Grant |
| CAP-1 | Reach IV Parallel Pipeline (Below Prado). Construct a 10,200 LF, 30-inch parallel line. | Build-out (Beyond 2048) | \$19,520,000 | x | | X | | x | x |
| CAP-2 | Reach IV-A Pipeline Relocation (Prado). Replace 18,000 LF of existing 36-inch pipe with 48-inch pipe. | Build-out (Beyond 2048) | \$55,114,000 | x | | x | | x | x |
| CAP-3 | Reach IV-D Parallel Pipeline (City of Chino). Construct a 5,9000 LF, 36-inch parallel line. | Build-out (Beyond 2048) | \$13,526,500 | X | | x | | x | x |
| FM-1 | Off-line Storage Feasibility Study | Near-Term (FY 26 & FY 27) | \$190,000 | x | x | x | x | | |
| CAP-4 | Off-line Storage. Construct six 2 MG and one 0.5 MG off-line storage reservoirs | Near/Long Term (2032-2048) | \$109,278,000 | x | x | x | | x | x |
| FM-2 | Smart MAS Covers. Install smart covers at 6 locations. | Near-Term (2025-2034) | \$175,000 | X | x | x | | x | |
| FM-3 | Green Hydrogen Feasibility Study. Evaluate the feasibility of Brine for Green Hydrogen. | Near-Term (FY 26 & FY 27) | \$200,000 | x | | | x | | |
| FM-4a | Evaluate brine management technologies | Near-Term (FY 26 & FY 27) | \$80,000 | x | | x | x | | |
| FM-4b | Brine Minimization Study. Evaluate brine management technologies | Near-Term (2025-2034) | \$190,000 | x | | x | x | | |
| CAP-18 | Brine Minimization Study. Evaluate brine management technologies | Build-out (Beyond 2048) | \$35,000,000 | x | | x | | x | x |
| FM-5 | PFAS Study. PFAS monitoring and treatment of PFAS in brine. | Near-Term (FY 26 & FY 27) | \$200,000 | | | x | x | | |
| FM-6 | SCADA System Work Plan (Real-time flow and quality data collection). | Near-Term (FY 26 & FY 27) | \$130,000 | x | x | x | x | | |
| CAP-5 | SCADA System. Install SCADA system in 3 – 5 phases (master station, in-line monitoring, existing discharger sites). | Near-Term (FY 26 & FY 27) | \$1,820,000 | x | x | x | | x | |
| FM-7 | Master Plan Market and Capacity Analysis Update | Near-Term (2025-2034) | \$150,000 | x | x | x | x | | |

Master Plan Implementation Next Steps and Schedule

- Receive Final Master Plan Feb 2025
- Incorporate identified projects in next 2-year Budget Jan – June 2025
- Issue RFP for SCADA Work Plan Mar – Apr 2025
- Incorporate long-term Projects into CIP Complete

Questions?

Inland Empire

Brine Line Master Plan

DECEMBER 2024

Prepared for:

SANTA ANA WATERSHED PROJECT AUTHORITY

11615 Sterling Avenue

Riverside, CA 92503

Contact: David Ruhl, P.E., Executive Manager of Engineering and Operations



Prepared by:

DUDEK

605 Third Street

Encinitas, California 92024

Contact: Michael Metts, PE, Project Manager

INTENTIONALLY LEFT BLANK

Table of Contents

Acknowledgements..... vii

Acronyms and Abbreviations..... viii

Executive Summary x

 ES-1 Project Purpose and Objectives..... xi

 ES-2 Service Area and System Overview xi

 ES-3 Market Research & Future Flow Projections xiii

 ES-4 Brine Line Hydraulic Model Development and Calibration xiv

 ES-5 Brine Line Capacity Analysis..... xvi

 ES-6 Capacity Management & Long-Term Planning Efforts xviii

 ES-7 Multi-Use Benefits for the Future xviii

 ES-8 Future Facilities, Improvements & Expansion xix

 ES-9 Policy Considerations.....xx

1 Introduction 1

 1.1 Project Purpose and Objectives..... 1

 1.2 Background..... 1

 1.3 Previous Studies..... 2

 1.4 Service Area Overview 2

 1.5 Scope of Work..... 5

 1.6 Report Organization 5

2 Existing System Description 7

 2.1 Brine Line System Summary..... 7

 2.2 Brine Line Flow Characteristics & Quality 12

 2.3 Pressurized Pipelines 15

3 Market Assessment & Future Flow Projections 17

 3.1 Brine Line Discharger Workshops 17

 3.2 Pipeline, Treatment and Disposal Capacity Rights..... 19

 3.2.1 Chino Basin Desalter Authority (CDA) Summary 20

 3.2.2 Eastern Municipal Water District (EMWD) Summary..... 22

 3.2.3 Inland Empire Utilities Agency (IEUA) Summary..... 25

 3.2.4 San Bernardino Valley Municipal Water District (SBVMWD) Summary 28

 3.2.5 Western Municipal Water District (WMWD) Summary 32

 3.3 Projected Brine Line Flow Summary 38

4 Hydraulic Model Update & Calibration..... 39

 4.1 Flow Monitoring..... 39

 4.1.1 Brine Line Calibration Reaches 39

- 4.1.2 Flow Monitoring Program 41
 - 4.1.3 Brine Flow Patterns..... 41
 - 4.2 Hydraulic Model Update & Calibration..... 42
 - 4.2.1 Model Updates..... 42
 - 4.2.2 Discharger Flows..... 42
 - 4.2.3 Model Calibration..... 42
- 5 Brine Line System Capacity Analysis 51
 - 5.1 Brine Line Design Criteria 51
 - 5.2 Brine Line Evaluation Criteria 52
 - 5.3 Brine Line Capacity Analysis Results..... 53
 - 5.3.1 Existing Discharge Capacity Evaluation (June 2023) 53
 - 5.3.2 Near-Term Discharge Capacity Evaluation (2024 – 2034)..... 54
 - 5.3.3 Long-Term Discharge Capacity Evaluation (2035 – 2049)..... 59
 - 5.3.4 Buildout Discharge Capacity Evaluation (Beyond 2049) 60
 - 5.3.5 Ownership Discharge Capacity Evaluation 65
 - 5.3.6 Reach-by-Reach Analysis..... 66
 - 5.4 Capacity Analysis Summary 69
- 6 Capacity Management & Long-Term Planning Efforts 71
 - 6.1 Reliability and Redundancy 71
 - 6.1.1 Brine Line Criticality Analysis 71
 - 6.1.2 Off-Line Storage Analysis..... 72
 - 6.2 Data Collection & Real Time Management..... 75
 - 6.2.1 SCADA-based System Overview 75
 - 6.3 Brine Minimization 77
 - 6.3.1 SAWPA Salt Management Plans 79
 - 6.3.2 Arlington & Chino Desalter Studies 80
 - 6.3.3 Rancho California Demineralization Studies 80
 - 6.3.4 Emerging Brine Management Technologies 81
 - 6.3.5 Projected Brine Management Cost..... 84
 - 6.4 PFAS Management..... 85
 - 6.4.1 Overview 86
 - 6.4.2 PFAS Treatment Processes 88
 - 6.4.3 PFAS Treatment Overview 88
 - 6.4.4 Brine Line Water Quality..... 90
 - 6.4.5 PFAS Treatment Alternatives 91
 - 6.4.6 PFAS Treatment Cost Comparisons..... 99
 - 6.4.7 PFAS Treatment Costs Summary 103
 - 6.4.8 Potential for PFAS Treatment Cost Reduction 103
 - 6.4.9 PFAS Management Recommendations..... 104

7 Brine Line Multi-Use Benefits..... 107

7.1 Overview..... 107

7.2 Brine Line is a Multi-Use Benefit System 108

7.2.1 Brine Management 108

7.2.2 Stormwater Capture 108

7.2.3 Water Reuse (Recharge, IPR, DPR) 110

7.2.4 Water Conservation 110

7.2.5 Public Awareness and Education..... 110

7.2.6 Environmental Protection & Regulatory Compliance 111

7.3 Multi-Use Benefits in Water Projects..... 111

7.3.1 Multi-Benefit Framework 112

7.4 Multi-Use Benefit Considerations 113

7.4.1 Energy Production..... 115

7.4.2 Water Production 117

8 Future Facilities, Improvements & Expansion..... 119

8.1 Recommended Improvement Projects..... 119

8.1.1 Pipeline Capacity Improvement Projects..... 119

8.1.2 Facility Management (FM) Projects 122

8.1.3 System Monitoring Projects 124

8.1.4 Potential Expansion Laterals..... 124

8.1.5 Ongoing or Future Project Evaluations 128

8.2 Identified Project Cost Summaries..... 130

8.3 Project Prioritization 130

8.4 Capital Improvement Program..... 131

9 Policy Considerations..... 132

9.1 Environmental Policies..... 132

9.2 Economic Policies..... 133

9.3 Regulatory and Legal Policies..... 133

9.4 Social and Community Policies..... 134

9.5 Research and Development Policies 134

TABLES

Table ES-1: Model Calibration Results xvi

Table 2-1: Brine Line Summary by Diameter and Material^{1, 2}8

Table 2-2: Existing Brine Line Siphons and Gravity Pressure 15

Table 3-1: Discharger Workshops..... 18

Table 3-2: Pipeline Capacity Right Summary 20

Table 3-3: Treatment and Disposal Capacity Right Summary 20

Table 3-4: CDA Projected Brine Line Discharge..... 21

Table 3-5: CDA Existing Brine Line Discharges 21

Table 3-6: CDA Near-Term Brine Line Discharges 21

Table 3-7: CDA Long-Term Brine Line Discharges 22

Table 3-8: CDA Build-Out Brine Line Discharges 22

Table 3-9: EMWD Projected Brine Line Discharges..... 23

Table 3-10: EMWD Existing Brine Line Discharges 23

Table 3-11: EMWD Near-Term Brine Line Dischargers 24

Table 3-12: EMWD Long-Term Brine Line Dischargers 24

Table 3-13: EMWD Build-Out Brine Line Dischargers 24

Table 3-14: IEUA Projected Brine Line Discharges..... 25

Table 3-15: IEUA Existing Brine Line Discharges..... 26

Table 3-16: IEUA Near-Term Brine Line Dischargers..... 26

Table 3-17: IEUA Long-Term Brine Line Dischargers..... 27

Table 3-18: IEUA Build-Out Brine Line Dischargers 28

Table 3-19: SBVMWD Projected Brine Line Discharges..... 28

Table 3-20: SBVMWD Existing Brine Line Discharges..... 30

Table 3-21: SBVMWD Near-Term Brine Line Dischargers..... 30

Table 3-22: SBVMWD Long-Term Brine Line Dischargers..... 31

Table 3-23: SBVMWD Build-Out Brine Line Dischargers..... 31

Table 3-24: WMWD Projected Brine Line Discharges 32

Table 3-25: WMWD Existing Brine Line Discharges 34

Table 3-26: WMWD Near-Term Brine Line Dischargers 35

Table 3-27: WMWD Long-Term Brine Line Dischargers 36

Table 3-28: WMWD Build-Out Brine Line Dischargers 37

Table 3-29: Brine Line Discharge Summary 38

Table 4-1: Flow Monitoring Locations 39

Table 4-2: Brine Line Model Calibration Results 43

Table 5-1: Brine Line Design Criteria for Capacity Evaluation 51

Table 5-2: Brine Line Model Manning’s Roughness Coefficients (“n”) 52

Table 5-3: Limiting Capacity by Brine Line Reach per Design Criteria 66

Table 5-4: Pipeline Segments Exceeding Brine Line Capacity..... 69

Table 5-5: Summary of Recommended System Capacity Improvements (All Phases) 69

Table 6-1: Off-Line Storage Reservoir Sizing for 8 Hours of Storage (MG) 73

Table 6-2: Phasing and Projected Costs for Initial SCADA System..... 77

Table 6-3: Summary EPA Drinking Water Standards for PFAS Constituents 89

Table 6-4: PFAS Effluent Scenarios..... 90

Table 6-5: Brine Line Water Quality Data..... 90

Table 6-6: Brine Line Water PFAS Characteristics¹ 91

Table 6-7: Lifecycle Cost Model Input 99

Table 6-8: Novel Adsorbent System Construction Cost Range 100

Table 6-9: O&M Cost Estimate for Novel Adsorbent System 101

Table 6-10: Electro-Oxidation System Construction Cost Range 101

Table 6-11: O&M Cost Estimate for Electro-Oxidation System 102

Table 6-12: Granular Activated Carbon System Construction Cost Range 102

Table 6-13: O&M Cost Estimate for Granular Activated Carbon System 103

Table 6-14: PFAS Treatment Costs Summary 103

Table 6-15: PFAS Treatment Costs Reduction Summary¹ 104

Table 8-1: Recommended Pipeline Capacity Improvement Projects Summary 120

Table 8-2: Recommended Facility Management Projects Summary 122

Table 8-3: Recommended SCADA Projects Summary 124

FIGURES

Figure ES.1 Service Area Boundary xii

Figure ES-2 72-Hour Flow Meter Brine Line Calibration Flow Curves xv

Figure 1-1 Regional Map 3

Figure 1-2 Service Area Boundary 4

Figure 2-1 Existing Brine Line System by Diameter 9

Figure 2-2 Existing Brine Line System by Reach and Lateral 10

Figure 2-3 Pipeline Capacity Rights by Member Agency 11

Figure 2-4 Treatment and Disposal Capacity Right by Member Agency 12

Figure 2-5 Brine Line Historical Flow 12

Figure 2-6 Brine Line Historical TDS 13

Figure 2-7 Brine Line Historical TSS 13

Figure 2-8 Brine Line Historical BOD 14

Figure 2-8 Brine Line Siphons and Gravity Pressure Flow Pipelines 16

Figure 3-1 Average Daily Discharge by Type (mgd) 17

Figure 3-2 Pipeline Capacity Rights & Treatment/Disposal Capacity Rights by Member Agency 19

Figure 3-3 Brine Line Discharge to OC San System over Time 38

Figure 4-1 2023 Brine Line Flow Monitor Locations 40

Figure 4-2 72-Hour Brine Line Flow Patterns for Model Calibration 41

Figure 4-3 SARI Metering Station (SMS) Calibration Curve 44

Figure 4-4 FM 01 Calibration Curve 45

Figure 4-5 FM 02 Calibration Curve 46

Figure 4-6 FM 03 Calibration Curve 47

Figure 4-7 FM 04 Calibration Curve 47

Figure 4-8 FM 05 Calibration Curve 48

Figure 4-9 FM 06 Calibration Curve 49

Figure 5-1 Existing Maximum Discharge Scenario – Maximum Pipeline d/D 55

Figure 5-2 Existing Maximum Discharge Scenario – Maximum Pipeline Velocities..... 56

Figure 5-3 Near-Term Maximum Discharge Scenario – Maximum Pipeline d/D 57

Figure 5-4 Near-Term Maximum Discharge Scenario – Maximum Pipeline Velocities..... 58

Figure 5-5 Long-Term Maximum Discharge Scenario – Maximum Pipeline d/D 61

Figure 5-6 Long-Term Maximum Discharge Scenario – Maximum Pipeline Velocities..... 62

Figure 5-7 Buildout Maximum Discharge Scenario – Maximum Pipeline d/D..... 63

Figure 5-8 Buildout Maximum Discharge Scenario – Maximum Pipeline Velocities..... 64

Figure 5-9 Ownership Discharge Scenario – Maximum Pipeline d/D..... 67

Figure 5-10 Ownership Discharge Scenario – Maximum Pipeline Velocities 68

Figure 6-1 Final Criticality Summary Rankings for Brine Line Segments (2021 Analysis) 72

Figure 6-2 Conceptual Brine Line Off-Line Storage Reservoir Locations..... 74

Figure 6-3 Current Average Daily Brine Flow Production 78

Figure 6-4 Novel Adsorbent Treatment System Example (courtesy of CycloPure) 93

Figure 6-5 Proposed NAS Site Layout 94

Figure 6-6 Example of EOX Treatment System (courtesy of Aclarity) 95

Figure 6-7 Proposed EOX Site Layout..... 96

Figure 6-8 Example of GAC Treatment System (courtesy of Calgon) 97

Figure 6-9 Proposed GAC Treatment System Site Layout..... 98

Figure 7-1 Multi-Benefit Framework Steps to Inform Water Management Decisions 112

Figure 7-2 Benefit Themes (Pacific Institute, 2020)..... 112

Figure 7-3 Projected Micro-Hydro Power Capabilities..... 115

Figure 8-1 Recommended Brine Line Capacity Improvement Projects 121

Figure 8-2 Expansion Areas for Potential Brine Line Service 125

APPENDICES

Appendix A Brine Line Discharger Information

Appendix B Novel Adsorbent Treatment System Sizing and Performance Information

Appendix C Aclarity Octa Sizing and Performance Information

Appendix D GAC Treatment System Sizing and Performance Information

Appendix E Brine Line Capital Improvement Program w/ Detailed Cost Opinions

Acknowledgements

We appreciate the combined efforts of the entire project team in the development and preparation of this Brine Line Master Plan. Our project team includes staff from SAWPA and Dudek. The following individuals are respectfully and gratefully acknowledged for their contributions to the completion of this report:

Santa Ana Watershed Project Authority (SAWPA)

Jeff Mosher
General Manager

David Ruhl, P.E.
Executive Manager of Engineering and Operations

Dudek

Michael Metts, P.E.
Project Manager

Elizabeth Caliva, P.E.
Lead Engineer

Greg Guillen, P.E., PhD
Treatment Specialist

Shannon Brown, P.E.
Senior Engineer

Jenny Li, EIT
Project Engineer

Acronyms and Abbreviations

| Acronym/Abbreviation | Definition |
|----------------------|--|
| afy | acre-feet per year |
| ac | acre |
| BOD | Biological Oxygen Demand |
| CDA | Chino Basin Desalter Authority |
| CIP | Capital improvement Program |
| CoFA | Consequence of Failure Analysis |
| d/D | depth to diameter ratio |
| DPR | Direct Potable Reuse |
| EDR | electrodialysis reversal |
| EMWD | Eastern Municipal Water District |
| EOX | Electro-oxidation |
| EPA | United States Environmental Protection Agency |
| EPS | extended period simulation |
| FM | flow monitor or flow meter |
| FO | Forward Osmosis |
| fps | feet per second |
| FRP | fiberglass reinforced pipe |
| FRRO | Flow Reversal Reverse Osmosis |
| GAC | granular activated carbon |
| GIS | Geographic Information System |
| gpd | gallons per day |
| HDPE | high density polyethylene |
| HMI | Human Machine Interface |
| ICARP | Integrated Climate Adaptation and Resiliency Program |
| i.e. | that is |
| IEUA | Inland Empire Utilities Agency |
| I/I | inflow and infiltration |
| IPR | Indirect Potable Reuse |
| IRWM | Integrated Regional Water Management |
| JCSD | Jurupa Community Services District |
| kWh | kilowatt-hour |
| LF | Lineal feet |
| MAS | maintenance access structures |
| MD | Membrane Distillation |
| MG | million gallons |
| MGD or mgd | million gallons per day |
| mg/l | milligrams per liter |
| NAS | Novel Adsorbent System |
| ng/l | nanograms per liter |
| O&M | operation and maintenance |

| Acronym/Abbreviation | Definition |
|-----------------------------|--|
| OC San | Orange County Sanitation District |
| OCWD | Orange County Water District |
| OWOW | One Water One Watershed |
| PFAS | per- and polyfluoroalkyl substances |
| PFBS | perfluorobutane sulfonic acid |
| PFHxS | perfluorohexane sulfonic acid |
| PFNA | perfluorononanoic acid |
| PFOA | perfluorooctanoic acid |
| PFOS | perfluorooctane sulfonic acid |
| PLC | Programmable Logic Controller |
| PoFA | Probability of Failure Analysis |
| ppt | parts per trillion |
| psi | pounds per square inch |
| PVC | polyvinyl chloride |
| PWWF | peak wet weather flow |
| RCP | reinforced concrete pipe |
| RCSD | Rubidoux Community Services District |
| RCWD | Rancho California Water District |
| RO | reverse osmosis |
| RTU | Remote Terminal Unit |
| SARI | Santa Ana River Interceptor |
| SARW | Santa Ana River Watershed |
| SAWPA | Santa Ana Watershed Project Authority |
| SBVMWD | San Bernardino Valley Municipal Water District |
| SCADA | Supervisory Control and Data Acquisition |
| SCWO | supercritical water oxidation |
| SMS | SARI Metering Station |
| SWRP | Stormwater Resource Plan |
| TDS | Total Dissolved Solids |
| TMDL | total maximum daily load |
| TSS | Total Suspended Solids |
| UNK | unknown |
| VCP | vitrified clay pipe |
| WMWD | Western Municipal Water District |
| WWTP | Wastewater Treatment Plant |
| YVWD | Yucaipa Valley Water District |
| yr | year |

INTENTIONALLY LEFT BLANK

Executive Summary

This Executive Summary provides highlights from the Brine Line Master Plan report, summarizing the key findings and recommendations of each section. The Executive Summary consists of the following sections:

- Key Project Objectives
- Service Area and System Overview
- Market Research & Future Flow Projections
- Brine Line Hydraulic Model Development and Calibration
- Brine Line Capacity Analysis
- Capacity Management & Long-Term Planning Efforts
- Brine Line Multi-Use Benefits
- Future Facilities, Improvements & Expansion
- Policy Considerations

ES-1 Project Purpose and Objectives

The purpose of this master plan is to identify the current capacity of the Brine Line system under a variety of anticipated flow conditions, identify system deficiencies, develop near- and long-term system improvements to address identified deficiencies, as well as update and calibrate the existing SAWPA Brine Line hydraulic model. In addition, the project identifies potential capacity management activities that SAWPA may implement to maximize regional use of the Brine Line, over time. The project also identifies existing dischargers and the potential regional market for future dischargers.

The primary objectives of this project include management and implementation of needed improvements to support ongoing growth and expansion of the Brine Line, in a manner that best serves the Santa Ana Watershed, SAWPA Member Agencies, and Brine Line dischargers. The project also has the objective of addressing facility and infrastructure needs to convey and manage increasingly higher salinity discharges, as well as increasing regulatory requirements.

This Brine Line Master Plan report, prepared by Dudek for the Santa Ana Watershed Project Authority (SAWPA), evaluates the current operation and capacity of the Inland Empire Brine Line (Brine Line) system. It also makes strategic recommendations for future system improvements. This report aims to ensure that the Brine Line continues to meet the evolving needs of the Santa Ana Watershed by identifying capacity constraints, system deficiencies, and proposing enhancements to support future growth and regulatory requirements.


ES-2 Service Area and System Overview

The Brine Line network spans approximately 72 miles of pipelines with diameters ranging from 12 to 48 inches. It is segmented into various reaches: IV, IV-A, IV-B, IV-D, IV-E, and V. These segments collectively transport wastewater downstream to the Orange County Sanitation District (OC San) operated Santa Ana River Interceptor (SARI), which extends an additional 21 miles before discharging to OC San Treatment Facility No. 2 (Plant No. 2) in Huntington Beach before being released into the Pacific Ocean.

SAWPA's Member Agencies, including the Eastern Municipal Water District (EMWD), Inland Empire Utilities Agency (IEUA), San Bernardino Valley Municipal Water District (SBVMWD), and Western Municipal Water District (WMWD), have established capacity rights within the Brine Line. The Orange County Water District (OCWD), the fifth Member Agency, does not hold any capacity rights. Additionally, the Chino Basin Desalter Authority (CDA) has ownership within the system.

Figure ES-1 illustrates the geographical diversity of the Brine Line system service area. The system encompasses a large geographical area, extending from Orange County on the west, to San Bernardino County in the northeast, and to Riverside County to the southeast. The system is a 72-mile, gravity-pressure system; portions of the system convey flows under pressure flow and other portions are gravity flow, incorporating a variety of maintenance access structures (MASs) and other required appurtenances.

Figure ES.1 Service Area Boundary



ES-3 Market Research & Future Flow Projections

This Master Plan provides a comprehensive evaluation of the Brine Line system, detailing current and projected future brine discharges. The analysis draws on data from workshops conducted with various stakeholders and examines the capacity and requirements of the system to handle future growth and regulatory changes. At present, brine flows are identified by the following categories:

- Potable Water Production Facilities (Groundwater Desalters): 78-percent of total flow
- Industrial Dischargers (e.g., food processing, laundries): 11-percent of total flow
- Desalination of Recycled Water: 4-percent of total flow
- Power Generation: 4-percent of total flow
- Domestic Wastewater: 3-percent of total flow

Between February 2023 and April 2024, SAWPA conducted a series of workshops with its Member Agencies and other large dischargers. The workshops were developed to verify existing Brine Line discharges, as well as identify potential future discharges planned by the various agencies. The data was used to project the maximum anticipated discharge to the Brine Line, thereby evaluating the system's capacity to manage those projected flows. Future discharge scenarios are developed for different time frames, including:

- Existing Discharge Analysis (June 2023)
- Near-Term Discharge Analysis (2024 to 2034, 10 years)
- Long-Term Discharge Analysis (2035 to 2049, 25 years)
- Build-Out Discharge Analysis (beyond 2049)

The Brine Line system has a contractual hydraulic capacity of 30 million gallons per day (mgd) with OC San. At present, the combined pipeline capacity of the Member Agencies is 32.57-mgd, and the current treatment capacity is 17-mgd. Key findings with respect to existing and projected Brine Line discharges include:

- Western Municipal Water District (WMWD): Projected ultimate future discharge of 16.1-mgd, exceeding its ownership capacity by approximately 5.0-mgd.
- Inland Empire Utilities Agency (IEUA): Projected ultimate future discharge of 1.9-mgd, well within its ownership capacity of 4.1-mgd.
- Chino Basin Desalter Authority (CDA): Current and future discharges are expected to match its ownership capacity of 3.7-mgd.
- San Bernardino Valley Municipal Water District (SBVMWD): Projected ultimate future discharge of 4.9-mgd, within its ownership capacity of 7.7-mgd.
- Eastern Municipal Water District (EMWD): Projected ultimate future discharge of 5.2-mgd, slightly under its ownership capacity of 5.9-mgd.
- Treatment Capacity: The current average discharge to the Brine Line is 13.5-mgd, with a maximum measured flow of 17.75-mgd. The maximum flow exceeds the available treatment and disposal capacity of 17.0-mgd.

- Capacity Management: Dischargers will need to reduce maximum flows and manage discharges more consistently to stay within their allocated capacities.
- Future Investments: Additional treatment and disposal capacity will be required to accommodate future growth. It is projected that further capacity purchases will be needed in 2034, 2042, and 2051.


The Brine Line system is projected to handle increasing discharges up to a maximum of 33.5-mgd at buildout. Strategic management and investment in additional treatment capacity are essential to ensure compliance with regulatory limits and to support future growth. The workshops provided valuable insights into future needs, enabling a proactive approach to capacity planning and system upgrades.

ES-4 Brine Line Hydraulic Model Development and Calibration

As part of the Brine Line master plan and hydraulic model development, flow monitoring was performed throughout the Brine Line system to evaluate system capacity and to calibrate the existing InfoSWMM hydraulic model. To evaluate the overall system capacity and performance, the existing Brine Line system was subdivided into smaller calibration reaches. Those calibration reaches were then used in conjunction with extended-period flow monitoring to provide field data for hydraulic model validation and calibration. Flow monitoring was performed by ADS Environmental at six (6) selected locations between the dates of June 1 and June 15, 2023. Flow metering was used to develop basin-specific data for model validation and calibration.

Based on review of the flow monitoring data, it was determined that flows were highest at the SARI Metering Station (SMS) from June 7 through June 9, 2023. Therefore, that same 72-hour period was used for each of the monitoring locations to establish a conservative estimate of the basin's flow patterns. Concurrent flow data from each Brine Line discharger was collected and used to coincide with this same 72-hour monitoring period, which is discussed more in Section 4.3. **Figure ES-2** presents the six (6) 72-hour flow patterns developed for each monitoring location and used for calibration of the Brine Line model.

Figure ES-2 72-Hour Flow Meter Brine Line Calibration Flow Curves



Flow data was collected for each discharger coinciding with the Brine Line flow monitoring period of June 1 through June 15, 2023 (refer to Section 4.1 for more information on the Flow Monitoring Program). Each discharger’s flow was incorporated into the model at the specific discharge location on the Brine Line, including the average flow associated with the 2-week monitoring period. The same 72-hour period (June 7 through June 9, 2023), previously used to develop diurnal patterns for the six flow monitoring locations, were used to develop unique diurnal patterns for each discharger. In this manner, there is consistency between the flow monitoring and discharge data for the calibration process.

Average discharger flow and 72-hour diurnal patterns were incorporated into the hydraulic model, and extended period simulations were executed over a 7-day modeling analysis period. Flow values and patterns at each of the seven flow monitoring locations were compared to the modeling analysis results. Model calibration is achieved by observing average flow values at the six monitoring locations and adjusting the 72-hour flow patterns, as necessary, to achieve a consistent result between the average and maximum flow values and patterns between the model and the flow monitoring results. The hydraulic model is deemed to be “calibrated” when both average and maximum model predictions reflected field measurements with 10% or less. The following **Table ES-1** summarizes the results of the calibration process for each calibration reach.

Table ES-1: Model Calibration Results

| Flow Meter | Calibration Results | | | | | |
|--------------------|---------------------|---------------|--------|----------------|---------------|--------|
| | Average Flows | | | Maximum Flows | | |
| | Measured (mgd) | Modeled (mgd) | % Diff | Measured (mgd) | Modeled (mgd) | % Diff |
| SMS | 13.34 | 13.53 | 1.4 | 14.02 | 14.99 | 6.9 |
| FM 01 | 0.31 | 0.30 | 3.9 | 0.53 | 0.56 | 6.8 |
| FM 02 ¹ | 8.53 | 6.77 | 20.6 | 9.17 | 7.35 | 19.9 |
| FM 03 | 6.87 | 6.48 | 5.8 | 7.74 | 7.54 | 2.5 |
| FM 04 | 3.98 | 3.71 | 6.9 | 4.76 | 4.54 | 4.6 |
| FM 05 ² | 2.13 | 1.75 | 17.5 | 2.41 | 2.08 | 13.4 |
| FM 06 | 1.40 | 1.46 | 3.9 | 1.60 | 1.70 | 6.5 |

Notes:

FM = flow meter

¹ The sum of the averages of FM 01, 02 and 03 should be approximately equal to the average flow at the SMS. The sum of the measured averages equal 15.7-mgd, while the sum of the modeled averages equal 13.5-mgd. Therefore, it was determined that the flow meter at FM 02 was measuring inaccurately.

² The calibration of FM 05 was reviewed and determined that FM 05 was also measuring inaccurately. Both the upstream (FM 06) and downstream (FM 04) flow data calibrated well.

It is noted that two of the six flow monitoring locations (FM 02 and FM 05) did not calibrate within the desired 10 percent accuracy. Section 4.2.3 provides more information on the calibration process for the hydraulic model and what investigation of the data found as two why FM 02 and FM 05 modeled versus measured flows did not result in values within 10 percent.

The updated and calibrated InfoSWMM hydraulic model provides a reliable tool for simulating the Brine Line system's hydraulic performance. The model accurately reflects average and maximum flow conditions, allowing for effective capacity analysis and system planning. The identified discrepancies and subsequent adjustments underscore the importance of continuous monitoring and validation to maintain model accuracy. This calibration effort ensures that the Brine Line system is well-prepared to handle current and future demands.

ES-5 Brine Line Capacity Analysis

The Brine Line system Capacity Analysis evaluates the hydraulic capacity of the Brine Line under multiple discharge scenarios, including Existing, Near-Term, Long-Term, Buildout, and Ownership conditions. This analysis, based on the updated and calibrated Brine Line hydraulic model, identifies potential system deficiencies, and informs future infrastructure improvements to ensure reliable service and accommodate increasing discharge demands. Key findings of the Capacity Analysis include:

Design Criteria

- Gravity pipelines are intended to maintain a minimum velocity of 2.0 feet per second (fps) during maximum discharge to ensure self-cleaning and prevent solids deposition.

- The maximum depth-over-diameter ratio (d/D) for gravity pipelines is set at 0.75 to provide sufficient headspace for inflow and infiltration (I/I) during wet weather events. While there is currently no indication of I/I issues currently in the system, these issues may arise as the system ages.
- Pressurized pipelines have maximum pressure limits of 80 pounds per square inch (psi) for Reach V and 55 psi for the top of Reach IV-E.

Existing Discharge Capacity (June 2023)

- All gravity flow pipelines maintained a d/D below 0.75.
- Maximum pressure in Reach V was 56 psi, and in the top of Reach IV-E, it was 6 psi.
- Pipeline velocities met or exceeded 2.0 fps, except in specific low-flow segments, which are expected to improve with increased future flows.

Near-Term Discharge Capacity (2023-2033)

- No gravity pipelines are anticipated to exceed a d/D of 0.75.
- Maximum pressures remain within acceptable limits.
- Increased flows result in higher velocities, meeting the minimum 2.0 fps threshold.

Long-Term Discharge Capacity (2034-2058)

- Portions of Reaches IV-D, IV-A, and IV are projected to exceed the 0.75 d/D criterion, with some sections expected to flow at full capacity (d/D of 1.0).
- Maximum pressures and velocities remain within design limits, though closer to thresholds.

Buildout Discharge Capacity (Beyond 2058)

- Additional segments are expected to exceed the 0.75 d/D criterion, with increased risks of surcharging and overflows.
- Higher flows necessitate potential infrastructure improvements to prevent system deficiencies.

Ownership Discharge Capacity

- Similar to Long-Term and Buildout scenarios, specific segments are projected to exceed the d/D criterion, requiring monitoring and potential upgrades.
- Maximum pressures and velocities remain within acceptable ranges but approach critical limits.

To address the identified capacity issues and ensure the Brine Line can accommodate future discharge demands, the following improvements are anticipated, including:

- The 36-inch fiberglass reinforced pipe (FRP) pipeline along Prado Dam should be upsized to 48 inches and relocated to prevent surcharging and overflow risks.

- Implement smart manhole covers for real-time monitoring of critical segments to proactively manage and mitigate potential overflows and system failures.

ES-6 Capacity Management & Long-Term Planning Efforts

In 2021, Dudek performed a criticality analysis of the Brine Line system, spanning over 73 miles and composed of various materials such as lined reinforced concrete, PVC, and HDPE. The Brine Line, which uses both open channel and gravity pressure flow conditions, is equipped with maintenance access structures to ensure operational efficiency. The objective of the analysis was to identify and prioritize critical components within the system, guiding SAWPA's financial policy decisions and prioritizing asset maintenance and capital improvement projects (CIP).

To improve system reliability and reduce impacts on dischargers during outages, SAWPA is investigating the construction of off-line storage reservoirs. The proposed plan includes seven reservoirs, capable of storing a minimum of 8-hours of Brine Line flow, strategically spaced throughout the system. These reservoirs would facilitate Brine Line shutdowns for maintenance and provide additional system capabilities, such as capturing dry weather stormwater flows and potentially supporting future brine minimization efforts.

To enhance monitoring and control of the Brine Line system, SAWPA is proposing the implementation of a Supervisory Control and Data Acquisition (SCADA) based system. This system would provide remote, automated flow and water quality data collection, reducing staff time and improving compliance efforts. The SCADA system concept includes Remote Terminal Units (RTUs), communication infrastructure, a SCADA master station, a data historian, alarm management, and security features.

With projected tributary flows expected to exceed the 30-mgd discharge limitation to OC San by approximately 2065, SAWPA is exploring brine minimization strategies. These include potential implementation of secondary brine concentration processes at groundwater desalination facilities and advanced treatment technologies like Flow Reversal Reverse Osmosis (FRRO) and Ceramic Membrane with Electrodialysis Reversal (EDR).

As regulatory pressure for per- and polyfluoroalkyl substances (PFAS) management intensifies, SAWPA is evaluating various treatment processes to remove PFAS from the Brine Line, including Novel Adsorbent Systems, Electro-oxidation, and Granular Activated Carbon. The assessment recommends conducting a pilot study and collecting water samples from individual dischargers to better understand and manage PFAS concentrations.

ES-7 Multi-Use Benefits for the Future

SAWPA remains dedicated to conducting its regional activities in a manner that supports the Santa Ana Watershed and its communities. The One Water One Watershed (OWOW) program is a testament to this commitment, promoting integrated water resource management and supporting multi-benefit projects to ensure watershed sustainability. As part of California's Integrated Regional Water Management (IRWM) Program, OWOW emphasizes collaborative planning and management across various disciplines, including water supply, water quality, stormwater management, and habitat protection. It particularly addresses the needs of Disadvantaged Communities and Native American tribal communities.

SAWPA's Roundtables facilitate joint water resource management and regulatory compliance, creating value through stakeholder collaboration and cost-effective solutions to water management challenges. Recent

environmental challenges, such as climate change and prolonged droughts, underscore the importance of SAWPA's initiatives. Projects like the 2020 feasibility study on cloud seeding for increasing water supply in the Santa Ana River Watershed exemplify SAWPA's innovative approach to regional water resiliency.

The Brine Line is a pivotal component of SAWPA's multi-use benefit system. It transports brine from desalination and water recycling facilities and regional industrial discharges to the ocean, providing an environmentally responsible and cost-effective solution for brine disposal. This system helps mitigate environmental impacts, improve water quality, and support groundwater recharge, stormwater capture, and water reuse. The Brine Line system also promotes water conservation, public awareness, and regulatory compliance, reinforcing its role as a critical multi-use benefit infrastructure.

In exploring future opportunities, SAWPA has investigated integrating renewable energy technologies within the Brine Line system, including in-pipe hydroelectric facilities and green hydrogen production from brine flows. While current feasibility indicates limited immediate opportunities for power generation, ongoing research and development could unlock future potential.

Overall, SAWPA's approach emphasizes the interconnected nature of water resources, advocating for integrated water management strategies that enhance sustainability, economic efficiency, and environmental stewardship. Through innovative projects and collaborative efforts, SAWPA aims to create a resilient, sustainable, and livable environment for the Santa Ana Watershed and its communities.

ES-8 Future Facilities, Improvements & Expansion

Chapter 8 of the Inland Empire Brine Line Master Plan focuses on future expansion opportunities, ongoing project evaluations, and the future Capital Improvement Program (CIP). This chapter highlights the critical planning and investment needed to support long-term operational needs, regulatory compliance, and strategic objectives. Key highlights include evaluation of new Brine Line management approaches:

- **Criticality Analysis:** Updates to prioritize infrastructure needs.
- **Off-Line Storage:** Reservoirs for brine storage during outages.
- **Real-Time Monitoring:** SCADA systems for enhanced system control.
- **Brine Minimization:** Advanced treatment and disposal technologies.
- **PFAS Management:** Compliance and treatment strategies.
- **Green Hydrogen:** Feasibility studies for renewable hydrogen production using brine.

Project Cost and Prioritization. Projects are evaluated based on urgency, cost-effectiveness, regulatory compliance, and environmental sustainability. Key considerations include critical infrastructure needs, operational efficiency, and regional goals. A phased approach distributes projects across:

- **Near-Term (2025–2034):** Address immediate challenges and operational needs.
- **Long-Term (2035–2048):** Support growth and adaptability.
- **Build-Out (Beyond 2049):** Address long-term strategic goals.

Chapter 8 emphasizes the importance of strategic planning, regional collaboration, and phased investments to ensure the Brine Line system meets future demands. By prioritizing expansion opportunities, integrating advanced technologies, and aligning with regulatory requirements, SAWPA will secure the system's role as a critical water quality management resource for the Inland Empire well into the future.

ES-9 Policy Considerations

SAWPA is dedicated to protecting and enhancing the water resources of the Santa Ana River Watershed. Their mission involves developing and maintaining regional plans, programs, and projects that optimize the beneficial uses of the watershed in an economically and environmentally responsible manner. Key areas of focus include water supply reliability, water quality improvement, recycled water, wastewater treatment, groundwater management, brine disposal, and integrated regional planning.

As brine discharges increase, SAWPA faces the challenge of maintaining and/or expanding the Brine Line system. To address this, SAWPA is considering a variety of policy measures to improve brine management and efficiency. These policies address environmental, economic, social, and regulatory considerations to ensure sustainable and equitable brine management. Key policy areas for consideration include:

- **Environmental Policies.** SAWPA is considering enhanced monitoring and reporting capabilities for continuous monitoring of brine discharges. Limits on brine discharge concentrations and constituents may be needed, particularly with emerging concerns (i.e., PFAS). Policies are intended to promote projects that restore and protect natural habitats, mandate advanced brine treatment technologies, and support stricter permitting processes for industries discharging brine.
- **Economic Policies.** Current practices require dischargers to bear the cost of facilities necessary for brine disposal, which can be cost-prohibitive. SAWPA may consider cost-sharing mechanisms, financial assistance programs, and infrastructure investments to upgrade brine treatment facilities. Incentives for sustainable brine management practices and revised fee structures to encourage reduction in brine discharge volumes may also be explored.
- **Regulatory and Legal Policies.** Updating permitting processes to include more requirements for brine management can help control Brine Line flows. Enhancing interagency collaboration and establishing a regional task force to coordinate efforts and share best practices can improve compliance and enforcement. Policies are intended to support innovative salinity control measures and advanced desalination or demineralization technologies.
- **Social and Community Policies.** SAWPA may establish regular forums for stakeholder engagement, including public meetings and community consultations, to educate the community about brine management issues and solutions. Policies would be intended to ensure that impacts on disadvantaged communities are considered, increasing transparency and accountability in decision-making processes.
- **Research and Development Policies.** Investing in research and development of new brine management technologies is crucial for the Brine Line's long-term viability. SAWPA could fund or cost-share research initiatives, partner with academic institutions, and invest in data collection infrastructure to support evidence-based policy making. Leveraging new technologies like remote sensing and real-time monitoring systems can enhance brine management.

Implementing these policies will assist SAWPA with ensuring sustainable brine management, protect the watershed's ecological health, and support the region's long-term water quality goals.

1 Introduction

This Brine Line Master Plan report for the Santa Ana Watershed Project Authority (SAWPA) evaluates the operation and capacity of the existing Inland Empire Brine Line (Brine Line) system and makes recommendations for future system improvements. The report was prepared by Dudek. The following section provides background information on the scope and objectives of the Master Plan project, the SAWPA Brine Line system and service area, and the contents and organization of the report.

1.1 Project Purpose and Objectives

The purpose of this master plan is to identify the current capacity of the Brine Line system under a variety of anticipated flow conditions, identify system deficiencies, develop near- and long-term system improvements to address identified deficiencies, as well as update and calibrate the existing SAWPA Brine Line hydraulic model. In addition, the project identifies potential capacity management activities that SAWPA may implement to maximize regional use of the Brine Line, over time. The project also identifies existing dischargers and the potential regional market for future dischargers.

The primary objectives of this project include management and implementation of needed improvements to support ongoing growth and expansion of the Brine Line, in a manner that best serves the Santa Ana Watershed, SAWPA Member Agencies, and Brine Line dischargers. The project also has the objective of addressing facility and infrastructure needs to convey and manage increasingly higher salinity discharges, as well as increasing regulatory requirements.

1.2 Background

SAWPA, formed in 1972, owns, plans, and operates facilities to protect water quality within the Santa Ana Watershed. **Figure 1-1** presents a regional map illustrating the extents of the watershed in Southern California. SAWPA is a Joint Powers Agency comprised of five (5) Member Agencies, including Eastern Municipal Water District (EMWD), Inland Empire Utilities Agency (IEUA), Orange County Water District (OCWD), San Bernardino Valley Municipal Water District (SBVMWD), and Western Municipal Water District (WMWD), as shown on **Figure 1-2**.

The SAWPA Brine Line accepts brine and other highly saline industrial wastewater discharges within the Santa Ana Watershed. The Brine Line is a regional facility with a pipeline capacity of 30 million gallons per day (mgd), tributary to the Orange County Sanitation District (OC San) system and ultimately to an ocean outfall. The Brine Line was constructed to dispose of high salinity wastes from groundwater desalination, power plants, and industrial users. Low initial flows resulted in allowing temporary discharges of lower salinity domestic wastewaters, increasing revenue, flow, and velocities. Removing excess salts from the watershed maintains watershed water quality, increasing groundwater resources and expanding recycled water beneficial use. The long-term regional goal achieves salt balance within the watershed, dependent on export of salt through the Brine Line system.

SAWPA and its Member Agencies conducted many studies focused on 1) understanding capabilities and conditions in the Brine Line, 2) planning future increases in high salinity discharges, and 3) planning for promulgation of new regulatory requirements affecting operation and maintenance of the Brine Line system. This master plan builds on these previous studies to provide an updated understanding of the system that addresses the current and future

needs of the Brine Line. This master plan assists SAWPA, its Member Agencies, and other stakeholders in defining actions for improvement of Brine Line operation and maintenance, thereby achieving watershed-wide salt balance sustainability under multiple projected future growth scenarios.

1.3 Previous Studies

The following previous studies were reviewed as part of this study:

- Inland Empire Brine Line Criticality Assessment, March 2021, Dudek
- Inland Empire Brine Line Overflow Emergency Response Plan, March 2021, SAWPA
- Phase 1 Salinity Management Plan, January 2010, CDM/Carollo/Wildermuth
- Phase 2 SARI Planning, May 2010, CDM/Carollo/Wildermuth
- Phase 3 SARI Operations, May 2010, CDM/Carollo/Wildermuth
- Eastern Municipal Water District Brine Management System Basis of Design Report, March 2009, CDM
- Santa Ana Regional Interceptor Market Analysis, August 2009, Environmental Engineering & Contracting, Inc.
- Santa Ana Regional Interceptor Hydraulic Model and Capacity Assessment, January 2006, Kennedy/Jenks

1.4 Service Area Overview

The Brine Line is a pipeline system that protects the Santa Ana Watershed from desalter concentrates and various high saline wastewater. Industries whose processes create high-saline waste that does not qualify for reuse, reclamation or return to the region through the municipal sewer system domestic wastewater treatment plants, may be discharged to the Brine Line. The pipeline system conveys this high saline wastewater to OC San's Treatment Facility in Huntington Beach. After treatment, the high saline wastewater is discharged to the Pacific Ocean.

The Brine Line system is comprised of six reaches, extending from Orange County on the west, to San Bernardino County in the northeast, and to Riverside County to the southeast. The system has over 72 miles of pipeline, ranging in diameter, age, material, and other critical categories. The system is a gravity pressure system, such that portions of the system convey flows under pressure flow and other portions are gravity flow, incorporating a variety of maintenance access structures (MASs) and other required appurtenances. The age and materials of the system's construction have changed with time, with initial construction including lined reinforced concrete and more recent construction incorporating polyvinyl chloride (PVC) and high-density polyethylene (HDPE) pipeline materials.



Figure 1-1 Regional Map




Figure 1-2 Service Area Boundary

1.5 Scope of Work

The following tasks are included in the scope of this Brine Line Master Plan:

- Data Collection and Review of Existing System
- Market Analysis and Future Growth Projections
- Flow Monitoring
- Hydraulic Model Update and Calibration
- Capacity Analysis
- Capacity Management and Long-Term Planning Efforts
- Brine Line Multi-Use Benefits
- Future Policy Considerations
- Development of CIP and Planning-Level Cost Opinion
- Report Delivery and Presentation to SAWPA Stakeholders

1.6 Report Organization

This Brine Line Master Plan report is organized into the following sections:

- **Section 1 Introduction** – Describes the background, objectives, scope of work, and structure of the report. Summarizes key characteristics of the Brine Line system and service area.
- **Section 2 Existing System Description** – Summarizes features of the existing Brine Line system including pipeline alignments, diameters, siphons, and flow characteristics.
- **Section 3 Market Assessment & Future Flow Projections** – Summarizes ownership capacities, anticipated growth in the Brine Line service area, and discharger loadings used to develop existing and future capacity analysis scenarios.
- **Section 4 Hydraulic Model Update & Calibration** – Describes updates to and calibration of the exiting Brine Line hydraulic model to recent (June 2023) flow monitoring data.
- **Section 5 Brine Line System Capacity Analysis** – Presents the results of the capacity analyses performed on the Brine Line system under existing, near-term, long-term, buildout, and ownership discharge conditions.
- **Section 6 Capacity Management & Long-Term Planning Efforts** – Summarizes potential long-term initiatives to improve management and performance of the Brine Line system, including reliability and redundancy analyses, real-time data collection, and brine minimization. Also addresses current and anticipated PFAS regulations and PFAS treatment options for the Brine Line system.
- **Section 7 Brine Line Multi-Use Benefits** – Describes how the Brine Line system is a multi-use benefit to the entire Santa Ana Watershed, enabling groundwater desalination, advanced recycled water treatment, industrial non-reclaimable water disposal, and a variety of other community-wide benefits.

- **Section 8 Future Facilities, Improvements & Expansion** – Presents a prioritized list of recommended Brine Line improvement projects and their estimated costs, organized into a 10-year Capital Improvement Program (CIP).
- **Section 9 Policy Considerations** – Discusses various policies that SAWPA and their Member Agencies may implement to enhance and strengthen Brine Line service throughout the Santa Ana Watershed.

2 Existing System Description

This section summarizes existing elements of the Brine Line system. The Brine Line features both a gravity collection system and pressurized pipelines designed to convey flows across the wide range of elevations within its service area. Information from the Brine Line Geographic Information System (GIS) database, existing hydraulic model, previous reports and studies, and as-built drawings were used to complete the following summary of the system.

2.1 Brine Line System Summary

The Brine Line system consists of approximately 72 miles of pipeline ranging in diameter from 12 to 48-inch, as summarized in **Table 2-1** and depicted in **Figure 2-1**. The Brine Line is divided into reaches, including Reach IV, IV-A, IV-B, IV-D, IV-E, and V as shown in **Figure 2-2**. Downstream of Reach IV, the OC San owned and operated Santa Ana River Interceptor (SARI) continues for 21 miles before discharging to OC San Treatment Facility No.2 (Plant No. 2) in Huntington Beach. The SARI line includes Reach I, II, and III. Finally, flows are discharges to the Pacific Ocean through OC San’s ocean outfall.

Four of SAWPA’s five Member Agencies – Eastern Municipal Water District (EMWD), Inland Empire Utilities Agency (IEUA), San Bernardino Valley Municipal Water District (SBVMWD), and Western Municipal Water District (WMWD) have established capacity rights in the Brine Line system. The fifth Member Agency, Orange County Water District (OCWD), does not own any capacity in the SARI or Brine Line systems. The Chino Basin Desalter Authority (CDA) also has ownership within the Brine Line.

To connect to the Brine Line, individual dischargers often construct and maintain dedicated laterals designed to convey flows from the discharge point (e.g., treatment plant, desalter, industrial facility) to a Brine Line reach. The privately owned and operated laterals were not evaluated as part of the Master Plan; however, efforts were made to research and describe the laterals herein for greater context of the overall Brine Line system. The following laterals are tributary to the Brine Line, but not owned or operated by SAWPA:

- **EMWD Brine Line Extension:** 15-mile pipeline connecting EMWD’s Perris and Menifee desalters and other high saline industrial dischargers in EMWD’s service area to Reach V. Constructed by EMWD in 1998 and 2001.
- **YVWD Brine Line Extension:** 16-mile pipeline connecting the Yucaipa Valley Water District’s (YVWD) Wochholz Regional Water Recycling Facility to Reach IV-E. Constructed by YVWD in 2012.
- **City of Beaumont Brine Line Extension:** 23-mile pipeline connecting the City of Beaumont’s wastewater treatment plant reverse osmosis facility to Reach IV-E. Constructed by Beaumont in 2020.
- **CRC Lateral:** 3-mile pipeline built as part of the original construction of Reach IV-B.
- **JCSD Laterals:** Ten (10) temporary connections to Reach IV-D, constructed by Jurupa Community Services District (JCSD). Only three (3) connections – Etiwanda, Wineville, and Hamner – remain active today.
- **Enertech (RBF) Lateral:** 0.5-mile pipeline connecting the Rialto Bioenergy Facility (RBF) to Reach IV-E. Constructed by Enertech.
- **Mountainview Power Plant Laterals:** Lateral connecting the Mountainview Power Plant to YVWD Brine Line Extension and subsequently, to Reach IV-E.

- **Corona Lateral:** 0.5-mile pipeline built as part of the original construction of Reach IV-B connecting high saline industrial dischargers and the WMWD collection station to Reach IV-B

Table 2-1: Brine Line Summary by Diameter and Material^{1, 2}

| Diameter (inches) | Length of Pipe (ft) | | | | | | Subtotals | % of Total |
|-------------------|---------------------|---------------------|---------------|---------------------|---------------|------------|----------------|---------------|
| | VCP | RCP | HDPE | PVC | FRP | Other | | |
| 12 | - | - | - | 5,084 | - | - | 5,084 | 1.3% |
| 16 | - | - | - | 19,983 | - | - | 19,983 | 5.3% |
| 18 | - | - | - | 4,433 | - | - | 4,433 | 1.2% |
| 23 | - | - | - | 19,950 ³ | - | - | 19,950 | 5.3% |
| 24 | - | - | - | 16,884 | - | - | 16,884 | 4.5% |
| 26 | - | 21,657 ⁴ | 49,702 | - | - | - | 71,359 | 18.9% |
| 27 | - | 3,123 | - | - | - | - | 3,123 | 0.8% |
| 30 | - | - | 423 | 23,852 | 15,957 | - | 40,232 | 10.7% |
| 32 | - | - | 4,900 | - | - | - | 4,900 | 1.3% |
| 36 | 10,066 | 42,735 | - | - | 16,598 | - | 69,399 | 18.4% |
| 39 | 52,409 | 715 | - | - | - | - | 53,124 | 14.1% |
| 42 | 38,213 | 22,417 | - | - | - | 449 | 61,079 | 16.2% |
| 48 | - | 8,185 | - | - | - | 4,773 | 8,185 | 2.2% |
| Totals | 100,688 | 98,832 | 55,025 | 90,186 | 32,555 | 449 | 377,735 | 100.0% |
| % of Total | 26.7% | 26.2% | 14.6% | 23.9% | 8.6% | 0.1% | 100.0% | 100.00% |

Notes:

- ¹ Per "User Tag" attribute in existing Brine Line InfoSWMM model.
- ² Material type definitions include vitrified clay pipe (VCP), reinforced concrete pipe (RCP), high density polyethylene (HDPE) and plastic/polyvinyl chloride (PVC), and fiberglass reinforced pipe (FRP).
- ³ 23-inch PVC pipeline material refers to the CIPP-lined sections of Reach V, completed as part of recent rehabilitation projects.
- ⁴ 26-inch RCP pipeline material refers to the CIPP-lined sections of Reach IV-A Upper.




Figure 2-1 Existing Brine Line System by Diameter




Figure 2-2 Existing Brine Line System by Reach and Lateral

Dischargers to the Brine Line system consist of direct dischargers (physical connections) and indirect dischargers (using wastehauler collection stations). Direct dischargers may own or lease pipeline, treatment, and disposal capacity in the Brine Line system, and include discharges of desalter brine, industrial high saline wastewater, and/or domestic wastewater. SAWPA also has authorized connections with specific agencies to provide fail-safe discharges for emergency situations. **Figures 2-3** and **2-4** summarize the 2024 Brine Line pipeline and treatment ownership, incorporating the current leased capacity program transfers of capacity.

Four (4) wastehauler collection stations are provided, one within each Member Agency’s service area, operated by the corresponding Member Agency. The dump stations are located at: (1) EMWD’s Perris/Menifee Desalter, (2) Upstream of IEUA’s Regional Plant 2, (3) the City of San Bernardino’s Wastewater Treatment Plant (WWTP), and (4) the City of Corona’s WWTP.

The Brine Line exports an average of approximately 92,800 tons of salt from the Santa Ana River Watershed per year.

Figure 2-3 Pipeline Capacity Rights by Member Agency





Figure 2-4 Treatment and Disposal Capacity Right by Member Agency



2.2 Brine Line Flow Characteristics & Quality

As of January 2024, the Brine Line conveys approximately 11.1-mgd (average monthly flow between January 2010 and January 2024), representing both direct and indirect dischargers. As shown by the trendline on **Figure 2-5**, Brine Line flows decreased from January 2010 through June 2017. Since June 2017, Brine Line flow has increased. As Brine Line flows increase, this is the most opportune time to complete the Brine Line Master Plan.





Figure 2-5 Brine Line Historical Flow



Although originally constructed to remove high salinity wastewater from the Santa Ana River watershed, domestic wastewater and low salinity flows have been accepted, which constituted most of the flow through 2005. With construction of brackish groundwater desalters and domestic discharge reduction, the percentage of low salinity flow has declined. Since 2009, approximately 75 percent of flow has been representative of municipal desalination facilities and power plants. **Figure 2-6** shows a gradual increase in Total Dissolved Solids (TDS) with time, and the trendline projects continuing increase in TDS (salt-

content). The current average monthly TDS of Brine Line flows is approximately 5,575 mg/L (510,000 pounds of salt per day).

With flow changes, SAWPA has identified challenges related to suspended solids concentrations, not attributable to typical discharge water quality. SAWPA conducted studies evaluating Total Suspended Solids (TSS) generation relative to desalination brine and high Biological Oxygen Demand (BOD) wastewaters. **Figure 2-7** shows historical TSS concentrations in the Brine Line, with 2010-era TSS concentrations being more than 200 mg/L. Over time, TSS concentrations have decreased, the trendline showing reduction to 100 mg/L.




Figure 2-7 Brine Line Historical TSS

Solids generation resulting from TSS loadings at the downstream end of the Brine Line more than double the typical discharger loading. TSS imbalance continues to be an intermittent challenge for SAWPA, but TSS concentrations are continuing to decrease.




Figure 2-8 Brine Line Historical BOD

Figure 2-8 illustrates the historical BOD concentrations through July 2022. BOD concentrations have decreased, but are steady at an average monthly concentration of approximately 40 mg/L. BOD concentrations will continue to decrease as domestic dischargers are eliminated. Domestic dischargers represent approximately 0.37-mgd of the 11.0-mgd average flow, about three percent.

2.3 Pressurized Pipelines

The Brine Line system includes fifteen (15) inverted siphons as well as long stretches of gravity pressure flow, particularly in Reach V, as presented in **Table 2-2** and shown in **Figure 2-8**.

A siphon is a pipeline that dips or sags to cross under an existing storm channel, body of water (e.g., stream or creek), utilities, or other overlying structure. Inverted siphons are designed to operate below the hydraulic grade line and thus are always flowing full (i.e., under pressure).

Gravity pressure flow pipelines are longer reaches of pipe designed to flow under pressure depending on upstream flow conditions. These sections have sealed maintenance access structures (MAS) to ensure water does not escape the line.

Table 2-2: Existing Brine Line Siphons and Gravity Pressure

| Siphon ID | To/From MAS ID | Structure Crossing | Pipe Size (inch) |
|-----------|---------------------|------------------------------|------------------|
| 1 | 4A-SS-7 to 4A-SS-10 | Central Ave | 26 |
| 2 | 4A-SS-1 to 4A-SS-4 | Chino Creek | 23 |
| 3 | 4B-0350 to 4B-0410 | River Road & Temescal Creek | 36 |
| 4 | 4D-0030 to 4D-0060 | Chino Creek | 42 |
| 5 | 4D-0190 to 4D-0200 | Stormwater Infrastructure | 42 |
| 6 | 4D-0330 to 4D-0360 | Stormwater Channel | 42 |
| 7 | 4D-0700 to 4D-073 | Stormwater Channel | 42 |
| 8 | 4D-0850 to 4D-0880 | Stormwater Channel | 39 |
| 9 | 4D-0940 to 4D-0970 | Existing Utilities / Roadway | 39 |
| 10 | 4D-0980 to 4D-1010 | Stormwater Channel | 39 |
| 11 | 4D-1080 to 4D-1090 | Existing Utilities / Roadway | 39 |
| 12 | 4E-0010 to 4E-0040 | RIX Treatment Ponds | 36 |
| 13 | 4E-0040 to 4E-0120 | Santa Ana River | 36 |
| 14 | 4E-0130 to 4E-0150 | Santa Ana River | 36 |
| 15 | 4E-0300 to 4E-0330 | Warm Creek | 36 |





Figure 2-8 Brine Line Siphons and Gravity Pressure Flow Pipelines

3 Market Assessment & Future Flow Projections

Section 2 presented the configuration of, and existing dischargers associated with the Brine Line system, as well as some statistical information regarding brine conveyance characteristics. To complete a comprehensive evaluation of the Brine Line system, it is necessary to project both existing and future brine discharges. As shown on **Figure 3-1**, approximately 78 percent of current brine discharges are from potable water production facilities (i.e., groundwater desalters). The next largest category of brine discharger is industrial dischargers (i.e., food processing, laundries) at approximately 11 percent. Desalination of recycled water constitutes an additional 4 percent, with power generation and domestic wastewater constituting an additional 4 percent and 3 percent, respectively. Based on current usage information, potable water and recycled water desalination constitutes approximately 82 percent of the existing Brine Line flows. Incorporating industrial discharges, approximately 93 percent of current brine flow is from these three brine categories. Considering California’s recurring extended drought conditions, it is reasonable to anticipate these brine categories will continue to constitute the majority of future Brine Line flows. Similarly, power generation in California has shifted toward renewable power systems, limiting the development of future brine producing facilities. Domestic discharges are intended to be reduced or eliminated from the Brine Line system.

Figure 3-1 Average Daily Discharge by Type (mgd)



3.1 Brine Line Discharger Workshops

To quantify both existing and future Brine Line discharges, SAWPA conducted a series of discharger workshops with its Member Agencies, their constituent cities and agencies, and other large Brine Line dischargers. These workshops were conducted both virtually and in-person between February 2023 and February 2024. Each workshop was conducted using a common agenda format, focusing on the five discharge categories identified on Figure 3.1 (above). Discussions included a brief history of the Brine Line system, a summary of each discharger’s history, and identification of potential future discharge requirements of each discharger. Initially, workshops were held with the SAWPA Member Agencies, providing each Member Agency the opportunity to establish its near- and long-term planning within its service area. **Table 3-1** provides a summary of the workshop agencies and the date the workshop was held.

The intent of these workshops was to identify the maximum anticipated discharge to the Brine Line system, thereby allowing evaluation of the system’s ability to convey those discharges and potentially identify and evaluate various

brine management methodologies that would be needed to meet the 30-mgd Pipeline Capacity Right for discharges to OC San facilities.

Table 3-1: Discharger Workshops

| Agency | Workshop Date |
|--|-------------------|
| San Bernardino Valley Municipal Water District | February 23, 2023 |
| San Bernardino Municipal Water Department | February 23, 2023 |
| City of Redlands | February 23, 2023 |
| East Valley Water District | February 23, 2023 |
| Eastern Municipal Water District | March 8, 2023 |
| Western Municipal Water District | March 16, 2023 |
| Inland Empire Utilities Agency | March 30, 2023 |
| Chino Basin Desalter Authority | March 19, 2023 |
| Elsinore Valley Municipal Water District | June 12, 2023 |
| Jurupa Community Services District | June 15, 2023 |
| Yucaipa Valley Water District | June 15, 2023 |
| City of Colton | June 21, 2023 |
| Riverside County Flood Control District | June 22, 2023 |
| City of Beaumont | July 13, 2023 |
| City of Chino | August 16, 2023 |
| Temescal Valley Water District | August 17, 2023 |
| City of Riverside | August 17, 2023 |
| Rubidoux Community Services District | August 24, 2023 |
| City of Corona | August 31, 2023 |
| Rancho California Water District | February 28, 2024 |

Unlike typical gravity conveyance systems, capacity rights within the Brine Line system acquired by the Member Agencies are based on a maximum discharge capacity, not on an average discharge capacity. As such, dischargers that experience discharge variations throughout the day cannot exceed their acquired capacity right (no peaking is allowed). The agreement between SAWPA and OC San establishes the 30-mgd capacity right as an absolute discharge maximum between the two systems, and there is no peaking allowance incorporated. Similarly, individual dischargers are allocated a discharge capacity right from Member Agencies without peaking. This maximum discharge capacity will be further discussed in the later discussions. Note: SAWPA’s agreement with OC San is currently slated to expire in 2046. However, based on increased flow, and resulting treatment and disposal requirements, SAWPA may need to initiate discussions with OC San prior to the expiration this agreement.

Based on the results of the workshops, five discharge scenarios were defined to encompass the current and future discharges to be analyzed using the SAWPA hydraulic modeling tool (discussed in Section 5 of this master plan). These five discharge scenarios include:


- Brine Line Ownership Capacity
- Existing Discharges (June 2023)
- Near-Team Discharges (2023-2033, 10-yrs)
- Long-Term Discharges (2034-2048, 25-yrs)
- Build-Out Discharges (beyond 2048)

Discharges discussed in this section are subdivided by SAWPA Member Agency with respect to both pipeline capacity and treatment and disposal capacity. **Appendix A** provides a comprehensive accounting of Brine Line discharges within the above defined discharge scenarios, in one spreadsheet.

3.2 Pipeline, Treatment and Disposal Capacity Rights

Direct and indirect dischargers are dispersed throughout the Brine Line service area, discharging to the various reaches of the system. Each Member Agency is responsible for monitoring, management, and allocation of its capacity right within its defined agency service area. As stated, SAWPA has a contractual capacity right of 30-mgd in the OC San SARI pipeline and 30-mgd in certain wastewater treatment and disposal facilities owned by OC San. However, as shown on **Figure 3-2** below, the Member Agencies have purchased from SAWPA a combined pipeline capacity right of 32.57-mgd, exceeding the contracted pipeline capacity right by 2.57-mgd. The difference between the contracted pipeline capacity right and the allocated pipeline capacity right will be further addressed in Chapter 6 of this master plan. Relative to treatment and disposal capacity right, SAWPA has purchased from OC San 17-mgd of treatment and disposal capacity right and the Member Agencies have purchased from SAWPA a total of 17.0-mgd of treatment and disposal capacity right, which is currently slightly less than the current modeled maximum flow.

Figure 3-2 Pipeline Capacity Rights & Treatment/Disposal Capacity Rights by Member Agency



The Brine Line system is owned by SAWPA, and SAWPA Member Agencies have purchased pipeline capacity rights in the Brine Line system. Capacity rights are allocated by the Member Agencies to those dischargers requiring a capacity right or may be leased to dischargers through the SAWPA capacity leasing program. Member Agencies also own the identified treatment and disposal capacity rights. Treatment and disposal capacity represents a volume and strength of effluent that is treated at the OC San treatment plant at Huntington Beach.

As discussed, the total pipeline capacity right is approximately 32.57-mgd, and the current treatment and disposal capacity right is approximately 17.00-mgd. This difference is not currently a liability for SAWPA or the Brine Line dischargers, as the current average total discharge to OC San facilities is approximately 13.53-mgd. However, as brine flows continue to increase, purchase of additional treatment and disposal capacity will be required. Current discharge projects indicate that maximum flows in the Brine Line system are anticipated to exceed 17.00-mgd and will become critical in the next few years.

Table 3-2 summaries the current discharges from each Member Agency compared to their current pipeline capacity right. Based on current information, all of the Member Agencies have significant remaining pipeline rights for continue increase in Brine Line dischargers. CDA is the only agency that is currently conveying discharges approaching its Pipeline Capacity Right, with approximately 8.7 percent remaining.

Table 3-2: Pipeline Capacity Right Summary

| Brine Line Discharger | Current Average Discharge (gpd) | Pipeline Capacity Right (gpd) | Remaining Capacity Right |
|--|---------------------------------|-------------------------------|--------------------------|
| Western Municipal Water District | 4,607,700 | 11,084,000 | 58.4% |
| Inland Empire Utilities Agency | 483,000 | 4,130,000 | 88.3% |
| Chino Basin Desalter Authority | 3,350,000 | 3,670,000 | 8.7% |
| San Bernardino Valley Municipal Water District | 1,558,000 | 7,738,000 | 79.9% |
| Eastern Municipal Water District | 3,529,600 | 5,946,000 | 40.6% |
| Total Member Agency Discharge (gpd): | 13,528,300 | 32,568,000 | 58.5% |

Table 3-3 summarizes the current discharges from each Member Agency compared to their current treatment and disposal capacity right. Of the Member Agencies, CDA, SBVMWD, and EMWD have used their existing Treatment & Disposal Right. WMWD has a quarter of its right remaining, while IEUA has approximately ¾ of its capacity right remaining. Near-term increases in available Treatment & Disposal Capacity Rights are required.

Table 3-3: Treatment and Disposal Capacity Right Summary

| Brine Line Discharger | Current Average Discharge (gpd) | Treatment & Disposal Capacity Right (gpd) | Remaining Treatment & Disposal Capacity Right |
|--|---------------------------------|---|---|
| Western Municipal Water District | 4,607,700 | 6,213,000 | 25.8% |
| Inland Empire Utilities Agency | 483,000 | 2,250,000 | 78.5% |
| Chino Basin Desalter Authority | 3,350,000 | 3,350,000 | 0.0% |
| San Bernardino Valley Municipal Water District | 1,558,000 | 1,639,000 | 4.9% |
| Eastern Municipal Water District | 3,529,600 | 3,548,000 | 0.5% |
| Total Member Agency Discharge (gpd): | 13,528,300 | 17,000,000 | 20.4% |

Overall, the Brine Line has average discharges of 13.53-mgd (79.6 percent), with existing maximum discharges of up to 17.75-mgd (104.4 percent of total rights). Dischargers to the Brine Line system will be required to reduce or eliminate maximum flows over the near-term, thereby staying within each agencies allocated treatment and disposal capacity limitations. However, treatment and disposal capacity will require monitoring over the next few years, as discharges approach the 17.00-mgd Treatment & Disposal Capacity Right. Some dischargers (i.e., Yucaipa Valley Water District) are currently projecting need to purchase additional Treatment & Disposal Capacity Rights to allow full utilization of their currently owned pipeline capacity.

The following discussion summarize the pipeline, treatment and disposal capacity rights of the five SAWPA Member Agencies and their associated dischargers, including their ownership rights, existing discharges, and projected discharges under the near-term, long-term, and build-out scenarios.

3.2.1 Chino Basin Desalter Authority (CDA) Summary

The Chino Basin Desalter Authority (CDA) contributes brine flows from its two groundwater desalters, including the Chino I and Chino II Desalters. The agency identified no planned expansion of these two facilities. The CDA has a

Brine Line ownership of approximately 3.67-mgd and is currently discharging at approximately that flow rate. Table 3-4 summarizes the CDA Brine Line ownership and allowable discharge. CDA discharges are tributary to Reach IV-D of the Brine Line System.

Table 3-4: CDA Projected Brine Line Discharge

| Brine Line Discharger | Reach | Pipeline Capacity Right (gpd) |
|--|-------|-------------------------------|
| Chino I Desalter | IV-D | 2,370,000 |
| Chino II Desalter (east) [discharged at Etiwanda] | IV-D | 650,000 |
| Chino II Desalter (west) [discharged at Wineville] | IV-D | 650,000 |
| CDA Allocation (gpd): | | 3,670,000 |
| CDA Ownership (gpd): | | 3,670,000 |
| Surplus/(Deficit) (gpd): | | 0 |

Table 3-5 provides a summary of existing average and maximum discharges within the CDA service area. As shown, the CDA service area is making use of almost all its Pipeline Capacity Right.

Table 3-5: CDA Existing Brine Line Discharges

| Existing Brine Line Discharger | Measured Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|--|----------------------------------|-----------------------------------|--|
| Chino I Desalter | 2,651,841 | 2,370,000 | 281,841 |
| Chino II Desalter (east) [discharged at Etiwanda] | 479,400 | 650,000 | 170,600 |
| Chino II Desalter (west) [discharged at Wineville] | 479,400 | 650,000 | 170,600 |
| CDA Discharge (gpd): | 3,610,641 | 3,670,000² | 59,359 |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to 2023 measured maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-6 summarizes projected near-term average and maximum discharges within the CDA service area. While the CDA service area is essentially making use of its entire Brine Line conveyance discharge capacity, the maximum rate from the Chino I Desalter is required to reduce its maximum discharge. The projected discharge exceeds the identified allowable discharge of 2.37-mgd by approximately 0.02-mgd. Treatment and disposal capacity for the IUEA service area is 3.35-mgd. The maximum discharge is within the existing treatment and disposal right for near-term projections.

Table 3-6: CDA Near-Term Brine Line Discharges

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|--|-----------------------------------|-----------------------------------|--|
| Chino I Desalter | 2,391,200 | 2,370,000 | (21,200) |
| Chino II Desalter (east) [discharged at Etiwanda] | 479,400 | 650,000 | 170,600 |
| Chino II Desalter (west) [discharged at Wineville] | 479,400 | 650,000 | 170,600 |
| CDA Discharge (gpd): | 3,350,000 | 3,670,000² | 320,000 |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to projected near-term maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-7 summarizes projected long-term average and maximum discharges within the CDA service area. The CDA is using its entire Brine Line pipeline capacity. The projected discharge matches the identified allowable discharge of 3.67-mgd. The CDA service area is not anticipating increases in Brine Line discharges in the future. It is noted that CDA is projected to meet its maximum allowable discharge during the long-term planning horizon. Treatment and disposal capacity right for CDA service area is 3.35-mgd. Discharges from the CDA service will increase to 3.67-mgd, resulting in a required increase in Treatment & Capacity Right by 0.32-mgd.

Table 3-7: CDA Long-Term Brine Line Discharges

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| Chino I Desalter | 2,370,000 | 2,370,000 | --- |
| Chino II Desalter (east) <i>[discharged at Etiwanda]</i> | 650,000 | 650,000 | --- |
| Chino II Desalter (west) <i>[discharged at Wineville]</i> | 650,000 | 650,000 | --- |
| CDA Discharge (gpd): | 3,670,000 | 3,670,000² | — |

Notes:

¹ Excess capacity is based on comparison of contractual maximum allowable to projected long-term maximum flow discharges.

² Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-8 provides a summary of projected build-out conditions within the CDA service area. The CDA service area shows no differences between the long-term planning horizons. Assuming the Treatment and disposal capacity right for the CDA service area is increased to 3.67-mgd, no additional treatment and disposal capacity right will be required based on build-out planning horizon.

Table 3-8: CDA Build-Out Brine Line Discharges

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| Chino I Desalter | 2,370,000 | 2,370,000 | --- |
| Chino II Desalter (east) <i>[discharged at Etiwanda]</i> | 650,000 | 650,000 | --- |
| Chino II Desalter (west) <i>[discharged at Wineville]</i> | 650,000 | 650,000 | --- |
| CDA Discharge² (gpd): | 3,670,000 | 3,670,000 | — |

Notes:

¹ Excess capacity is based on comparison of contractual maximum allowable to projected build-out maximum flow discharges.

² Summary information based on Member Agency ownership, not on summation of columnar data.

3.2.2 Eastern Municipal Water District (EMWD) Summary

The Eastern Municipal Water District (EMWD) service area is tributary to Reach V of the Brine Line system. EMWD has a pipeline capacity right of approximately 5.95-mgd. Discharges to the Brine Line are associated with the three EMWD groundwater desalters, including the existing Menifee, Perris, and Perris II groundwater desalter facilities. **Table 3-9** summarizes the EMWD service area pipeline capacity discharge conditions.

Table 3-9 summarizes the existing and future dischargers to the Brine Line from the EMWD service area. As with other existing dischargers, it is projected that these dischargers will increase discharge up to their allocated Pipeline Capacity Right. The shaded discharger is projected to be a new discharger added in the future, as defined by the following discussions:

1. Eastern Municipal Water District. EMWD identified a planned 5.4-mgd expansion of its Perris II Desalter that is projected to increase brine discharges by 900,000 gallons. The Project is projected to occur beyond the 10-year horizon. EMWD also identified its Perris North Program, which is intended to be a groundwater

Table 3-9: EMWD Projected Brine Line Discharges

| Brine Line Discharger | Reach | Pipeline Capacity Right (gpd) |
|---|-------|-------------------------------|
| EMWD Perris & Menifee Desalination Facility | V | 3,998,000 |
| Perris II Expansion (Future) | V | 900,000 |
| Rancho California Water District | V | 2,000,000 |
| Collection Station | V | 200,000 |
| EMWD Allocation (gpd): | | 7,098,000 |
| EMWD Ownership (gpd): | | 5,946,000 |
| Surplus/(Deficit) (gpd): | | (1,152,000) |

Note: Shaded information represents identified future dischargers

contamination and remediation project using evaporators to reduce the brine volume by a factor of eight times. The project is proposed to be located within the Moreno Valley area. EMWD is also discussing a potential new location for the PWR Project, located in San Jacinto. Since a connection to the Brine Line is too far, they are looking at 21 acres of evaporation ponds to manage brine. Also, in the Lakeview Nuevo Area, EMWD is conducting hydrogeological evaluations for siting a new desalter, to be online in the 20+ year timeframe. A total of approximately 32,000 gallons per day (gpd) is being hauled to the collection station, which is projected to increase with time.

2. Rancho California Water District. Previous evaluations conducted by the Rancho California Water District (Rancho Water) identified that brine from the Santa Rosa Water Reclamation Plant would be conveyed to the Fallbrook Public Utility District for ultimate discharge through their land outfall to the Oceanside Ocean Outfall. During our recent discussions with Rancho Water, it was identified that the final decision was not made, and that the potential for conveying approximately 2.0-mgd of brine to the Brine Line was still being evaluated. Based on the Rancho Water Workshop, approximately 1.0-mgd of brine is projected to be conveyed to the Brine Line in the near-term period, with another 1.0-mgd potentially discharged through the Build Out Period.

Table 3-10 provides a summary of existing average and maximum discharges within the EMWD service area. As shown, the EMWD service area exceeds the allowable discharge by approximately 0.1-mgd, a condition that is expected to be resolved in the near-term planning horizon.

Table 3-10: EMWD Existing Brine Line Discharges

| Existing Brine Line Discharger | Measured Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|----------------------------------|-----------------------------------|--|
| EMWD Perris & Menifee Desalination Facility | 4,097,866 | 3,998,000 | (99,866) |
| EMWD Discharge² (gpd): | 4,097,866 | 3,998,000 | (99,866) |

Notes:

- 1 Excess capacity is based on comparison of contractual maximum allowable to 2023 measured maximum flow discharges.
- 2 Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-11 summarizes the projected near-term average and maximum discharges within the EMWD service area. As shown, EMWD service area eliminates peaked discharges during the near-term period and adds 50,000 gpd of flow at the collection station, while maintaining an excess Pipeline Capacity Right of approximately 0.90-mgd. The EMWD service area has a total treatment and disposal capacity right of 3.55-mgd. Within the near-term period, the EMWD service area is projected to exceed its treatment/disposal capacity right by approximately 1,500,000 gpd, necessitating that additional treatment and disposal capacity rights be acquired.

Table 3-11: EMWD Near-Term Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| EMWD Perris & Menifee Desalination Facility | 3,998,000 | 3,998,000 | --- |
| Rancho California Water District | 1,000,000 | 1,000,000 | --- |
| Collection Station | 50,000 | 200,000 | 150,000 |
| EMWD Discharge (gpd): | 5,048,000 | 5,946,000² | 898,000 |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to projected near-term maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-12 summarizes projected long-term average and maximum discharges within the EMWD service area. As shown, EMWD service area is projected to add one additional discharge in the long-term period. Maximum discharge is projected to exceed the Pipeline Capacity Right by approximately 0.1-mgd. The EMWD service area has a total treatment and disposal capacity of 3.55-mgd. Within the long-term period, the EMWD service area will exceed its treatment/disposal capacity right by approximately 2.50-mgd, necessitating that approximately 2.5-mgd of additional treatment and disposal capacity right be acquired.

Table 3-12: EMWD Long-Term Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| EMWD Perris & Menifee Desalination Facility | 3,998,000 | 3,998,000 | --- |
| Perris II Future Expansion | 900,000 | 900,000 | --- |
| Rancho California Water District | 1,000,000 | 1,000,000 | 1,000,000 |
| Collection Station | 150,000 | 200,000 | 50,000 |
| EMWD Discharge (gpd): | 6,048,000 | 5,946,000² | (102,000) |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to projected long-term maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-13 provides a summary of build-out conditions within the EMWD service area. As shown, EMWD service area will add the remainder of the RCWD 2.0-mgd discharge, increasing discharge to 7.1-mgd. With a Pipeline Capacity Right of 5.9-mgd, EMWD is projected to exceed its Pipeline Capacity Right by approximately 1.2-mgd. As such, additional capacity right is required.

Table 3-13: EMWD Build-Out Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| EMWD Perris & Menifee Desalination Facility | 3,998,000 | 3,998,000 | --- |

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|--|-----------------------------------|-----------------------------------|--|
| Perris II Future Expansion | 900,000 | 900,000 | -- |
| Rancho California Water District | 2,000,000 | 2,000,000 | -- |
| Collection Station | 200,000 | 200,000 | -- |
| EMWD Discharge² (gpd): | 7,098,000 | 5,946,000 | (1,152,000) |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to projected build-out maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

The EMWD service area has a total treatment and disposal capacity right of 3.55-mgd. Within the long-term period, the EMWD service area will exceed its treatment/disposal capacity by approximately 3.55-mgd, necessitating that approximately 3.55-mgd of additional treatment and disposal capacity right be acquired.

3.2.3 Inland Empire Utilities Agency (IEUA) Summary

The Inland Empire Utilities Agency (IEUA) service area is unique in that IEUA owns and operates its own brine disposal system, referred to as the North Non-Reclaimable Wastewater System (North System), and discharges to the Brine Line through Reaches IV, IV-A, and IV-D. The 13.45-mgd North System consists of the Non-Reclaimable Wastewater System (NRWS) and the 2.7-mgd Etiwanda Wastewater Line (EWL) in the Agency’s north service area, conveying wastewater to the County Sanitation Districts of Los Angeles County’s sewer system. The Brine Line receives discharges from IEUA’s south service area. **Table 3-14** summarizes existing and future discharges with respect to IEUA’s pipeline capacity right.

Table 3-14: IEUA Projected Brine Line Discharges

| Brine Line Discharger | Reach | Pipeline Capacity Right (gpd) |
|--|-------|-------------------------------|
| California Institution for Men | IV-A | 194,000 |
| California Institution for Women | IV-D | 400,000 |
| Green River Golf Club | IV | 7,000 |
| Mission Linen Supply | IV-A | 713,000 |
| In-N-Out Burger, Chino Distribution Center | IV-D | 86,000 |
| OLS Energy | V-A | 130,000 |
| Repet, Inc. | IV-A | 64,800 |
| Chino Eastside WTP | IV-D | 65,500 |
| Collection Station | IV-A | 200,000 |
| IEUA Allocation (gpd): | | 1,860,300 |
| IEUA Ownership (gpd): | | 4,130,000 |
| Surplus/(Deficit) (gpd): | | 2,269,700 |

As shown in the table, IEUA has a total pipeline capacity right of 4.13-mgd. There are nine (9) individual dischargers within the IEUA service area, including the IEUA collection station (located on Reach IV-A near Regional Plant 2). Based on the Discharger Workshops, discharges from the IEUA southern service are projected to be approximately 1.86-mgd, significantly less than the agency’s ownership by approximately 4.13-mgd. Existing discharges total to an average of approximately 0.48-mgd. Discharges from the IEUA service area exhibit significant maximum flows, with the maximum flow at approximately 1.61-mgd (3.33 peaking factor). Operating with this peaking factor is possible as a result of the disparity between the Pipeline Capacity Right and the actual discharged flow. The workshops did not identify projections of large increases in discharge from the IEUA service area.

Table 3-15 provides a summary of current average and maximum discharges within the IEUA service area. As with the WMWD service area, IEUA exhibits a couple of dischargers that currently exceed their allocated capacity, IEUA has a significant amount of excess discharge capacity such that dischargers occasionally exceed their allocations, and the agency has its own brine disposal system, the North System, that limits discharges to the Brine Line system. IEUA is not projecting the potential for new dischargers to the Brine Line system, but as existing dischargers grow, the agency will need to continue to control maximum discharges to assure that their capacity right is not exceeded.

Table 3-15: IEUA Existing Brine Line Discharges

| Existing Brine Line Discharger | Measured Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|--|----------------------------------|-----------------------------------|--|
| California Institution for Men | 152,376 | 194,000 | 41,624 |
| California Institution for Women | 679,528 | 400,000 | (279,528) |
| Green River Golf Club | 4,340 | 7,000 | 2,660 |
| Mission Linen Supply | 360,024 | 713,000 | 352,976 |
| In-N-Out Burger, Chino Distribution Center | 62,582 ³ | 86,000 | 23,418 |
| OLS Energy | 51,996 | 130,000 | 78,004 |
| Repet, Inc. | 61,404 | 43,200 | (18,204) |
| Chino Eastside WTP | 10,000 | 65,500 | 55,500 |
| Collection Station | 224,015 | 250,000 | 25,985 |
| IEUA Discharge (gpd): | 1,606,265 | 4,130,000² | 2,523,735 |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to 2023 measured maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.
- ³ In-n-Out intends to reduce flow to the Brine Line, with current estimates at diverting 31,000 gpd from the Brine Line.

It is noted that IEUA is studying future need for the Collection Station. As IEUA is required to vacate the RP-2 site and return it to the Army Corp of Engineers, evaluations are focused on condition of the collection station, costs and potential locations to relocate the station (Brine Line or North System), or the elimination of the Collection Station based on low use.

Table 3-16 provides a summary of projected near-term average and maximum discharges within the IEUA service area. Similar to the WMWD service area, the IEUA service area had several dischargers currently exceeding their allocated conveyance capacity. It is projected that, within the near-term period (10 years), IEUA dischargers will no longer exceed their conveyance capacities, shown in the table with zero excess capacity (i.e., “--”). The IEUA service area has significant excess capacity of approximately 2.89-mgd, increasing slightly as a result of maximum discharge management. No additional dischargers were identified in the Discharger Workshops for the IEUA service area during the near-term period.

Table 3-16: IEUA Near-Term Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|--|-----------------------------------|-----------------------------------|--|
| California Institution for Men | 152,376 | 194,000 | 41,624 |
| California Institution for Women | 400,000 | 400,000 | -- |
| Green River Golf Club | 4,340 | 7,000 | 2,660 |
| Mission Linen Supply | 360,024 | 713,000 | 352,976 |
| In-N-Out Burger, Chino Distribution Center | 62,582 | 86,000 | 23,418 |
| OLS Energy | 51,996 | 130,000 | 78,004 |

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|--------------------------------|-----------------------------------|-----------------------------------|--|
| Repet, Inc. | 43,200 | 43,200 | --- |
| Chino Eastside WTP | 65,500 | 65,500 | --- |
| Collection Station | 100,000 | 200,000 | 100,000 |
| IEUA Discharge (gpd): | 1,240,018 | 4,130,000² | 2,889,982 |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to projected near-term maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

With respect to treatment and disposal capacity, IEUA has a total capacity of 2.25-mgd. Based on the projected near-term maximum discharges of 1.24-mgd, IEUA is not anticipated to require additional treatment and disposal capacity.

Table 3-17 provides a summary of projected long-term average and maximum discharges within the IEUA service area. It is projected that within the long-term period, IEUA discharges will no longer exceed their pipeline capacities, shown in the table with zero excess capacity (i.e., “—”). The IEUA service area has significant excess capacity of approximately 2.81-mgd. No additional dischargers were identified in the Discharger Workshops for the IEUA service area during the long-term period.

With respect to treatment and disposal capacity, IEUA has a total capacity of 2.25-mgd. Based on the projected long-term discharges of 1.32-mgd, IEUA is not anticipated to require additional treatment and disposal capacity during the long-term period. In the future, IEUA could consider selling excess capacity back to SAWPA.

Table 3-17: IEUA Long-Term Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|--|-----------------------------------|-----------------------------------|--|
| California Institution for Men | 152,376 | 194,000 | 41,624 |
| California Institution for Women | 400,000 | 400,000 | --- |
| Green River Golf Club | 4,340 | 7,000 | 2,660 |
| Mission Linen Supply | 360,024 | 713,000 | 352,976 |
| In-N-Out Burger, Chino Distribution Center | 62,582 | 86,000 | 23,418 |
| OLS Energy | 51,996 | 130,000 | 78,004 |
| Repet, Inc. | 43,200 | 43,200 | --- |
| Chino Eastside WTP | 65,500 | 65,500 | --- |
| Collection Station | 150,000 | 200,000 | 50,000 |
| IEUA Discharge (gpd): | 1,290,018 | 4,130,000² | 2,839,982 |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to projected long-term maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-18 provides a summary of projected build-out conditions within the IEUA service area. No new build-out discharges were identified, and existing discharges maximize use of their allowed pipeline capacity. With respect to treatment and disposal capacity, IEUA has a total capacity of 2.25-mgd. Based on the projected build-out discharges of 1.89-mgd, IEUA is not anticipated to require additional treatment and disposal capacity to meet build-out conditions.

Table 3-18: IEUA Build-Out Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|--|-----------------------------------|-----------------------------------|--|
| California Institution for Men | 194,000 | 194,000 | --- |
| California Institution for Women | 400,000 | 400,000 | --- |
| Green River Golf Club | 7,000 | 7,000 | --- |
| Mission Linen Supply | 713,000 | 713,000 | --- |
| In-N-Out Burger, Chino Distribution Center | 86,000 | 86,000 | --- |
| OLS Energy | 130,000 | 130,000 | --- |
| Repet, Inc. | 43,200 | 43,200 | --- |
| Chino Eastside WTP | 65,500 | 65,500 | --- |
| Collection Station | 200,000 | 200,000 | --- |
| IEUA Discharge² (gpd): | 1,838,700 | 4,130,000 | 2,291,300 |

Notes:

- 1 Excess capacity is based on comparison of contractual maximum allowable to projected build-out maximum flow discharges.
- 2 Summary information based on Member Agency ownership, not on summation of columnar data.

3.2.4 San Bernardino Valley Municipal Water District (SBVMWD) Summary

Table 3-19 summarizes existing and future discharges with respect to San Bernardino Valley Municipal Water District’s (SBVMWD) Brine Line pipeline capacity right. As shown in the table, SBVMWD has a total pipeline capacity right of 7.74-mgd. There are seven (7) existing and future dischargers from the SBVMWD service area, including the collection station (located at the City of San Bernardino WWTP). Based on the information collected during the Discharger Workshops, discharges from the SBVMWD service area are projected to be approximately 4.83-mgd, approximately 2.91-mgd less than the Pipeline Capacity Right. Current discharges total to an average of approximately 1.56-mgd. The significant disparity between pipeline capacity right and the current discharges allow dischargers to exhibit an existing maximum flow of approximately 2.02-mgd (peaking factor of 1.29). Dischargers in the SBVMWD service area are projecting significant growth from the Regional Recycled Water Facilities Project and Yucaipa Valley Water District increased brine flows, both representing increased recycled water demineralization. Dischargers within the SBVMWD service area discharge to Reach IV-E of the Brine Line system.

Table 3-19: SBVMWD Projected Brine Line Discharges

| Brine Line Discharger | Reach | Pipeline Capacity Right (gpd) |
|---|-------|-------------------------------|
| Agua Mansa Power Plant | IV-E | 62,000 |
| Mountainview Generating Station | IV-E | 432,000 |
| Rialto Bioenergy Facility, LLC | IV-E | 250,000 |
| YVWD - Henry Wochholz Regional Water Recycling Facility | IV-E | 1,756,000 |
| Regional Recycled Water Facilities Project | IV-E | 1,550,000 |
| City of Beaumont Wastewater TP | IV-E | 580,000 |
| Collection Station | IV-E | 200,000 |
| SBVMWD Allocation (gpd): | | 4,830,000 |
| SBVMWD Ownership (gpd): | | 7,738,000 |
| Surplus/(Deficit) (gpd): | | 2,908,000 |

Note: Shaded information represents identified future dischargers

Table 3-15 summarizes Brine Line dischargers located within the SBVMWD service area. These dischargers are contributing less than their existing pipeline capacity right. For purposes of the Master Plan, it is assumed the dischargers will over time increase their discharge to their total pipeline capacity right. However, SBVMWD is projected to increase capacity for two existing dischargers, and add one additional discharger (shaded dischargers) as defined in the following discussions:

1. Bunker Hill Regional Recycled Water Feasibility Study. San Bernardino Valley MWD (as lead agency), City of San Bernardino, East Valley WD, and the City of Redlands are participating in the future development of the Bunker Hill Basin Regional RW Feasibility Study as part of the Salinity Management Coalition. (Project). The Project participants are studying a program where each agency will individually construct necessary facilities, and coordinate operations to meet local groundwater basin objectives through an indirect potable reuse project. East Valley constructed the Sterling Natural Resource Center to recycle wastewater from its service area and recharge via Weaver Basins. San Bernardino is developing a Tertiary Treatment System to produce recycled water from the San Bernardino Water Reclamation Plant for general plant use and irrigation. Valley District's recycled conveyance system conveys recycled water for recharge via the Weaver Basins. Redlands has existing Waste Discharge Requirements for treatment and discharge of recycled water from its service area into Bunker Hill-B Groundwater Management Zone. Phase 2 of the Redlands Wastewater Treatment Facility will focus on infrastructure and process upgrades to the existing facility. Recycled water replenishment of the Bunker Hill-B Groundwater Management Zone provides a drought tolerant water supply, improving supply reliability and a drought buffer in the event of a prolonged drought. Projected treatment capacity and recycled water product by agency includes:
 - a. San Bernardino: 21-mgd from its WRP and 33-mgd from RIX, with 3.8-mgd starting in 2027 and another 4.0-mgd starting around 2040 (7.8-mgd total).
 - b. East Valley: Projected treatment capacity of 10.0-mgd, with 8.6-mgd of recycled water production
 - c. Redlands: 6.5-mgd treatment capacity, with 4.5-mgd of recycled water production
2. Yucaipa Vally Water District. Yucaipa Valley Water District (YVWD) constructed its own 15.5-mile Brine Line lateral, extending from the Wochholz Regional Water Recycling Facility (WRWRF), with a treatment capacity of 8.0-mgd (current flow approximately 4.0-mgd), to Reach 4E of the Brine Line (adjacent to San Bernardino WWTP). YVWD has a total pipeline capacity of 1.756-mgd and a total treatment capacity of 0.595-mgd. The District is currently projecting an increase to its WRWRF capacity, resulting in an increase brine flow of approximately 400,000 gpd. Additionally, the District may extend its regional brine line to its existing WTP, thereby allowing additional brine discharge to the Brine Line up to existing pipeline capacity of 1.756-mgd. Plant improvements are planned to be online by December 2026, with proposed WTP connection in the following years. YVWD will require additional Brine Line treatment and disposal capacity rights to support its projected WRWRF expansion plans.
3. City of Beaumont. The City of Beaumont (Beaumont) currently operates a wastewater treatment plant with a permitted capacity of 6.0-mgd. Total Dissolved Solids (TDS) tributary to the Beaumont plant range between 180 to 250 milligrams per liter (mg/l). New membrane systems were installed in November 2022 with a capacity of 220,000 gpd, resulting is a brine flow of approximately 550,000 gpd. Beaumont currently makes use of its full allocated flow capacity. In February 2024, Beaumont identified an additional 30,000 gpd of needed brine capacity, bringing their total brine discharge to 580,000 gpd (0.58-mgd).

Table 3-20 provides a summary of current average and maximum discharges within the SBVMWD service area. The SBVMWD service area also has several dischargers that are currently exceeding their allocated capacity. Similarly,

the significant amount of excess pipeline capacity accommodating maximum flows. However, as dischargers increase and/or are added to the agencies service area, maximum dischargers will be required to not exceed their allotted capacity.

Table 3-20: SBVMWD Existing Brine Line Discharges

| Existing Brine Line Discharger | Measured Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|----------------------------------|-----------------------------------|--|
| Agua Mansa Power Plant | 92,820 | 62,000 | (33,820) |
| Mountainview Generating Station | 478,880 | 432,000 | (46,880) |
| Rialto Bioenergy Facility, LLC | 141,173 | 250,000 | 108,827 |
| YVWD - Henry Wochholz Regional Water Recycling Facility | 463,325 | 1,756,000 | 1,292,675 |
| City of Beaumont Wastewater TP Collection Station | 604,884 | 550,000 | (54,884) |
| | 235,060 | 250,000 | 14,940 |
| SBVMWD Discharge (gpd): | 2,016,142 | 7,738,000² | 5,721,858 |

4. Notes:

- 5. ¹Excess capacity is based on comparison of contractual maximum allowable to 2023 measured maximum flow discharges.
- 6. ²Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-21 provides a summary of projected near-term average and maximum discharges within the SBVMWD service area. The SBVMWD service area has dischargers that are currently exceeding their allotted discharge capacity based on maximum discharge volumes. Similarly, these maximum discharges are mitigated through storage or other means by the discharger to maintain flow within the required limits. The SBVMWD service area discharge is projected to increase significantly during the near-term (10-year) period, particularly associated with increases from Yucaipa Valley Water District and proposed new discharges from the Regional Recycled Water Facilities Project. Despite these increases, the conveyance capacity in the SBVMWD service area exceeds the maximum discharge by approximately 3.04-mgd.

Table 3-21: SBVMWD Near-Term Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| Agua Mansa Power Plant | 62,000 | 62,000 | --- |
| Mountainview Generating Station | 432,000 | 432,000 | --- |
| Rialto Bioenergy Facility, LLC | 230,523 | 250,000 | 19,477 |
| YVWD - Henry Wochholz Regional Water Recycling Facility | 1,756,000 | 1,756,000 | --- |
| City of Beaumont Wastewater TP | 532,000 | 550,000 | 18,000 |
| Regional Recycled Water Facilities Project | 1,550,000 | 1,550,000 | --- |
| Collection Station | 140,000 | 200,000 | 60,000 |
| SBVMWD Discharge (gpd): | 4,702,523 | 7,738,000² | 3,035,477 |

Notes:

- 1 Excess capacity is based on comparison of contractual maximum allowable to projected near-term maximum flow discharges.
- 2 Summary information based on Member Agency ownership, not on summation of columnar data.

The SBVMWD service area maintains a treatment and disposal capacity of 1.64-mgd. As shown in the table, the projected near-term discharges significantly exceed the available treatment/disposal capacity by approximately 3.06-mgd, necessitating an increase of 3.0-mgd in treatment and disposal capacity in the near-term period.

Table 3-22 provides a summary of projected long-term average and maximum discharges within the SBVMWD service area. The SBVMWD service area will mitigate all maximum discharges by the long-term period, with accompanying increases in existing discharger flows. Despite these increases, the pipeline capacity in the SBVMWD service area exceeds the maximum discharge by approximately 2.97-mgd.

The SBVMWD service area maintains a treatment and disposal capacity of 1.64-mgd. Therefore, the projected long-term discharge significantly exceeds the available treatment/disposal capacity by approximately 3.11-mgd, necessitating increase in treatment/disposal capacity of approximately 3.0-mgd in the long-term period.

Table 3-22: SBVMWD Long-Term Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| Agua Mansa Power Plant | 62,000 | 62,000 | --- |
| Mountainview Generating Station | 432,000 | 432,000 | --- |
| Rialto Bioenergy Facility, LLC | 230,523 | 250,000 | 19,477 |
| YVWD - Henry Wochholz Regional Water Recycling Facility | 1,756,000 | 1,756,000 | --- |
| City of Beaumont Wastewater TP | 550,000 | 550,000 | --- |
| Regional Recycled Water Facilities Project | 1,550,000 | 1,550,000 | --- |
| Collection Station | 170,000 | 200,000 | 30,000 |
| SBVMWD Discharge (gpd): | 4,750,523 | 7,738,000² | 2,987,477 |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to projected long-term maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-23 provides a summary of projected build-out conditions within the SBVMWD service area. The SBVMWD service area will mitigate maximum discharges at build-out. No increases in discharge are projected, with build-out conditions the same as the long-term condition. The pipeline capacity in the SBVMWD service area exceeds the maximum discharge by approximately 2.89-mgd.

Table 3-23: SBVMWD Build-Out Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| Agua Mansa Power Plant | 62,000 | 62,000 | --- |
| Mountainview Generating Station | 432,000 | 432,000 | --- |
| Rialto Bioenergy Facility, LLC | 250,000 | 250,000 | --- |
| YVWD - Henry Wochholz Regional Water Recycling Facility | 1,756,000 | 1,756,000 | --- |
| City of Beaumont Wastewater TP | 550,000 | 550,000 | --- |
| Regional Recycled Water Facilities Project | 1,550,000 | 1,550,000 | --- |
| Collection Station | 200,000 | 200,000 | --- |
| SBVMWD Discharge² (gpd): | 4,800,000 | 7,738,000 | 2,938,000 |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to projected build-out maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

The SBVMWD service area maintains a treatment and disposal capacity of 1.64-mgd. As shown in the table, the projected build-out condition significantly exceeds the available treatment/disposal capacity by approximately 3.16-mgd, necessitating increase in treatment/disposal capacity.

3.2.5 Western Municipal Water District (WMWD) Summary

Table 3-24 summarizes existing and future discharges with respect to Western Municipal Water District’s (WMWD) pipeline capacity right. As shown in the table, WMWD has a total pipeline capacity of 11.08-mgd. There are 24 discrete dischargers within the WMWD service area, including the WMWD collection station (located at WWTP No. 1 within the City of Corona). Based on the information collected during the Discharger Workshops, discharges from the WMWD service area are projected to be approximately 16.04-mgd, exceeding the WMWD pipeline capacity right by approximately 4.96-mgd. Existing discharge is approximately 4.61-mgd. Dischargers in the WMWD service area are projecting significant growth, particularly regarding new or expanded groundwater desalter facilities and increase recycled water demineralization for groundwater recharge. It is noted that dischargers within the WMWD service area discharge to Reaches IV-B, IV-D, and V of the Brine Line system.

Table 3-24: WMWD Projected Brine Line Discharges

| Brine Line Discharger | Reach | Pipeline Capacity Right (gpd) |
|---|-------|-------------------------------|
| Anita B. Smith Treatment Facility | IV-D | 30,000 |
| Aramark Uniform & Career Apparel, LLC | IV-D | 330,000 |
| Dart Container Corporation | IV-B | 60,000 |
| Frutarom USA, Inc. | IV-B | 5,000 |
| Pyrite Canyon Treatment Facility (Stringfellow) | IV-D | 259,000 |
| Wellington Foods, Inc. (International Foods) | V | 30,000 |
| JCSD - Etiwanda Metering Station [includes discharges below] | IV-D | 854,500 |
| • <i>Magnolia Foods, LLC [3,560 gpd]</i> | | |
| • <i>Metal Container Corporation [165,000 gpd]</i> | | |
| • <i>Del Real, LLC [190,164 gpd]</i> | | |
| • <i>JCSD Roger D. Teagarden Ion Exchange WTP [225,000 gpd]</i> | | |
| • <i>JSCD Wells 17 & 18 Ion Exchange Treatment Facility [225,000 gpd]</i> | | |
| JCSD - Hamner Metering Station | IV-D | 49,000 |
| Southern California Edison Mira Loma Peaker Plant | IV-D | 2,500 |
| JCSD - Wineville Metering Station | IV-D | 249,000 |
| WMWD Arlington Desalter | IV-B | 1,400,000 |
| Temescal Desalter (City of Corona) | IV-B | 2,150,000 |
| Rubidoux CSD | IV-D | 2,000,000 |
| Riverside County Flood Control and Water Conservation District | IV-D | 2,000,000 |
| Elsinore Valley MWD | V | 1,200,000 |
| Temescal Valley Water District | V | 225,000 |
| JCSD Future Desalter [Future Etiwanda discharge] | IV-D | 4,000,000 |
| Riverside Future Recycled Water Desal | IV-D | 1,000,000 |
| Collection Station (Waste Haulers) | IV-D | 200,000 |
| Western MWD Allocation (gpd): | | 16,044,000 |
| Western MWD Pipeline Capacity(gpd): | | 11,084,000 |
| Surplus/(Deficit) (gpd): | | (4,960,000) |

Note: Shaded information represents identified future dischargers.

⁽⁴⁾ Future and existing pipeline capacity right

As shown in Table 3-2, the WMWD service area has several existing Brine Line dischargers that are assumed to continue to increase discharge to their allocated capacity right. The shaded dischargers are identified future discharges, as discussed in the following discussions:

1. Rubidoux Community Services District. Currently, Rubidoux Community Services District (RCSD or Rubidoux CSD) has no desalter operations and is wholly reliant on local groundwater supply to meet potable water demands of its water customers. Water is produced from six wells with an average TDS concentration of approximately 500 mg/l, ultimately reaching an average discharge TDS concentration of approximately 740 mg/l. District sewage is conveyed to the City of Riverside for treatment and disposal, with a discharge TDS concentration limit of 650 mg/l. As a result, the District will require approximately 2.0-mgd of Brine Line capacity for a proposed 7.0-mgd future desalter facility. RCSD projects the facility to be construction beyond the 10-year planning horizon.
2. Riverside County Flood Control & Water Conservation District. During the agency workshops, Riverside County Flood Control and Water Conservation District (RCFC&WCD) identified their desire to explore diversion to the Brine Line as an option for compliance with the MSAR Bacterial Indicators total maximum daily load (TMDL). The dry weather deadline for that TMDL has passed. Therefore, the agency may enter into TSO territory (i.e., diversions must be completed within <10 years). RCFC&WCD projects that these flows will increase over time, estimated to be up to 2.0-mgd. The first 1.0-mgd is projected within the near-term horizon (<10 years) and the second 1.0-mgd should be added to the long term (25 years). These projected discharges are based information gain during the agency workshops. Projected discharges will be reevaluated on a five-to-ten-year basis, thereby updating, and verifying demand increases over time. The purpose of the Brine Line is to remove salts from the Santa Ana Watershed. MS4 diversions flows with high salinity would be a benefit to the Watershed and support the purpose of the Brine Line. Approval to discharge these flows would be required by both the General Managers of SAWPA and OC San.
3. Elsinore Valley Municipal Water District. Elsinore Valley Municipal Water District (EVMWD) currently has a Brine Line pipeline capacity right of 0.80-mgd. The agency is required to discharge up to 7.5-mgd of tertiary treated effluent to Lake Elsinore. EVMWD is planning implementation of an Indirect Potable Reuse (IPR) project with the remaining effluent, which would increase its brine flow by approximately 0.65-mgd. EVMWD also projects that emerging regulations on groundwater supplies may result in the need for additional demineralization effort for their 5,500 afy of groundwater supplies (up to 0.50-mgd of brine production). EVMWD projects that its brine discharges will double in capacity within the next 25 years. Discharges to the Brine Line are projected to be approximately 1.2-mgd by 2045. This master plan includes 0.65-mgd of discharge outside the 10-year planning period, with the remainder discharged outside the 25-year planning horizon.
4. Temescal Valley Water District. The Temescal Valley Water District (TVWD) has no specific plans in the near future for discharges to the Brine Line. However, based on the potential of IPR/direct potable reuse (DPR) projects in the future, TVWD projected a small discharge to the Brine Line of 225,000 gpd, projecting that to occur well outside the 25-year planning horizon.
5. Jurupa Community Services District. Jurupa Community Services District (JCSD) operates the Chino II Desalter, owned by the Chino Basin Desalter Authority (CDA). JCSD has expressed concern about future regulatory changes and how those might impact discharges to the Brine Line, particularly potential per- and polyfluoroalkyl substances (PFAS) regulations. Based on these regulatory considerations, JCSD identified the potential for a future groundwater desalter outside the 10- to 20-year planning horizon. This future desalter is proposed to be a maximum capacity of 30-mgd. Buildout of JCSD is approximately 40-mgd of demand and expected to occur in approximately 2040. Discharge from this proposed desalter would be at the Etiwanda connection, similar to the existing desalter, at a flow of 4.0-mgd.

- 6. City of Riverside. The City of Riverside (City) projects the need for a future recycled water desalination plant, with a brine production of 1.0-mgd. Discharge would be to Reach IV-D of the Brine Line. The City discussed capacity rights to its existing WWTP. JCSD has 4-mgd, Rubidoux CSD has 3-mgd, Edgemont Community Services District has 0.80-mgd, and High Grove has 0.80-mgd. JCSD is projected to increase its capacity right by 1.0-mgd in 2030. Total flow is approximately 9.0-mgd. The plant also has significant tributary stormwater flows. It was identified that a 7- to 8-mile Brine Line lateral may be required to connect the City to the Brine Line.

Table 3-25 provides a summary of current average and maximum discharges from dischargers within the WMWD service area. As shown, several existing dischargers within the WMWD service area exhibit maximum flow values that exceed the current flow allocation. Discharge agreements restrict discharge, not allowing for flow peaking. However, as shown, the overall ownership capacity within the WMWD service area is sufficient to accommodate these maximum discharges currently.

As future dischargers are connected, the available excess capacity with the WMWD service will be reduced. Under these future conditions, it will become necessary to reduce, and ultimately eliminate, peaking of discharges to the Brine Line system. Individual dischargers will be faced with options including storage of flow to allow for a more consistent discharge profile or potentially reduction in overall discharge to reduce discharge variability. As the Brine Line system approaches capacity, discharge variations from individual discharges may result in violation of the OC San discharge limitations. Monitoring and control of discharge variations will be critical in the future.

Table 3-25: WMWD Existing Brine Line Discharges

| Existing Brine Line Discharger | Measured Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|--|----------------------------------|-----------------------------------|--|
| Anita B. Smith Treatment Facility | 60,000 | 30,000 | (30,000) |
| Aramark Uniform & Career Apparel, LLC | 375,804 | 330,000 | (45,804) |
| Dart Container Corporation | 75,081 | 60,000 | (15,081) |
| Frutarom USA, Inc. | 28,800 | 5,000 | (23,800) |
| Pyrite Canyon Treatment Facility (Stringfellow) | 198,855 | 259,000 | 60,145 |
| Wellington Foods, Inc. (International Foods) | 74,037 | 30,000 | (44,037) |
| JCSD - Etiwanda Metering Station [includes discharges below] | 1,184,680 | 854,500 | (330,180) |
| • Magnolia Foods, LLC | | | |
| • Metal Container Corporation | | | |
| • Del Real, LLC [190,164 gpd] | | | |
| • JCSD Roger D. Teagarden Ion Exchange WTP | | | |
| • JCSD Wells 17 & 18 Ion Exchange Treatment Facility | | | |
| JCSD - Hamner Metering Station | 92,994 | 49,000 | (43,994) |
| JCSD - Wineville Metering Station | 323,926 | 249,000 | (74,926) |
| WMWD Arlington Desalter | 1,275,608 | 1,400,000 | 124,392 |
| Temescal Desalter (City of Corona) | 2,159,801 | 2,150,000 | (9,801) |
| Collection Station (Waste Haulers) | 566,497 | 250,000 | (316,497) |
| Western MWD Discharge (gpd): | 6,416,083 | 11,084,000² | 4,677,917 |

Notes:

¹ Excess capacity is based on comparison of contractual maximum allowable to 2023 measured maximum flow discharges.

² Summary information based on Member Agency ownership, not on summation of columnar data.

Table 3-26 provides a summary of projected near-term average and maximum discharges from dischargers within the WMWD service area. New dischargers are shown in yellow, including Rubidoux CSD and Elsinore Valley MWD,

totaling an additional 1,650,000 gpd of additional flow. However, Rubidoux CSD will discharge to Reach IV-D and Elsinore Valley CSD will discharge to Reach V. Western MWD conveyance capacity ownership (11.08-mgd) continues to exceed the projected discharge volumes, so additional conveyance capacity is not anticipated during the near-term period.

As shown in the table, it is anticipated several existing dischargers will begin to control maximum discharges during the near-term period, identified by the lack of excess capacity (i.e., “---”). Dischargers with positive excess capacity values are projected to increase flows in the future, while dischargers with negative excess capacity values continue to exceed their conveyance capacity allocation (a condition that is controlled in the future analyses). Western MWD maintains an excess conveyance capacity of 3.90-mgd throughout the near-term period.

Table 3-26: WMWD Near-Term Brine Line Dischargers

| Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| Anita B. Smith Treatment Facility | 30,000 | 30,000 | --- |
| Aramark Uniform & Career Apparel, LLC | 330,000 | 330,000 | --- |
| Dart Container Corporation | 60,000 | 60,000 | --- |
| Frutarom USA, Inc. | 28,800 | 5,000 | (23,800) |
| Pyrite Canyon Treatment Facility (Stringfellow) | 198,855 | 259,000 | 60,145 |
| Wellington Foods, Inc. (International Foods) | 30,000 | 30,000 | --- |
| JCSD - Etiwanda Metering Station [includes discharges below] | 1,184,680 | 854,500 | (330,180) |
| • <i>Magnolia Foods, LLC</i> | | | |
| • <i>Metal Container Corporation</i> | | | |
| • <i>Del Real, LLC [190,164 gpd]</i> | | | |
| • <i>JCSD Roger D. Teagarden Ion Exchange WTP</i> | | | |
| • <i>JCSD Wells 17 & 18 Ion Exchange Treatment Facility</i> | | | |
| JCSD - Hamner Metering Station | 92,994 | 49,000 | (43,994) |
| JCSD - Wineville Metering Station | 323,926 | 249,000 | (74,926) |
| WMWD Arlington Desalter | 1,268,000 | 1,400,000 | 132,000 |
| Riverside County Flood Control | 1,000,000 | 2,000,000 | 1,000,000 |
| Temescal Desalter (City of Corona) | 1,883,000 | 2,150,000 | 267,000 |
| Rubidoux CSD | 1,000,000 | 2,000,000 | 1,000,000 |
| Elsinore Valley MWD | 650,000 | 1,200,000 | 550,000 |
| Collection Station (Waste Haulers) | 100,000 | 200,000 | 100,000 |
| Western MWD Discharge (gpd): | 7,182,755 | 11,084,000² | 3,901,245 |

Notes:

- ¹ Excess capacity is based on comparison of contractual maximum allowable to projected near-term maximum flow discharges.
- ² Summary information based on Member Agency ownership, not on summation of columnar data.

Riverside County Flood Control and Water Conservation District (RCFCWCD) operates many flood control facilities, including dams, flood basins, levees, open channels, and major underground storm drains. During drought and non-rainy seasons, the majority of water collected by RCFCWCD facilities is considered non-reclaimable flows, or “urban drool.” The RCFCWCD discussed the potential for collecting and diverting these flows to the Brine Line at various location throughout the RCFCWCD service area. It is currently estimated that approximately 2.0-mgd of non-reclaimable water could be discharged to the Brine Line. At present, this project is in the conceptual phase, with additional discussion and planning to be completed between WMWD, SAWPA and the RCFCWCD. Discharges are planned to be tributary to Reaches 4D and 4E of the Brine Line system. It is projected that the project could be

operational within the near-term planning horizon, contributing 1.0-mgd to the Brine Line. The remaining 1.0-mgd is projected through the long-term planning horizon.

With regard to treatment and disposal, Western MWD has a total of 6.21-mgd of capacity. Therefore, based on the maximum discharge condition, there is a deficiency of 0.97-mgd (increase of approximately 0.20-mgd beyond the existing conditions). Therefore, it is anticipated the Western MWD would be required to purchase additional treatment and disposal capacity within the near-term period to accommodate its existing and new dischargers. As treatment and disposal capacity is required to be purchased in 1.0-mgd increments, Western MWD would be required to purchase 1.0-mgd of capacity within the near-term period to cover excess discharges of 0.97-mgd.

Table 3-27 provides a summary of projected long-term average and maximum discharges from dischargers within the WMWD service area. New dischargers are highlighted including future discharges from the Riverside County Flood Control, Temescal Valley Water District, Jurupa Community Services District, and the City of Riverside. Furthermore, remaining maximum discharges are minimized to the extent possible. It is noted that discharge from the WMWD service area is projected to more than double within the long-term period, resulting in exceeding the existing pipeline capacity by approximately 2.53-mgd, requiring purchase of additional pipeline capacity.

Table 3-27: WMWD Long-Term Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| Anita B. Smith Treatment Facility | 30,000 | 30,000 | --- |
| Aramark Uniform & Career Apparel, LLC | 330,000 | 330,000 | --- |
| Dart Container Corporation | 60,000 | 60,000 | --- |
| Frutarom USA, Inc. | 5,000 | 5,000 | --- |
| Pyrite Canyon Treatment Facility (Stringfellow) | 259,000 | 259,000 | --- |
| Wellington Foods, Inc. (International Foods) | 30,000 | 30,000 | --- |
| JCSD - Etiwanda Metering Station [includes discharges below] | 854,500 | 854,500 | --- |
| • <i>Magnolia Foods, LLC</i> | | | |
| • <i>Metal Container Corporation</i> | | | |
| • <i>Del Real, LLC [190,164 gpd]</i> | | | |
| • <i>JCSD Roger D. Teagarden Ion Exchange WTP</i> | | | |
| • <i>JCSD Wells 17 & 18 Ion Exchange Treatment Facility</i> | | | |
| JCSD - Hamner Metering Station | 49,000 | 49,000 | --- |
| JCSD - Wineville Metering Station | 249,000 | 249,000 | --- |
| WMWD Arlington Desalter | 1,400,000 | 1,400,000 | --- |
| Temescal Desalter (City of Corona) | 2,150,000 | 2,150,000 | --- |
| Rubidoux CSD | 2,000,000 | 2,000,000 | --- |
| Riverside County Flood Control | 2,000,000 | 2,000,000 | --- |
| Elsinore Valley MWD | 800,000 | 1,200,000 | 400,000 |
| Temescal Valley Water District | 225,000 | 225,000 | --- |
| JCSD Future Desalter (future Etiwanda discharge) | 3,000,000 | 4,000,000 | 1,000,000 |
| Riverside Future Recycled Water Desalination | 1,000,000 | 1,000,000 | --- |
| Collection Station (Waste Haulers) | 150,000 | 200,000 | 50,000 |
| Western MWD Discharge (gpd): | 13,594,000 | 11,084,000² | (2,510,000) |

Notes:

- Excess capacity is based on comparison of contractual maximum allowable to projected long-term maximum flow discharges.
- Summary information based on Member Agency ownership, not on summation of columnar data.

The WMWD service area has a total of 6.21-mgd of treatment and disposal capacity. Therefore, based on the maximum discharge condition, there is a deficient of 7.40-mgd in the long-term period. It is anticipated the WMWD would be required to purchase a total of approximately 8.0-mgd of additional treatment and disposal capacity within the long-term period to accommodate its total existing, near-term, and long-term dischargers.

Table 3-28 provides a summary of projected build-out conditions within the WMWD service area. New dischargers are highlighted. Remaining maximum discharges are minimized where possible. It is noted that discharge from the WMWD service area is projected to increase by approximately 2.5-mgd at build-out, resulting in exceeding the existing conveyance capacity by approximately 5.0-mgd, requiring purchase of additional pipeline capacity (cumulative among the various evaluation periods).

Table 3-28: WMWD Build-Out Brine Line Dischargers

| Existing Brine Line Discharger | Projected Maximum Discharge (gpd) | Maximum Allowable Discharge (gpd) | Excess Discharge Capacity ¹ (gpd) |
|---|-----------------------------------|-----------------------------------|--|
| Anita B. Smith Treatment Facility | 30,000 | 30,000 | --- |
| Aramark Uniform & Career Apparel, LLC | 330,000 | 330,000 | --- |
| Dart Container Corporation | 60,000 | 60,000 | --- |
| Frutarom USA, Inc. | 5,000 | 5,000 | --- |
| Pyrite Canyon Treatment Facility (Stringfellow) | 259,000 | 259,000 | --- |
| Wellington Foods, Inc. (International Foods) | 30,000 | 30,000 | --- |
| JCSD - Etiwanda Metering Station [includes discharges below] | 854,500 | 854,500 | --- |
| • <i>Magnolia Foods, LLC</i> | | | |
| • <i>Metal Container Corporation</i> | | | |
| • <i>Del Real, LLC [190,164 gpd]</i> | | | |
| • <i>JCSD Roger D. Teagarden Ion Exchange WTP</i> | | | |
| • <i>JCSD Wells 17 & 18 Ion Exchange Treatment Facility</i> | | | |
| JCSD - Hamner Metering Station | 49,000 | 49,000 | --- |
| SCE Mira Loma Peaker Power Plant | 2,500 | 2,500 | --- |
| JCSD - Wineville Metering Station | 249,000 | 249,000 | --- |
| WMWD Arlington Desalter | 1,400,000 | 1,400,000 | --- |
| Temescal Desalter (City of Corona) | 2,150,000 | 2,150,000 | --- |
| Rubidoux CSD | 2,000,000 | 2,000,000 | --- |
| Riverside County Flood Control | 2,000,000 | 2,000,000 | --- |
| Elsinore Valley MWD | 1,200,000 | 1,200,000 | --- |
| Temescal Valley Water District | 225,000 | 225,000 | --- |
| JCSD Future Desalter (future Etiwanda discharge) | 4,000,000 | 4,000,000 | --- |
| Riverside Future Recycled Water Desalination | 1,000,000 | 1,000,000 | --- |
| Collection Station (Waste Haulers) | 200,000 | 200,000 | --- |
| Western MWD Discharge (gpd): | 16,094,000 | 11,084,000² | (4,960,000) |

Notes:

¹ Excess capacity is based on comparison of contractual maximum allowable to projected build-out maximum flow discharges.

² Summary information based on Member Agency ownership, not on summation of columnar data.

The WMWD service area has a total of 6.23-mgd of treatment and disposal capacity. Therefore, based on the maximum discharge condition, there is a deficiency of approximately 9.86-mgd through build-out. It is anticipated the WMWD would be required to purchase this additional treatment and disposal capacity or define methods of managing brine production to decrease discharges.

3.3 Projected Brine Line Flow Summary


Table 3-29 summarizes the projected maximum discharge from the Member Agency service areas, as derived from the Discharger Workshops. Figure 3.3 illustrates the information provided in the table. As shown, discharges to the OC San system are projected to increase with time, with a projected maximum discharge of approximately 33.5-mgd. As the contracted limit between SAWPA and OC San is 30.0-mgd, brine management measures will be required to assure that the contracted limit is not exceeded. It is noted, however, that Brine Line system discharges are not projected to exceed the contract limit until approximately 2065, based on current projection by the various member agencies and other dischargers.

Figure 3-3 illustrates the projected growth in Brine Line discharges over time. As the current maximum discharge from the Brine Line is modeled to be approximately 17.7-mgd, SAWPA is projected to require additional treatment and disposal capacity. As shown on the figure, based on current projections, SAWPA will require additional treatment and disposal increases in 2026, 2034, 2042, and 2051 to stay ahead of the projected discharge increases. It is projected that brine minimization will be required beyond 2065 to maintain discharges below the 30.0-mgd limitation.

Table 3-29: Brine Line Discharge Summary

| Year | Maximum Discharge (mgd) |
|-----------|-------------------------|
| 2023 | 17.7 |
| 2024-2033 | 21.5 |
| 2034-2058 | 29.4 |
| Build-Out | 33.5 |

Figure 3-3 Brine Line Discharge to OC San System over Time



4 Hydraulic Model Update & Calibration

A hydraulic model is the primary tool for evaluating existing and anticipated future capacity of a collection system. The following section details the flow monitoring performed on the Brine Line system, the updates made on the existing InfoSWMM hydraulic model, and the model calibration performed to prepare the Authority's Brine Line hydraulic model for the capacity analysis component of this Study. Note: the InfoSWMM software is being phased out by AutoDesk; therefore, SAWPA should consider conversion of this software to a more current hydraulic modeling package such as Aquanuity's AquaTwin Sewer.

4.1 Flow Monitoring

In-line flow monitoring generally provides a current and accurate assessment of the capacity usage within a conveyance system. As part of the Brine Line hydraulic model update, flow monitoring was performed throughout the Brine Line system to evaluate system capacity and to calibrate the existing InfoSWMM hydraulic model. The following sections provide detail on the Brine Line flow monitoring locations and model calibration results.

4.1.1 Brine Line Calibration Reaches

To evaluate the overall system capacity and performance, the existing Brine Line system was subdivided into smaller calibration reaches. Those reaches were then used in conjunction with extended-period flow monitoring to provide field data for hydraulic model validation and calibration.

To accurately quantify tributary Brine Line flows from each reach, a clear understanding of how water moves into and out of each calibration reach was mapped. **Figure 4-1** illustrates each of the Brine Line calibration reaches, highlighting the locations where flow monitors (FM) were installed. **Table 4-1** presents a tabular report for the six flow monitoring locations.

Table 4-1: Flow Monitoring Locations

| Flow Meter | MAS ID | Reach | Diameter (in) | Location Description |
|------------|---------|-------|---------------|---|
| FM 01 | 4A-0220 | IV-A | 27 | Pomona Rincon Rd NW of Euclid Ave |
| FM 02 | 4B-0100 | IV-B | 30 | Butterfield Drive west of Clearwater Dr |
| FM 03 | 4D-0110 | IV-D | 42 | Euclid Ave south of Pine Ave |
| FM 04 | 4D-0670 | IV-D | 42 | Bellgrave Ave NE of Wineville Ave |
| FM 05 | 4D-1220 | IV-D | 39 | Canal St NE of Mission Blvd |
| FM 06 | 4D-0280 | IV-E | 36 | Santa Ana River (dry portion) east of Mt Vernon Ave |




Figure 4-1 2023 Brine Line Flow Monitor Locations


4.1.2 Flow Monitoring Program

Flow monitoring was performed by ADS Environmental Services at six (6) selected locations between the dates of June 1 and June 15, 2023. Flow data was collected at 5-minute intervals throughout the monitoring period. The flow monitoring equipment stored raw data, including ultrasonic depth, maximum velocity, and pressure depths. The continuity equation ($Q = V \times A$) was used to convert depth and velocity data to flow. The flow monitoring equipment incorporates area-velocity measurement devices, such as the Doppler sensors, with an identified accuracy of $\pm 10\%$.

4.1.3 Brine Flow Patterns

Flow monitoring data was used to develop basin-specific flow patterns for model validation and calibration. Based on review of the flow monitoring data, it was determined that flows were highest at the SARI Metering Station (SMS) from June 7 through June 9, 2023. Therefore, that same 72-hour period was used for each of the monitoring locations to establish a conservative estimate of the basin’s flow patterns. Concurrent flow data from each Brine Line discharger was collected and used to coincide with this same 72-hour monitoring period, further discussed in Section 4.2.2. **Figure 4-2** presents the 6 72-hour flow patterns developed for each monitoring location and used for calibration of the Brine Line model.

Figure 4-2 72-Hour Brine Line Flow Patterns for Model Calibration



4.2 Hydraulic Model Update & Calibration

The primary tool for the hydraulic capacity analysis is the Brine Line hydraulic model, simulating flow scenarios, such as wastewater depth, flow rate, and velocity within the Brine Line system. As part of this master plan, SAWPA's existing Brine Line InfoSWMM hydraulic model was updated, calibrated, and used to evaluate system capacity. The following discussions outline the model update and calibration process implemented.

4.2.1 Model Updates

Updates were incorporated into the hydraulic model based on available system improvement plans, including the recently constructed City of Beaumont lateral. The following specific updates were incorporated into the hydraulic model:

- Reach V Rehabilitation & Improvement Project, 2014
- Reach V Rehabilitation & Improvement Project, Phase 2, 2017
- Brine Disposal Pipeline Project Reach 1 (City of Beaumont Lateral), 2018
- Brine Disposal Pipeline Project Reach 2 (City of Beaumont Lateral), 2018

4.2.2 Discharger Flows

Flow data was collected for each discharger coinciding with the Brine Line flow monitoring period of June 1 through June 15, 2023. Each discharger's flow was incorporated into the model at the specific discharge location on the Brine Line, including the average flow associated with the 2-week monitoring period. The same 72-hour period (June 7 through June 9, 2023), previously used to develop flow patterns for the 6 flow monitoring locations, were used to develop unique flow patterns for each discharger. In this manner, there is consistency between the flow monitoring and discharge data for the calibration process.

4.2.3 Model Calibration

Average discharger flow and 72-hour flow patterns were incorporated into the hydraulic model, and extended period simulations were executed over a 7-day modeling analysis period. Flow values and patterns at each of the 6 flow monitoring locations were compared to the modeling analysis results. Model calibration is achieved by observing average flow values at the six (6) monitoring locations and adjusting the 72-hour flow patterns, as necessary, to achieve a consistent result between the average and maximum flow values and patterns between the model and the flow monitoring results. The hydraulic model is deemed to be "calibrated" when both average and maximum model predictions reflected field measurements within 10% or less. The following **Table 4-2** summarizes the results of the calibration process for each calibration reach.

Table 4-2: Brine Line Model Calibration Results

| Flow Meter | Calibration Results | | | | | |
|--------------------|---------------------|---------------|--------------|----------------|---------------|--------------|
| | Average Flows | | | Maximum Flows | | |
| | Measured (mgd) | Modeled (mgd) | % Difference | Measured (mgd) | Modeled (mgd) | % Difference |
| SMS | 13.34 | 13.53 | 1.4 | 14.02 | 14.99 | 6.9 |
| FM 01 | 0.31 | 0.30 | 3.9 | 0.53 | 0.56 | 6.8 |
| FM 02 ¹ | 8.53 | 6.77 | 20.6 | 9.17 | 7.35 | 19.9 |
| FM 03 | 6.87 | 6.48 | 5.8 | 7.74 | 7.54 | 2.5 |
| FM 04 | 3.98 | 3.71 | 6.9 | 4.76 | 4.54 | 4.6 |
| FM 05 ² | 2.13 | 1.75 | 17.5 | 2.41 | 2.08 | 13.4 |
| FM 06 | 1.40 | 1.46 | 3.9 | 1.60 | 1.70 | 6.5 |

Notes:

- ¹ The sum of the averages of FM 01, 02 and 03 should be approximately equal to the average flow at the SMS. The sum of the measured averages equal 15.7-mgd, while the sum of the modeled averages equal 13.5-mgd. Therefore, it was determined that the flow meter at FM 02 was measuring inaccurately.
- ² The calibration of FM 05 was reviewed and determined that FM 05 was also measuring inaccurately. Both the upstream (FM 06) and downstream (FM 04) flow data calibrated well.

It is noted that two of the six flow monitoring locations (FM 02 and FM 05) did not calibrate within the desired 10% accuracy. Both monitoring locations were subsequently investigated to determine the source of possible discrepancies. For FM 02, the sum of FM 01, FM 02 and FM 03 would be expected to equal the SMS flow measurement. The sum of these model-predicted flow values coincided with the SMS, while the sum for the flow monitored values reflects values that are approximately 2.0-mgd higher than would be expected. Dudek requested the flow monitoring subconsultant, ADS, to review the data for FM 02. The flow monitoring data analysis indicated a potential weir-like affect occurring downstream of the flow monitoring equipment, resulting in the calculated measurements being up to approximately 15% high. Reducing the measured value by 15% would result in the modeled and measured values for FM 02 being within the 10% accuracy threshold. As a result, FM 02 was not used in calibration of the hydraulic model.

ADS also evaluated the data for the FM 05 monitoring location. As the equipment operates on a depth to velocity relationship, the raw data did not show a specific issue with the hydraulic factors. However, should the Doppler sensors be biased, they tend to be biased to the high side of the scale. As a sensitivity analysis, reducing FM 05 measurements by 10%, to an average flow value of 1.92-mgd, results in the modeled and measured values falling within the 10% accuracy. As a result, monitoring location FM 05 was also not used in calibration of the hydraulic model.

Finally, it is noted that flow within the Brine Line is based on the individual discharger flows, which are not consistently repeatable as would typically be found in a sewer collection system. Discharger flows vary over a relatively large range based on the ongoing operations of the discharging entity. For example, desalters typically have multiple treatment trains within their process. These treatment trains may be impacted by a variety of operational, maintenance or other challenges, which may result in increases and decreases in actual brine discharge to the Brine Line system. Other dischargers may be impacted by similar operational or maintenance activities, resulting in similar flow fluctuations. The modeling analysis uses flow variation patterns to replicate actual flow variations but cannot exactly match the discharger flow variations at all times. This discrepancy exhibits itself by variation between the predicted and measured flow at the flow monitoring locations.

Furthermore, the calibration effort collected data from the dischargers to coincide with the Brine Line flow monitoring dates. The actual discharges have travel time and dampening effects that occur as the flows traverse the Brine Line system. As a result, comparison of the flow monitoring results with modeling predictions is displaced in time and do not exactly reflect the discharge conditions. As a result, for calibration, matching exact patterns was not the intention, rather matching average and maximum flow values is the goal. In this manner, the critical flow conditions (maximum and average) are reflected in the hydraulic model, allowing an accurate analysis of the hydraulic capabilities of the Brine Line system. The 10% accuracy allowance is a method of accounting for these variabilities within the analysis itself. **Figures 4-3 through 4-9** provide the calibration curves for each of the flow monitoring locations.

Figure 4-3 presents the calibration curves for the SMS at the most downstream reach of the Brine Line. These curves track well, with the modeled maximum slightly more conservative than the measured maximum, which is preferred for capacity analysis.

Figure 4-3 SARI Metering Station (SMS) Calibration Curve




Figure 4-4 presents the curves for FM 01 at the base of Reach IV-A, which serves very few customers and has limited flow. Again, these curves track well with the modeled maximum slightly more conservative than the measured maximum indicating the discharger diurnal patterns entered into the model are resulting in accurately modeled flow conditions in Reach IV-A.

Figure 4-4 FM 01 Calibration Curve




Figure 4-5 presents the curves for FM 02, which demonstrate the significant difference between the modeled and measured flows at the downstream end of Reach IV-B. As previously stated, a statistical analysis performed on the flow metering data points indicated a potential weir-like effect that could result in the flows measuring up to 15% high. Average flows were off by approximately 20% at this location. The similarity of the patterns of the two curves, however, indicates the diurnal patterns used for the dischargers upstream are resulting in downstream modeled flow variability that match measured conditions.

Figure 4-5 FM 02 Calibration Curve




Figure 4-6 presents the calibration curves for FM 03, which is measuring flows in Reach IV-D, just upstream of the confluence with Reach IV-A. At this location, average and maximum flows calibrated within 6% and 2.5% respectively. The pattern of the curves indicates relatively accurate correlation of flow conditions in the Brine Line between the modeled and measured values.

The calibration curves for FM 04, as shown in Figure 4-7, located upstream of FM 03, indicate a minor time offset of the flows but patterns that correlate in overall flow variability, with a consistent daily maximum.

Figure 4-6 FM 03 Calibration Curve




Figure 4-7 FM 04 Calibration Curve




Figure 4-8 presents the curves for FM 05. As stated previously, the measured data for FM 05 was not used due to FM 04 and FM 06, located downstream and upstream of FM 05, respectively, calibrating well and the ADS review conceding that the flow meters, if biased, are typically biased high. The patterns, while again indicating a time offset, show a relatively consistent diurnal pattern between modeled and measured conditions.

Figure 4-8 FM 05 Calibration Curve





Figure 4-9 presents the curves for FM 06, at the upstream end of Reach IV-E, downstream of the Yucaipa and Beaumont laterals. The average and maximum flows calibrated within 4 and 6.5% respectively, with the modeled maximum slightly more conservative than the measured maximum. The patterns show consistent shape indicating the flow variability in the discharger diurnal patterns entered in the model are consistent with measured conditions.

Figure 4-9 FM 06 Calibration Curve



INTENTIONALLY LEFT BLANK

5 Brine Line System Capacity Analysis

The following section summarizes the results of the Brine Line capacity analyses under Existing, Near-Term, Long-Term, Buildout, and Ownership discharge scenarios, as well as an overall reach-by-reach analysis. The Brine Line hydraulic model, updated and calibrated as discussed in Section 4, was used to analyze each defined discharge scenario. The model results were compared to design criteria, developed with concurrence from SAWPA staff, to identify potential Brine Line deficiencies under the various discharge conditions.

5.1 Brine Line Design Criteria

Brine Line capacity, under existing and future discharge conditions, was evaluated using the design criteria presented in **Table 5-1**. These criteria also serve as the basis for introduction of new or improved facilities intended to extend existing Brine Line service or accommodate increased discharge through the system across the various planning horizons. These design criteria were developed after consultation with SAWPA staff and industry standards for gravity and pressurized pipelines.

Table 5-1: Brine Line Design Criteria for Capacity Evaluation

| | | |
|--------------------------------|--|--------------------|
| Gravity Pipeline Parameter | Minimum Velocity during Maximum Discharge | 2.0 fps |
| | Manning’s Roughness Coefficient | 0.013 ¹ |
| | Maximum Depth-over-Diameter during Maximum Discharge | 0.75 |
| Pressurized Pipeline Parameter | Maximum Pressure – Reach V | 80 psi |
| | Maximum Pressure – Top of Reach IV-E | 55 psi |

Notes:

¹ Unless material and/or age are otherwise specified. See Table 5.2 for other roughness coefficients used in Brine Line model when pipeline material was defined.

Typical criteria used for capacity evaluation of gravity (i.e., open channel flow) pipelines include the maximum depth-over-diameter ratio (d/D) and minimum flow velocity. Using Manning’s equation, the flow within each segment of gravity pipeline is defined as a function of the depth of flow and pipeline diameter (i.e., d/D). Gravity pipelines are not designed to flow at full capacity (i.e., maximum d/D of 1.0), as the headspace in the pipeline accommodates potential inflow and infiltration (I&I) during wet weather events. For typical wastewater collection systems, gravity pipelines flowing at or near full capacity can increase the incidence of sanitary sewer spills at manholes and other open surface locations throughout the system.

Maintenance access structures (MASs) throughout the Brine Line system are sealed in portions of the Brine Line, including within the Prado Inundation Area and the gravity pressure lines. These sealed MAS can accommodate increased flows under potential pressure flow conditions (i.e., siphons). Nevertheless, this Master Plan evaluates gravity flow pipelines to maintain a maximum d/D of 0.75, or 75% full flow, during maximum discharge conditions. The Brine Line system can maintain pipeline capacity beyond a d/D of 0.75, and the following analyses consider this ability when identifying potential system deficiencies.

Under maximum discharge conditions, gravity pipelines should attain a minimum velocity of at least 2.0 fps to achieve desired “self-cleaning” properties, thereby minimizing solids settlement and eventual deposition. Velocities greater than 8.0 fps should be avoided over an extended period to prevent scouring and damage to the interior

walls of pipelines. Design criteria for pressurized pipelines, which always flow full, typically do not specify a minimum velocity. However, maximum velocities in pressurized pipelines should remain below 10.0 fps, with 8.0 fps desired.

The Manning’s roughness coefficient (“n” value) of a pipeline varies with material and age. The Brine Line model contains pipelines with Manning’s roughness coefficients ranging from 0.009 to 0.018, with 0.013 predominant. **Table 5-2** summarizes the typical Manning’s coefficients assigned to pipelines in the model based on material type.

Table 5-2: Brine Line Model Manning’s Roughness Coefficients (“n”)

| Pipeline Material | Minimum “n” | Maximum “n” | Model “n” |
|-------------------------------|-------------|-------------|--------------------|
| HDPE, PVC, or CIPP-Lined | 0.009 | 0.011 | 0.010 |
| RCP | 0.011 | 0.015 | 0.013 ¹ |
| VCP | 0.013 | 0.015 | 0.013 |
| FRP (Slip-lined) ² | 0.009 | 0.0105 | 0.010 |

Notes:

- ¹ The majority of RCP pipe in the Brine Line model has an “n” value of 0.013. A portion of Reach IV-B, from MAS 4B-0170 to MAS 4B-0010 (approximately 3.1 miles), was assigned an “n” value of 0.009 corresponding to the FRP material.
- ² FRP slip-lined pipe extends from MAS 4A-0150 to MAS 4A-0010.

Consistent with industry standards, a roughness coefficient of 0.013 represents a conservative estimate of the average roughness of a typical gravity pipeline over its useful lifespan. A roughness coefficient of 0.013 was used for pipelines where age and/or material information was unknown.

Reach V and a portion of Reach IV-E, near the Colton Wastewater Treatment Plant, were designed to convey flow under gravity pressure conditions, effectively serving as an extended siphon. The maximum allowable pressure for these extended pressurized sections of the Brine Line is based on pipeline class, as identified on the record drawings.

5.2 Brine Line Evaluation Criteria

As stated in Section 5.1, the d/D design criterion for gravity flow pipelines accounts for the headspace above the flow line, in consideration of I&I during wet weather events. Unlike typical municipal wastewater collection systems, the Brine Line does not exhibit significant flow variations during wet weather events. Furthermore, the Brine Line does not follow a typical municipal layout, minimizing the likelihood of illicit storm drain connections.

Separate evaluation criteria are used to determine permissible flow levels or remaining available capacity under maximum flow conditions. Such evaluation criteria are referred to as “trigger” criteria. Based on discussions with SAWPA staff and criteria established by other agencies, gravity flow pipelines are permitted to flow up to 75% full at maximum discharge before improvement projects will be considered. Meanwhile, pressurized pipelines can experience maximum pressures up to those listed in Table 5-1, prior to triggering potential improvements.

5.3 Brine Line Capacity Analysis Results

The following discussions present the Brine Line capacity analysis results for the Existing, future (including Near-Term, Long-Term, and Buildout), and Ownership discharge scenarios. Each scenario was developed using information collected during the Discharge Workshops, as summarized in Section 3.

In addition, Brine Line capacity was analyzed on a Reach-by-Reach basis to establish the maximum allowable flow within each defined Reach, after which improvement projects may be required. The capacity of privately-owned laterals is not evaluated. However, the maximum d/D of privately-owned laterals is provided on each discharge scenario's capacity results figure for reference.

5.3.1 Existing Discharge Capacity Evaluation (June 2023)

A capacity analysis under Existing discharge conditions (June 2023) was performed using the calibrated Brine Line model. A five-day extended period simulation (EPS) was completed, with maximum d/D in gravity flow pipelines compared to the evaluation criteria, as summarized in Section 5.2. **Figure 5-1** illustrates the maximum d/D results for gravity flow pipelines of the Brine Line system under Existing discharge conditions.

Under Existing discharge conditions, no gravity flow pipelines are shown to achieve a maximum d/D greater than 0.75. The maximum pressure in Reach V as predicted by the model is approximately 56 psi. The maximum pressure at the top of Reach IV-E as predicted by the model is approximately 6 psi.

Additionally, **Figure 5-2** depicts the maximum pipeline velocities anticipated throughout the Brine Line system under Existing discharge conditions. In general, the gravity flow pipelines Reaches IV and IV-A through IV-E are expected to attain a velocity of at least 2.0 fps over a five-day period. Due to current low flows from IEUA dischargers, the maximum velocity in Reach IV-A north of Euclid Ave is expected to reach 1.9 fps only. However, as flows from IEUA dischargers increase over the future discharge scenarios, the maximum velocity in Reach IV-A north of Euclid Ave will also increase to at least 2.0 fps. SAWPA is recommended to consider increased observation and cleaning of this reach.

The maximum velocities within the extended siphons in Reach V were calculated using the continuity equation ($Q = V \times A$). Under Existing maximum discharge conditions, velocities in Reach V are expected to reach 2.2 fps but not exceed 8.0 fps in the smallest diameter (i.e., 23-inch) segments.

No dischargers are connected to the CRC lateral in the Existing discharge scenario, resulting in a maximum velocity of zero throughout the lateral (i.e., no flow). Furthermore, the Discharge Workshops did not identify any new dischargers to the CRC lateral in future scenarios. It is assumed that no flow is conveyed to the Brine Line via the CRC lateral in any of the following discharge scenarios.

5.3.2 Near-Term Discharge Capacity Evaluation (2024 - 2034)

A capacity analysis of the Brine Line system under Near-Term discharge conditions was performed. Near-Term discharges were developed as discussed in Section 3 and represent the projected increase in discharge between 2024 and 2034. A five-day EPS was completed, with maximum d/D in gravity flow pipelines compared to the evaluation criteria summarized in Section 5.2. **Figure 5-3** summarizes the maximum d/D in gravity flow pipelines of the Brine Line system under Near-Term discharge conditions.

Under Near-Term discharge conditions, no gravity flow pipelines are anticipated to achieve a maximum d/D greater than 0.75. The maximum pressure in Reach V as predicted by the model is 57 psi. The maximum pressure at the top of Reach IV-E as predicted by the model is approximately 6 psi.

Figure 5-4 depicts the maximum pipeline velocities anticipated throughout the Brine Line system under Near-Term discharge conditions. Compared to the Existing discharge scenario, velocities are expected to increase due to higher flows in the Near-Term scenario. For example, several pipelines in Reach IV-A north of Euclid Ave are expected to reach a maximum velocity of 2.0 fps instead of remaining at or below 1.9 fps.

Under Near-Term discharge conditions, the maximum velocity in Reach V will increase to approximately 2.5 fps in the smallest diameter segments as a result of additional flows from Elsinore Valley MWD's future connection to the Brine Line. As with the Existing discharge scenario, velocities are not anticipated to exceed 8.0 fps within Reach V under Near-Term discharge conditions.




Figure 5-1 Existing Maximum Discharge Scenario – Maximum Pipeline d/D




Figure 5-2 Existing Maximum Discharge Scenario – Maximum Pipeline Velocities




Figure 5-3 Near-Term Maximum Discharge Scenario – Maximum Pipeline d/D




Figure 5-4 Near-Term Maximum Discharge Scenario - Maximum Pipeline Velocities

5.3.3 Long-Term Discharge Capacity Evaluation (2035 - 2049)

A capacity analysis of the Brine Line system under Long-Term discharge conditions was performed using the hydraulic model. Long-Term discharges were developed as discussed in Section 3 and represent the projected increase in discharges to the Brine Line between 2035 and 2049. A five-day EPS was completed, and maximum d/D in gravity flow pipelines compared to the evaluation criteria summarized in Section 5.2. **Figure 5-5** summarizes the maximum d/D in gravity flow pipelines of the Brine Line system under Long-Term discharge conditions.

Under Long-Term discharge conditions, portions of Reaches IV-D, IV-A, and IV are projected to experience maximum d/D values greater than 0.75. Of note, the lower segments of Reach IV-A, south of Euclid Avenue, are expected to reach a maximum d/D of 1.0 (i.e., pipeline flowing full). The lower portion of Reach IV-A was slip-lined with FRP in 2013. Upon completion of the slip-lining project, the diameter of the lower Reach IV-A pipeline was effectively reduced from 42-inch to 36-inch.

The results of the capacity analysis indicate that surcharge conditions are not projected in the lower Reach IV-A pipelines, while it is flowing full. In other words, under Long-Term discharge conditions, flow in lower Reach IV-A will not rise to surface elevations or potentially increase the likelihood of a Brine Line overflow. It is noted that the MAS along this reach are sealed to prevent potential overflows. Projected pressures within the MAS are less than 10 psi.

The maximum pressure in Reach V as predicted by the model is 58 psi. The maximum pressure at the top of Reach IV-E as predicted by the model is approximately 6 psi.

Figure 5-6 illustrates the maximum pipeline velocities anticipated throughout the Brine Line system under Long-Term discharge conditions. Compared to the Existing and Near-Term discharge scenarios, velocities are expected to increase due to higher flows in the Long-Term scenario. Nearly all pipelines in Reach IV-A north of Euclid Ave are expected to reach a maximum velocity of 2.0 fps.

Under Long-Term discharge conditions, the maximum velocity in Reach V will increase to approximately 3.3 fps in the smallest diameter segments as a result of additional flows from the EMWD service area and Temescal Valley Water District's future connection to the Brine Line. As with the Existing and Near-Term discharge scenarios, velocities are not anticipated to exceed 8.0 fps within Reach V under Long-Term discharge conditions.

5.3.4 Buildout Discharge Capacity Evaluation (Beyond 2049)

A capacity analysis of the Brine Line system under Buildout discharge conditions was performed using the hydraulic model. Buildout discharges were developed as outlined in Section 3 and represent the projected increase in discharges to the Brine Line beyond 2049. A five-day EPS was completed, and maximum d/D in gravity flow pipelines compared to the evaluation criteria summarized in Section 5.2. **Figure 5-7** summarizes the maximum d/D in gravity flow pipelines of the Brine Line system under Buildout discharge conditions.

Under Buildout discharge conditions, pipelines in Reaches IV-D, IV-A, and IV are anticipated to experience maximum d/D values greater than 0.75. Compared to the results of the Long-Term capacity analysis, additional segments of Reach IV-A, south of Euclid Avenue, are projected to reach a maximum d/D of 1.0, resulting from the increase in discharge between the Long-Term and Buildout scenarios. Similarly, the maximum d/D of pipelines already identified as deficient ($d/D > 0.75$) under Long-Term discharge conditions is projected to worsen in the Buildout discharge scenario.

The results of the capacity analysis indicate that surcharge conditions are projected at MAS 4A-0160, in the lower Reach IV-A pipeline, while it is flowing full. In other words, under Buildout discharge conditions, the flow in lower Reach IV-A will rise to ground level at MAS 4A-0160 and potentially increase the likelihood of a Brine Line overflow. MAS structures in this portion of the reach are sealed to prevent potential overflows.

The maximum pressure in Reach V as predicted by the model is 58 psi. The maximum pressure at the top of Reach IV-E as predicted by the model is approximately 6 psi.

Figure 5-8 illustrates the maximum pipeline velocities anticipated throughout the Brine Line system under Buildout discharge conditions. Compared to the previous discharge scenarios, velocities are expected to increase due to higher flows in the Buildout scenario.

Under Buildout discharge conditions, the maximum velocity in Reach V will increase to approximately 3.5 fps in the smallest diameter segments as a result of additional flows from Elsinore Valley MWD. As with the previous discharge scenarios, velocities are not anticipated to exceed 8.0 fps within Reach V under Buildout discharge conditions.




Figure 5-5 Long-Term Maximum Discharge Scenario – Maximum Pipeline d/D




Figure 5-6 Long-Term Maximum Discharge Scenario – Maximum Pipeline Velocities




Figure 5-7 Buildout Maximum Discharge Scenario – Maximum Pipeline d/D




Figure 5-8 Buildout Maximum Discharge Scenario – Maximum Pipeline Velocities

5.3.5 Ownership Discharge Capacity Evaluation

A capacity analysis of the Brine Line system under Ownership discharge conditions was performed using the hydraulic model. Ownership discharges were developed as discussed in Section 3 and represent the maximum allowable discharge to the Brine Line based on existing Member Agency ownership and its distribution to specific dischargers. A five-day EPS was completed, and maximum d/D in gravity flow pipelines compared to the evaluation criteria summarized in Section 5.2. **Figure 5-9** summarizes the maximum d/D in gravity flow pipelines of the Brine Line system under Ownership discharge conditions.

Under Ownership discharge conditions, pipelines in Reaches IV-D, IV-A, and IV are projected to experience maximum d/D values greater than 0.75. Compared to the results of the Long-Term capacity analysis, the maximum d/D of pipelines already identified as deficient ($d/D > 0.75$) is projected to increase due to the additional discharge in the Ownership scenario. The lower segments of Reach IV-A, south of Euclid Avenue, are projected to continue flowing full at a maximum d/D of 1.0.

The results of the capacity analysis indicate that surcharge conditions are projected at MAS 4A-0160 in the lower Reach IV-A pipeline, while it is flowing full. In other words, under Ownership discharge conditions the flow in lower Reach IV-A will rise to the level of the ground surface at MAS 4A-0160 and potentially increase the likelihood of a Brine Line overflow. MAS structures in this portion of the reach are sealed to prevent potential overflows.

The maximum pressure in Reach V as predicted by the model is 58 psi. The maximum pressure at the top of Reach IV-E as predicted by the model is approximately 6 psi.

Figure 5-10 illustrates the maximum pipeline velocities anticipated throughout the Brine Line system under Ownership discharge conditions. Compared to the previous discharge scenarios, velocities are expected to increase due to higher flows in the Ownership scenario.

Under Ownership discharge conditions, the maximum velocity in Reach V will increase to approximately 4.0 fps in the smallest diameter segments. As with the previous discharge scenarios, velocities are not anticipated to exceed 8.0 fps within Reach V under Ownership discharge conditions.

5.3.6 Reach-by-Reach Analysis

The capacity of the individual Brine Line Reaches is estimated using the criteria summarized in Table 5-1. For Reaches governed by gravity flow, the pipeline with the lowest capacity before exceeding a maximum d/D of 0.75 establishes the maximum or limiting capacity of that entire Reach.

The Reach-by-Reach analysis addresses the capacity of gravity flow pipelines in Reach IV and IV-A through IV-E. Traditional siphons within these Reaches (as identified by their Siphon IDs in the d/D figures above) were not included in this analysis, as they were designed to convey greater discharges by increasing hydraulic gradients.

Instead of maximum d/D criteria, the capacity of Reach V is established based on the maximum acceptable velocity of 8.0 fps in pressurized pipelines. The smallest pressurized pipelines in Reach V with a diameter of 23 inches convey flow up to 15.0-mgd before velocities exceed 8.0 fps. **Table 5-3** summarizes the limiting flow capacity of each Reach, based on the defined criteria.

Table 5-3: Limiting Capacity by Brine Line Reach per Design Criteria

| Reach | Pipeline ID Limiting Reach Capacity | Pipeline Diameter (in) | Estimated Limiting Capacity at d/D = 0.75 (MGD) | Estimated Limiting Capacity at d/D = 1.0 (MGD) | Anticipated Maximum Flow at Buildout (MGD) |
|-----------------------|---|---------------------------|---|--|--|
| IV | P-4-0130 | 48 | 27.3 | 30.0 | 31.2 |
| IV-A (U) ¹ | P-4A-0300 | 26 | 7.3 | 8.0 | 1.3 |
| IV-A (L) ² | P- 4A-0160 | 36 | 12.5 | 13.7 | 20.8 |
| IV-B (U) | P-4B-0550 | 18 | 3.4 | 3.7 | 1.4 |
| IV-B (L) | P-4B-0220 | 36 | 13.0 | 14.2 | 10.5 |
| IV-D (U) | P-4D-1510 | 36 | 12.4 | 13.6 | 4.8 |
| IV-D (L) | P-4D-0250 | 42 | 18.7 | 20.6 | 16.8 |
| IV-E | P-4E-0340 | 36 | 10.2 | 11.2 | 4.5 |
| V | N/A | 23 | 15.0 ³ | 15.0 ³ | 10.5 |

Notes:

- ¹ North of Euclid Ave; (U) = Upper
- ² South of Euclid Ave; (L) = Lower
- ³ Estimated limiting capacity of Reach V is based on a maximum velocity of 8.0 fps instead of d/D, as this Reach of the Brine Line is generally designed to flow full (i.e., under pressure).




Figure 5-9 Ownership Discharge Scenario – Maximum Pipeline d/D




Figure 5-10 Ownership Discharge Scenario – Maximum Pipeline Velocities

5.4 Capacity Analysis Summary

The capacity analysis indicates there are six (6) sections of pipe in the Brine Line system that are anticipated to exceed SAWPA’s maximum d/D criterion of 0.75 as conditions approach the Long-Term (2034-2058) planning scenario, as presented in **Table 5-4**. These “choke points” include six (6) sections with d/D values anticipated to be between 0.75 and 1.0 and one (1) section of pipe, the 36-inch section of FRP pipe along Prado Dam, which is anticipated to surcharge (d/D ≥ 1). All pipes are located within roadways.

Table 5-4: Pipeline Segments Exceeding Brine Line Capacity

| Location | Reach | D/S MAS ID | U/S MAS ID | Diameter (in) | Max d/D | Length (LF) |
|----------|-------------------|------------|------------|---------------|---------|-------------|
| 1 | IV-A | 4A-0050 | 4D-0010 | 36 | 1.0 | 12,600 |
| 2 | IV-D | 4D-0110 | 4D-0150 | 42 | 0.91 | 2,000 |
| 3 | IV-D ¹ | 4D-0020 | 4D-0030 | 42 | 0.82 | 1,550 |
| 4 | CRC ² | CRC-0010 | CRC-0020 | 15 | 0.77 | 500 |
| 5 | IV | 4-0060 | 4-0130 | 48 | 0.86 | 7,000 |
| 6 | IV | 4-0030 | 4-0040 | 42 | 0.80 | 1,250 |

Notes:

¹ This section of pipeline of pipeline is downstream of a siphon and is of relatively low slope and was determined to not constitute a hydraulic deficiency requiring mitigation.

² The “choke point” listed as location 5 in Reach CRC is due to a backflow condition from Reach IV-B and is not indicative of a true capacity restriction in this section of pipe in the CRC reach.

Based on the capacity analysis results presented in Table 5-4, four system capacity improvement projects are recommended:

1. Long-Term Planning Scenario Recommendation:

- **Location 1, Reach IV-A:** Upgrade the entire reach of 36-inch FRP pipeline along the west side of Prado Dam to a 48-inch pipeline. Relocate the pipeline further west, away from the dam.

2. Buildout Planning Scenario Recommendations:

- **Location 2, Reach IV-D:** Construct a 36-inch parallel pipeline to alleviate the choke point at Location 2.
- **Locations 5 and 6, Reach IV:** Construct a single parallel pipeline to increase capacity at choke points in Locations 5 and 6.

3. Near-Term Planning Scenario Recommendation:

- **Locations 2 through 6:** Install smart manhole covers at choke points in Locations 2 through 6 to monitor long-term flow conditions. Adjust the timing of the recommended parallel pipeline projects based on changing conditions, if necessary.

A summary of the recommended improvement projects can be found in **Table 5-5**.

Table 5-5: Summary of Recommended System Capacity Improvements (All Phases)

| Planning Scenario | Project ID | Location | Ex. Diameter (inch) | Length (LF) | Recommendation |
|------------------------|------------|---|---------------------|---------------------|------------------------------------|
| Long-Term (2034-2058) | CAP-1 | Reach IV-A FRP Piping west of Prado Dam (Location 1, Table 5-4) | 36 | 18,000 ¹ | 48-inch Replacement and Relocation |
| Near-Term (2024-2034) | CAP-2 | Choke Points at Locations 2 through 6 in Table 5-4 | Varies | - | Smart Manhole Cover Surveillance |
| Buildout (Beyond 2048) | CAP-3 | Reach IV-D between MHs 4D-0110 and 4D-0150 (Location 2, Table 5-4) | 42 | 2,100 | 36-inch Parallel |
| Buildout (Beyond 2048) | CAP-4 | Reach IV between MHs 4-0030 and 4-0130 (Locations 5 - 6, Table 5-4) | 42 | 10,200 ² | 30-inch Parallel |
| TOTAL | | | | 30,300 | - |

Notes:

¹ While the hydraulic deficiency in this reach of pipeline occurs in only 12,600 LF of pipe, it is recommended the entire reach of 36-inch RFP be upsized and relocated away from the Prado Dam.

² This recommended pipeline would parallel the entire reach of pipe between the two choke points identified as Locations 5 and 6 in Table 5-4.

6 Capacity Management & Long-Term Planning Efforts

6.1 Reliability and Redundancy

Reliability and redundancy are fundamental to the effective capacity management and long-term planning of the SAWPA Brine Line. Ensuring continuous operation, mitigating risks, and planning for future needs are essential for maintaining the functionality and sustainability of this critical infrastructure. Through careful planning and investment in reliable and redundant systems, the SAWPA Brine Line can continue to serve the region's brine disposal needs effectively and sustainably. The following sections provide the results from the 2021 risk assessment performed on the Brine Line system as well as other Brine Line studies focused on maintaining the long-term focus and reliability of the system.

6.1.1 Brine Line Criticality Analysis

In 2021, Dudek performed a system-wide criticality analysis of the Brine Line, with the objective of identifying and prioritizing the critical components of the system. The Criticality Analysis results influence the prioritization of identified Capital Improvement Projects, including projects required for operational or capacity-based purposes. The following is a summary of the Brine Line Criticality Analysis and the results obtained.

As previously discussed in this document the Brine Line spans over 73 miles, incorporating six reaches and various materials, such as lined reinforced concrete, PVC, and HDPE. The Brine Line uses both open channel and gravity pressure flow conditions to transport brine, with maintenance access structures for operational efficiency. SAWPA undertook the criticality assessment to evaluate the risk of infrastructure failure and its consequences. This assessment guides the agencies financial policy decisions, as well as helps prioritize asset maintenance and capital improvement projects.

A risk-based criticality assessment was used to develop and analyze failure probabilities and consequences. Failure Mode and Effects Analysis (FMEA) techniques were adapted to assess potential failure modes and their impacts on the Brine Line system operation. This approach helped identify high-risk assets requiring immediate attention and lower-risk assets for regular monitoring. The analysis performed include:

- Consequence of Failure Analysis (CoFA): Evaluates the impact of potential pipeline failures in categories like environmental/regulatory, health/safety, economic/personnel, and transportation. This analysis used Geographic Information System (GIS) techniques to analyze and visualize the consequences.
- Probability of Failure Analysis (PoFA): Assesses the likelihood of pipeline failures based on factors like pipe age, maintenance accessibility, material, fault zone proximity, and potential spill points.

Combining the CoFA and PoFA results allowed assignment of criticality scores and ranking (High, Medium, Low) for each Brine Line pipeline segment. Results guided the prioritization of then current CIP projects. Approximately 14 percent of the Brine Line system was identified to have high criticality, 39 percent medium criticality, and 47 percent low criticality. The then current CIP included a 10-year plan addressing immediate and long-term infrastructure needs, prioritized based on criticality, ensuring high criticality components receive attention first.

The criticality assessment provided a data-driven foundation for SAWPA to prioritize its CIP, ensuring long-term sustainability and resilience of the Brine Line system. Regular updates to the criticality analysis and CIP were recommended to maintain the system's viability and adapt to new challenges. **Figure 6-1** illustrates the resulting criticality of the overall Brine Line system.

Figure 6-1 Final Criticality Summary Rankings for Brine Line Segments (2021 Analysis)



6.1.2 Off-Line Storage Analysis

During Brine Line outages, typically associated with ongoing system improvements, system evaluations, or potentially a system failure, SAWPA is required to decrease or eliminate the transport of brine throughout or within only those affected reaches of the Brine Line system. Decreasing or eliminating flow in the system currently requires SAWPA staff to coordinate individually with affected dischargers, impacting the dischargers' operations. As a means of ongoing system reliability improvement and reducing impact on system dischargers, SAWPA is investigating construction of a series of off-line storage reservoirs, with the intent to use this available storage to dewater the system as opposed to eliminating discharger flow. Under the proposed plan, SAWPA would construct a series of off-line storage reservoirs capable of storing a minimum of 8-hours of tributary Brine Line flow. The proposed concept includes a total of seven reservoirs, spaced throughout the system, to receive diverted brine to effectively empty the Brine Line on an as-needed basis for needed rehabilitation or repair.

The initial concept includes one reservoir along Reach IV-A, one along Reach IV-B, three along Reach IV-D and two along Reach V, as shown on **Figure 6-2**. To establish projected reservoir sizing, existing and projected brine flow was identified using the hydraulic model for each identified reservoir location (future design efforts will determine the exact location of storage facilities). Depending on the location, the reservoirs upstream and one reservoir

downstream of a potential shutdown location would be used simultaneously to receive diverted brine flow. This concept allows for storage to be shared across multiple reservoirs, reducing the size and cost of any one reservoir. Once the shutdown is complete, the stored flows would be required to be slowly released back into the Brine Line system, making use of available excess capacity. **Table 6-1** summarizes required reservoir storage volumes in million gallons (MG), by Reach, for each Brine Line flow condition, as well as the recommended reservoir sizing for each location.

Table 6-1: Off-Line Storage Reservoir Sizing for 8 Hours of Storage (MG)

| Reach | Existing Flow Condition | Near-Term Flow Condition | Long-Term Flow Condition | Buildout Flow Condition | Recommended Sizing |
|--------|-------------------------|--------------------------|--------------------------|-------------------------|--------------------|
| IV-A | 0.10 | 0.11 | 0.14 | 0.24 | 0.5-MG |
| IV-B/V | 2.23 | 2.67 | 3.32 | 3.48 | 2 at 2-MG |
| IV-D | 0.91 | 1.10 | 1.52 | 1.88 | 2-MG |
| IV-D | 0.64 | 0.48 | 1.56 | 1.89 | 2-MG |
| IV-D | 0.10 | 0.45 | 1.11 | 1.16 | 2-MG |
| IV-E | 0.62 | 1.46 | 1.48 | 1.51 | 2-MG |

It is noted that the sizing of the proposed storage reservoirs is based on the Buildout flow scenario, with an 8-hour storage capacity. As such, the reservoirs would be capable of providing extended storage capacity (12- to 24-hour storage capacity) during earlier planning horizons. Furthermore, reservoir draining would be easily accomplished in earlier planning horizons with significant excess system capacity and would likely take extended periods of time during later planning horizons when system capacity is more fully utilized.

Construction of the proposed off-line storage facilities, while facilitating Brine Line shutdowns, also provide extended system capabilities, including providing capture facilities for potential first-flush dry weather stormwater flows, thereby eliminating these typically contaminated flows from entering the groundwater or other drinking water resources. Also, as SAWPA contemplates brine minimization efforts for future Brine Line capacity management, these reservoirs could be used as forebay intake structures through which influent is routed to future flow minimization treatment facilities. Also, with respect to Green Hydrogen production, the proposed reservoirs could provide the locations from which water is directed to the hydrogen electrolyzer facilities. Considering the long-term needs of the Brine Line system, the proposed off-line reservoir system provides an array of benefits to SAWPA and its Member Agencies.

To fully evaluate the proposed reservoir facilities, it is recommended that a future study more thoroughly assess the feasibility of the proposed off-line storage concept. Factors requiring additional evaluation include:

- Construction of above- or below-ground reservoirs
- Methods of diverting flow into the reservoirs and returning stored water to the Brine Line
- Determination of the necessity for aeration and/or disinfection to mitigate potential odors
- Location of proposed reservoirs, potential for additional locations, and potential increased capacity
- Phasing of storage reservoirs over time

A planning level cost estimate for this project is included in Chapter 8.




Figure 6-1 Conceptual Brine Line Off-Line Storage Reservoir Locations

6.2 Data Collection & Real Time Management

Collection of real-time flow and quality information increases SAWPA's ability to monitor, operate, and control the Brine Line system. Furthermore, real-time data gathering allows SAWPA to monitor system dischargers on a continuous basis, thereby recording potential discharge violations and facilitating future pretreatment enforcement. Finally, a real-time understanding of each discharger's flow and strength characteristics will allow for a more equitable distribution of cost between the dischargers, and ultimately between the SAWPA Member Agencies. For these reasons, SAWPA is proposing implementation of a Supervisory Control and Data Acquisition (SCADA) based system for the purpose of data collection, evaluation, and management.

It is recommended that the SCADA-based system be implemented (more for data acquisition than control at this time), with data collection and transmittal devices installed at each discharger location and at each in-line flow monitoring location. The SCADA system concept was originally investigated by SAWPA in 2010, as part of its Santa Ana Watershed Salinity Management Program, Phase 3 SARI Operations Technical Memorandum (Phase 3 TM).

The proposed SCADA-based system provides remote, automated flow (and ultimately water quality) data collection for each discharger, and the overall Brine Line system. The collected data provides SAWPA staff information for monitoring discharge flow and quality, understanding the movement of brine discharges throughout the Brine Line system, and accurately quantifying system capacity and conditions on a real-time basis. Furthermore, automated data collection reduces SAWPA staff time related to data management and enhances ongoing effort related to compliance. The collected data is also useful in maintenance of the Brine Line hydraulic model, providing more accurate information throughout the current and future conveyance system.

The SCADA-based review conducted in the Phase 3 TM developed a system concept, typical installation details, an implementation phasing concept, and an Engineer's Opinion of Probable Cost. As part of this Master Plan effort, Dudek has updated the SCADA-based system concept, including required field devices, anticipated communication protocols, and the anticipated system cost. It is anticipated that more accurate details for the proposed SCADA-based system will be developed during future preliminary and final design efforts. The information included herein updates the Phase 3 TM information to represent the current and projected discharge conditions through build-out of the Brine Line system.

6.2.1 SCADA-based System Overview

The proposed Brine Line SCADA-based system will monitor discharges into the system from the various industries, municipalities, and agencies tributary to the Brine Line, currently and into the future. Key components of the proposed SCADA-based system include:

1. **Remote Terminal Units (RTUs) or PLCs (Programmable Logic Controllers):** These devices are installed at remote sites within the Brine Line system. RTUs or PLCs are responsible for gathering data from sensors and instruments (i.e., flow meters, probes, or others) located at the discharger sites and various in-line flow monitoring stations. The Phase 3 TM identified RTUs to convert field device signals to digital signals that can be transmitted over the communications network. A small PLC or a smart data acquisition module (DAM) is proposed for this purpose. Currently, the industry standard uses PLC-based devices for these efforts. Therefore, this analysis assumes the PLC-based equipment.

SAWPA is investigating automating its quarterly TSS and BOD sampling efforts. There are several options for in-line probes for TSS and TDS/conductivity, at reasonable cost, \$8,000 and \$1,000 per unit

respectively. In-line BOD analyzers are on the order of \$40,000 to \$80,000 per unit. Therefore, it is anticipated that the initial SCADA system will focus on flow monitoring, with the ability to incorporate water quality monitoring in the future. The system will be capable of incorporating operator developed water quality information. Also, water quality probes will require calibration and ongoing maintenance to reliably provide accurate data.

2. **Communication Infrastructure:** A robust communication network is essential for transmitting data between the PLCs and the central SCADA-based system. These facilities include wired connections (such as Ethernet or fiber optic cables) or wireless technologies (i.e., cellular communication) depending on the geographic scope and location of the brine conveyance system. The Phase 3 TM identified then-available technologies to develop a practical SCADA-based approach. The most practical communication protocol was determined to be the cellular network. The identified system used Cellular Digital Packet Data (CDPD), which was an open IP-based standard for the transmission of data over cellular communications. The CDPD service was discontinued in conjunction with the retirement of the parent AMPS service, and has been functionally replaced by faster services, such as 1xRTT, Evolution-Data Optimized, and UMTS/High Speed Packet Access (HSPA). Preliminary and final design efforts will determine the exact protocol for implementation.
3. **SCADA Master Station/Human-Machine Interface (HMI):** The SCADA-based master station serves as the central control hub of the entire system, collecting real-time data from the distributed PLCs and provides graphical interface for operators to monitor the status and performance of the Brine Line System. The master station can also facilitate control actions, allowing operators to remotely adjust parameters, if required. The HMI typically consists of computer monitors and software applications to display real-time data, alarms, and other optional information in a visual format. HMIs allow operators to interact with the system, view trends, acknowledge alarms, and make informed decisions based on the data presented.

The Phase 3 TM recommended development of a stand-alone, PC-based HMI for the SCADA-based system. The proposed development was based on this use of Wonderware software. Software vendors, including IOSight, AquaSight, and others, provide pre-developed data collection, management, and analysis capabilities within a single program suite. These vendors were contacted to identify the best option for the proposed application. For the purposes of this analysis, the IOSight configuration is used for cost purposes. Data is collected and stored locally and, on the cloud, to facilitate data management and manipulation. The IOSight software has a \$50,000 set up cost, with an annual cost of approximately \$12,000 to \$18,000, for the anticipated size of the SAWPA implementation.

4. **Data Historian:** A data historian is used to archive and store historical data collected by the SCADA-based system. This data is valuable for trend analysis, performance optimization, regulatory compliance reporting, and troubleshooting. The historian (database storage) ensures that a comprehensive record of system behavior is maintained. This database also archives the data in the event of a software failure.
5. **Alarm Management System:** SCADA-based systems typically include alarm management capabilities, which alert operators to abnormal conditions, equipment failures, or other potential system component failures. Alarms are displayed on the HMI and typically trigger notifications (i.e., emails, texts) to ensure timely response and corrective actions. This functionality would allow SAWPA to identify dischargers that are exceeding their permit requirements. This functionality may not be necessary during the initial stages of the implementation.

- 6. **Security Features:** Given the critical nature of brine line systems, SCADA-based systems typically incorporate security measures to protect against unauthorized access, cyber threats, and data breaches. These features include user authentication, encryption of communication channels, and adherence to industry standards for cybersecurity. The proposed software vendors have these security measures built into their systems already.
- 7. **Database and Reporting Tools:** SCADA-based systems integrate with databases and reporting tools to generate performance reports, analyze historical trends, and support decision-making processes. These tools help operators and managers assess system efficiency, identify areas for improvement, and ensure compliance with operational objectives and regulatory requirements.

As noted, the Phase 3 TM recommends a phased approach to construction, based on the discharge conditions at each site. The existing Brine Line has approximately 36 dischargers. Phasing of the SCADA system is summarized in **Table 6-2**.

Table 6-2: Phasing and Projected Costs for Initial SCADA System

| Phase | Description of Work | Cost ¹ |
|--------------|---|--------------------|
| 1 | Construction and installation of Master Station, operator workstation, setup, integration of programming and automation | \$200,000 |
| 2 | Construction and installation of first 12 discharger sites with the highest flow | \$350,000 |
| 3 | Construction and installation of next 12 discharger sites with medium flow | \$350,000 |
| 4 | Construction and installation of last 12 discharger sites with low flow | \$350,000 |
| 5 | Construction and installation of up to five (5) in-line flow monitoring stations | \$1,500,000 |
| TOTAL | | \$2,750,000 |

Note:

¹ Costs representative of 2010 TM, updated to 2024 costs using ENR Los Angeles CCI and current dischargers.

6.3 Brine Minimization

By accounting for planned and potential future sources of discharge to the Brine Line system through build out, it is projected that the total Brine Line flow will exceed the 30-mgd Brine Line capacity right. Current projections suggest that SAWPA will exceed their capacity right in approximately the year 2065, as shown on Figure 3-3. Sections 4 and 5 of this Master Plan identify the effect of these projected flows throughout the Brine Line system. Table 6-5 of this master plan provides an existing Brine Line Water Quality summary.

Similarly, SAWPA owns 17-mgd of treatment and disposal capacity in the OC San treatment facilities. Understanding the contracted limit of 30-mgd, this section addresses the potential need for future brine minimization facilities to assure that discharges to the OC San system remain below the 30-mgd capacity right. As identified in previous sections, SAWPA Member Agencies currently own a total of 32.5-mgd of pipeline capacity within the Brine Line system.

SAWPA has previously evaluated various Brine Line configurations in its Phase 2 Brine Line Planning Technical Memorandum (Phase 2 TM), for the purpose of lowering brine discharge below the 30-mgd limitation. Six potential system reconfigurations were evaluated. Ultimately, among these long-range options for managing the projected future flows, the recommended action was to continue to direct brine flows into the OC San system. However, SAWPA and its Member Agencies could pursue implementation of a secondary brine concentration processes at existing and future groundwater desalination facilities. It is noted that the Phase 2 TM did not evaluate the impacts of brine minimization relative to ongoing wastewater and recycled water demineralization at local water reclamation facilities. At present, groundwater desalters and recycled water demineralization projects account for up to 82 percent of the tributary Brine Line flow as shown in **Figure 6-3**. Based on recent discharger workshops, it is projected that wastewater and recycled water demineralization will continue to increase, with comparable increases in




Figure 6-3 Current Average Daily Brine Flow Production

groundwater desalination, resulting in these two discharges contributing 90 percent of the Brine Line flow. Incorporating industrial discharges, these three discharger categories are projected to contribute over 97 percent of tributary Brine Line flow.

Considering that 82 percent of brine line flow to the Brine Line system will ultimately be discharged from groundwater desalination and recycled water demineralization facilities, concentrating on these dischargers with respect to brine management will provide the most efficient method of maintaining brine flows below the 30-mgd OC San limitation. In addition, the facilities within these two categories are owned and operated by public agencies, which have the ability and funding to implement the necessary brine management facilities. Again, it is projected that the Brine Line will exceed its 30-mgd capacity right in approximately the year 2065. Based on current projections, flows from existing and projected desalination and demineralization facilities would be required to be reduced by approximately 8 percent (2.3-mgd) to maintain SAWPA's capacity right.

During discussions with existing dischargers, it was identified that current groundwater desalination facilities within the tributary area are not implementing additional brine concentration efforts. Agencies involved in groundwater desalination as a means of producing drinking water are likely focused on increasing water production, not decreasing brine production. However, as brine disposal is a significant cost, reduction in brine volumes is a worthwhile undertaking for these agencies. As other constituents of concern are identified and regulated (i.e., PFAS), control of these emerging constituents will involve similar treatment technologies, allowing attainment of brine reduction more realistic in coordination with emerging constituent treatment processes.

6.3.1 SAWPA Salt Management Plans

SAWPA understands the discrepancy between Member Agency ownership and downstream discharge limitations and has taken steps to effectively manage the capacity discrepancy. SAWPA completed the Phase 1 Salt Management Plan Technical Memorandum (Phase 1 TM) in January 2010. The Phase 1 TM discussed brine minimization strategies and pilot testing conducted by the Eastern Municipal Water District (EMWD) and Western Municipal Water District (WMWD) for management of brine waste and potential increased water recovery. The following discussion summarizes these and other brine minimization efforts:

- **EMWD Brine Minimization Pilot Testing:** EMWD conducted pilot testing using chemical softening techniques (caustic soda) to remove scaling precursors from the brine, followed by secondary treatments, including reverse osmosis (RO) and electro-dialysis reversal (EDR), to increase water recovery. Challenges included solids breakthrough causing irreversible fouling of membranes. In Phase II of the testing, EMWD refined the process using lime-soda ash softening and achieved improved recovery rates.
- **WMWD Brine Minimization Pilot Testing:** WMWD pilot tested concentrate treatment methods using pellet-softening reactors to remove calcium and silica from the RO concentrate. This testing allowed for recovery of up to 70 percent of the RO concentrate as permeate.
- **Future Scenarios:** Both districts planned at that time to expand their desalination and concentrate treatment capacities to reduce brine discharge and increase water recovery. The Phase 1 TM discusses potential actions, including best management practices, desalination for water supply, and zero liquid discharge to manage salt removal efforts.

SAWPA's Phase 2 SARI Planning Technical Memorandum (Phase 2 TM), dated May 2010 reviewed both centralized and decentralized brine minimization. Centralized in-line brine minimization represented by full Brine Line flows diverted to a centralized facility, where the total volume would undergo biological treatment, followed by chemical softening, microfiltration/reverse osmosis and disinfection. Concentrated waste from the centralized treatment plant would be returned to the Brine Line. Decentralized brine minimization considered installation of secondary RO processes at the groundwater desalters to reduce desalter discharges to the Brine Line. A 30-year Present Worth analysis comparison demonstrated that decentralized brine minimization was approximately three (3) times more cost effective than the centralized in-line plant option.

The Phase 2 TM discussed impacts of future technology within the Santa Ana watershed, specifically focusing on technologies that minimize brine flow volumes, summarized as follows:

- **Desalter Brine Minimization:** The selection of brine minimization technologies is dependent on brine water quality from the various RO desalination facilities. High calcium concentrations require chemical softening to prevent scaling in downstream RO treatment. Lime and soda-ash were defined for softening dependent on water composition.

- **Chemical Softening Process:** Chemical addition (lime and soda-ash) raises pH levels to precipitate inorganic species like calcium, magnesium, and silica, reducing their concentrations in the brine. This pre-treatment allows for higher recovery rates in downstream RO processes.
- **Wastewater Recycling:** Planned projects focused on recycling of wastewater for non-potable and indirect potable uses, mainly groundwater recharge, due to water scarcity and population growth. Recycled water quality is regulated and requires advanced treatment technologies, such as RO, prior to percolation in the local groundwater basin. Increasing local water supplies through groundwater augmentation continues to grow in popularity.
- **Industrial Dischargers:** Various industrial operations discharge wastewater into the Brine Line system, with diverse characteristics including organic material, total suspended solids (TSS), and total dissolved solids (TDS). Ongoing efforts are recommended to manage and treat these discharges.
- **Temporary Domestic Dischargers:** Temporary domestic dischargers are identified to be phased out, with plans to redirect flows to alternate facilities or treatment plants.
- **Fail-Safe Connections:** Fail-safe connections ensure emergency discharge locations in case of infrastructure failures, permitting controlled discharge of treated or untreated wastewater. SAWPA is also interested in minimizing these discharges in the future.

6.3.2 Arlington & Chino Desalter Studies

The Arlington and Chino Desalters are key components related to managing salt content within the Santa Ana River Watershed, but they face challenges related to brine disposal and scale formation. Implementation of pellet softening, particularly following successful pilot testing at the Arlington Desalter, appears promising for mitigating these challenges.

- **Purpose of Pellet Softening:** The primary goal of pellet softening is to reduce scale-forming minerals in the brine-concentrate discharged from the desalters. This reduction helps alleviate maintenance problems in the Brine Line system and reduces associated costs.
- **Effectiveness:** Pilot testing has shown that pellet softening effectively reduces silica concentrations and removes calcium carbonate, thus demonstrating its efficacy in addressing mineral scaling.
- **Future Considerations:** Full-scale implementation of pellet softening is being considered for the Arlington Desalter, with potential expansion to the Chino Desalters. This expansion could help further mitigate scaling issues and optimize brine disposal.
- **Institutional Arrangements:** The project funding and implementation would likely involve collaboration between the Chino Basin Desalter Authority (CDA) and SAWPA Member Agencies, reflecting the shared interest in addressing capacity constraints and operational challenges.

6.3.3 Rancho California Demineralization Studies

Rancho California Water District (RCWD) meets its water demand of 76,000 acre-feet per year (afy) from various sources. Agricultural needs make up 47 percent of its demand, with the remainder for domestic, commercial, and landscape use. To meet increasing agricultural demand and address supply challenges, RCWD plans to enhance

water treatment capabilities, including reducing TDS levels in recycled water to expand agricultural usage. A demineralization/desalination plant is proposed to achieve TDS levels below 500 mg/L, enabling up to 16,000 afy of recycled water for agriculture. The plan involves advanced treatment (microfiltration followed by RO), with resulting brine-concentrate needing volume-reduction technology to manage waste flows. Implementation would require coordination with EMWD, potentially necessitating pilot testing, engineering, permits, and funding considerations, including addressing capacity limitations in the Brine Line system.

6.3.4 Emerging Brine Management Technologies

The SAWPA TM's assumed RO as the brine minimization technology. Since those studies, emerging technologies are offering additional options for brine minimization, with one even contributing the benefit of destroying per- and polyfluoroalkyl substances (PFAS), the “forever chemicals” currently being regulated as a drinking water contaminant. The recent designation of PFAS compounds as hazardous materials by the United States Environmental Protection Agency (EPA) has increased the focus on potential PFAS capture and treatment. Capture of PFAS within high salinity, non-reclaimable waste streams is a difficult and costly process (further discussed later in Section 6.4). The following discussions describe emerging treatment options for Brine Line flows, should flows need to be reduced to manage system capacity.

6.3.4.1 Flow Reversal Reverse Osmosis

One of the challenges facing the Brine Line system is that of increasing the capacity of the system using brine minimization and concentration techniques to improve recovery at the desalters. Typical reverse osmosis has a low recovery rate for high salinity waters and additional rounds of RO for brine minimization have typically offered significantly diminished returns and has thus not been financially feasible. Flow Reversal Reverse Osmosis (FRRO) is an innovative technique within the realm of membrane-based water desalination in which the conventional direction of feedwater flow is periodically reversed during operation, strategically altering the flow dynamics across the membrane surface. This periodic reversal serves to minimize concentration polarization and fouling, enhancing overall system efficiency and extending the lifespan of the membrane. FRRO exhibits notable advantages, such as reduced energy consumption, improved resistance to membrane fouling and significant increase in produce water capacity, making it an attractive option for water treatment applications. The method's ability to enhance performance metrics, coupled with its potential for integration with renewable energy sources, positions FRRO as a promising technology in the pursuit of sustainable and efficient water purification solutions.

One manufacturer, ROTEC, developed a patented approach for “block repositioning”, which repositions blocks of pressure between the stages allowing the blocks to be switched. This new approach further improves treatment capacity as well as results in the need for less-frequent cleaning. FRRO is a technology that could potentially make brine concentration a more cost-effective solution for the Brine Line as system flows increase.

6.3.4.2 Ceramic Membrane with Electrodialysis Reversal

A ceramic membrane with EDR for brine concentration is a cutting-edge technology employed in the process of desalination and concentration of saline solutions. The ceramic membrane serves as a selective barrier, allowing the passage of water molecules while restricting the passage of salts and impurities. EDR is integrated into the system to facilitate the controlled migration of ions through ion-exchange membranes in response to an applied electric field. This not only aids in concentrating the brine but also assists in minimizing scaling on the ceramic membrane surface. The combination of ceramic membranes and EDR presents an efficient and durable solution for brine concentration processes, offering improved resistance to fouling and longer operational lifespans

compared to traditional desalination methods. This integrated approach contributes to the sustainability and cost-effectiveness of brine concentration processes, especially in the context of water treatment and resource recovery and may prove to be a viable solution for brine concentration for the Brine Line in the future.

6.3.4.3 Other Considerations

Future advances in water treatment technologies may increase SAWPA's ability to manage its brine flows more effectively and, potentially, create multi-use benefits for the community at large. Section 7.3 discusses the fact that the Brine Line is, as a regional facility, a multi-use benefit system, providing a wide array of benefits to the Santa Ana River Watershed by exporting salt from the watershed. Over time, it is recommended that SAWPA investigate innovative and collaborative opportunities to reduce brine volume, increase brine management, and otherwise create beneficial use of its brine flows. Water is a valuable resource, and the Brine Line will ultimately convey up to 30.0-mgd of brine. Identifying emerging uses, treatment technologies, or multi-benefit uses for these flows will be beneficial to SAWPA and its Member Agencies. The following discussion identify areas of focus for potential identification of such opportunities:

1. **Membrane Distillation (MD):** MD is an emerging desalination technology that utilizes a hydrophobic membrane to separate water vapor from the brine. MD operates at relatively low temperatures and pressures compared to traditional distillation methods like thermal distillation, making it more energy-efficient. The membrane selectively allows only water vapor to pass through, resulting in a purified permeate stream that is free from salts and contaminants. MD can be scaled for various applications, from small-scale portable units for remote areas to large-scale industrial systems for brine concentration and desalination. It can handle high salinity and complex feed waters, making it suitable for treating brine streams from various sources, including seawater desalination reject brine and industrial wastewater. MD systems can be designed in modular configurations, allowing for easier installation, maintenance, and integration into existing water treatment processes.

While membrane distillation offers advantages, there are ongoing research efforts to address challenges such as membrane fouling, scaling, and improving process efficiency. Advances in membrane materials, module design, and system optimization are expanding the application of membrane distillation for brine concentration and water purification. MD is a promising technology for brine concentration and desalination, offering energy-efficient and versatile solutions for addressing water scarcity and wastewater management challenges. Continued research and development in this field will further enhance the performance and cost-effectiveness of membrane distillation systems.

2. **Forward Osmosis (FO):** FO is an innovative separation process that has gained attention for various applications, including brine concentration and water purification. FO operates based on the natural osmotic phenomenon, utilizing a semi-permeable membrane to separate water from dissolved solutes, without applying external hydraulic pressure. A semi-permeable membrane allows water molecules to pass through while blocking dissolved solutes. A concentrated solution (known as the draw solution) and a feed solution (such as brine or wastewater) are separated by the semi-permeable membrane. The difference in solute concentrations between the solutions creates an osmotic pressure gradient across the membrane. Water molecules move from the lower concentration (feed solution) to the higher concentration (draw solution), driven by osmotic pressure. The draw solution, enriched with water from the feed solution, requires further processing to separate the water from the draw solutes, thereby regenerating the draw solution for reuse. Or, as in the Brine Line scenario, the concentrated draw solution could be returned to the Brine Line with a reduced flow volume.

Despite its advantages, FO faces certain challenges. Efficient draw solution recovery and regeneration processes are essential to minimize operational costs and environmental impacts. Continued research is needed to develop more robust and selective membranes that withstand harsh operating conditions and improve separation performance. Enhancing overall process efficiency, reducing fouling potential, and optimizing system design are ongoing areas of research. Further research and development efforts are essential to overcome challenges and optimize FO processes for broader implementation in water and resource management sectors.

- 3. Electrodialysis Reversal (EDR):** EDR is an advanced membrane-based technology used for desalination, brine concentration, and purification of water by utilizing ion-selective membranes and electrical potential to facilitate the separation of ions from a feed solution. EDR operates based on the principles of electrodialysis, with an additional feature of periodic reversal of electrical polarity to mitigate membrane fouling and enhance efficiency. EDR systems consist of alternating ion-exchange membranes (anion-selective and cation-selective membranes) arranged in a stack between electrode compartments. A feed solution containing ions to be separated (such as brine) is introduced into the system. When an electric potential is applied across the membranes, positively charged ions (cations) migrate towards the negatively charged electrode (cathode) and negatively charged ions (anions) migrate towards the positively charged electrode (anode). As ions migrate through the ion-exchange membranes under the influence of the electric field, they are selectively removed from the feed solution, resulting in two separate streams: a desalinated product stream (permeate) and a concentrated brine stream (concentrate or reject). In EDR, the polarity of the electrodes is periodically reversed, causing the migration of ions to alternate directions. This reversal helps prevent membrane fouling by redistributing the accumulated ions and reducing scaling on the membrane surfaces.

Despite its advantages, EDR technology has challenges. Further research is needed to develop advanced membrane materials and cleaning techniques to minimize fouling and scaling issues. Enhancing energy efficiency and reducing operational costs through system optimization and integration with renewable energy sources. Developing innovative system designs and integrating EDR with other water treatment technologies for enhanced performance and cost-effectiveness. EDR is promising for desalination, brine concentration, and water purification, offering selective ion removal and energy-efficient operation. Continued research and development efforts are needed to overcome challenges and optimize EDR systems for broader applications in water treatment and resource recovery.

- 4. Solar-Driven Technologies:** Solar-driven desalination technologies, such as solar stills or solar-assisted MD, are gaining attention for brine concentration. Using renewable energy sources for the energy-intensive process of brine concentration can reduce operational costs and environmental impacts.

Solar thermal desalination systems utilize solar energy to generate heat, which is used to evaporate water and produce freshwater through condensation. Solar stills use a transparent cover to capture solar radiation and heat saline water, causing evaporation. The vapor condenses on the cover and is collected as freshwater, leaving behind concentrated brine. In multi-stage flash (MSF) distillation, solar thermal energy is used to heat multiple stages of brine, causing rapid evaporation and condensation. Freshwater is collected from the condensate, and brine is discharged as a concentrated stream. In multiple-effect distillation (MED), solar thermal energy drives multiple stages of evaporation and condensation, similar to MSF distillation. The concentrated brine is discharged from the final stage.

Solar-powered reverse osmosis (RO) systems use photovoltaic panels to directly convert solar energy into electricity, which powers high-pressure pumps for the RO process. RO membranes desalinate seawater or brackish water by separating salt ions from water molecules under pressure. Solar-powered RO systems are suitable for remote or off-grid locations where access to conventional electricity is limited.

Solar membrane distillation (SMD) combines membrane distillation with solar thermal energy to desalinate water. SMD systems use a hydrophobic membrane to separate water vapor from brine. Solar energy is used to heat the feedwater, driving the distillation process.

Challenges with solar driven process include developing efficient energy storage solutions (e.g., batteries, thermal storage) to ensure continuous operation during periods of low solar irradiance, optimizing system designs and integrating solar technologies with treatment processes to maximize efficiency and reliability, and further reducing the overall cost of solar-driven systems to enhance affordability and widespread adoption.

5. **Hybrid Systems:** Hybrid systems, in the context of water treatment and brine concentration, refer to integrated approaches that combine multiple technologies to optimize efficiency, enhance performance, and address specific challenges associated with desalination and brine management. These systems leverage the strengths of different technologies to achieve synergistic benefits and improve overall process sustainability. Hybrid systems are typically used in large-scale desalination plants to optimize water recovery and energy efficiency. Hybrid systems are also applied in industrial sectors to treat complex wastewater streams and recover valuable resources.
6. **Advanced Materials:** Advanced materials play a key role in enhancing the efficiency, performance, and sustainability of technologies used in various industries, including water treatment, desalination, and brine concentration. These materials are designed to exhibit specific properties such as high selectivity, durability, and resistance to fouling or corrosion, making them ideal for challenging environments and applications. Challenges include the ability to scale up advanced materials from laboratory-scale to commercial applications while maintaining performance and cost-effectiveness. Developing multifunctional materials and hybrid systems that combine multiple functionalities (e.g., adsorption and catalysis) for integrated water treatment processes. Conducting comprehensive lifecycle assessments to evaluate the environmental impact and sustainability of advanced materials throughout their lifecycle.

These emerging technologies offer promising solutions to the challenges associated with brine concentration, such as energy consumption, cost-effectiveness, and environmental sustainability. Continued research and development in this field are crucial to enabling widespread adoption and implementation of these innovative approaches.

6.3.5 Projected Brine Management Cost

As stated, it is currently projected that SAWPA will approach the OC San flow limitation of 30-mgd in approximately 2065. As such, brine management technological advancements will undoubtedly progress over this time. Similarly, the cost of current and future brine management options will undoubtedly increase as well. For the purposes of this master plan and considering the extended time by which brine management is required to be implemented, no specific costs for these facilities are projected. However, it is recommended that a specific planning study be completed within the next ten to fifteen years to evaluate the technological advancements related to brine concentration, with a specific focus on future costs for these treatment facilities.

From SAWPA's 2010 investigations, brine minimization facilities were projected to cost in excess of \$12,000,000 per-mgd of treatment capacity. Based on the estimated flow of approximately 2.3-mgd required to reduce projected flows below the 30-mgd OC San limitation, the cost (in 2010 dollars) was projected to exceed \$27,000,000. In 2024 dollars, this cost is approximately \$35,000,000. From the 2010 analyses into brine minimization facilities based on cost and other considerations, SAWPA determined the following strategic recommendations:

- Moving forward with a “business as usual” approach will eventually present major impediments to implementing a brine minimization strategy to manage flow below the 30-mgd limitation, with a projected higher cost. However, it is noted that the Brine Line system is projected to be able to convey these higher “buildout” flows to the OC San discharge location.
- Implementation of brine concentration projects at as many existing or future groundwater desalter sites offers multiple benefits, including managing future flows below the 30-mgd limit and having less impact from and to OC San.
- Potential advantages exist relative to a direct ocean outfall approach including the possibility of a lower overall cost, while minimizing dependency on OC San for treating flows. However, significant challenges would exist relative to this option.
- Considering the substantial high cost and other implementation hurdles, a downstream, in-line brine concentration approach was not considered to be feasible. However, advancements in treatment technologies and treatment requirements for emerging constituents of concern could substantially change this conclusion.

The following discussions identify emerging technologies focused on PFAS removal. At present, it is not clear that many treatment technologies on the market are capable of removing PFAS from wastewater. For example, the efficacy of granular activated carbon filtration will vary depending on the nature of the wastewater. Wastewater can contain high concentrations of dissolved organic carbon, which may limit the utility of granular activated carbon (GAC) in removing PFAS from wastewater. At present, the only demonstrated treatment process for removal of PFAS from wastewater may be reverse osmosis.

6.4 PFAS Management

PFAS compounds are a group of synthetic organofluorine chemical compounds that are both widespread in use and persistent in the environment. Their occurrence in water is frequently associated with military installations, airports, firefighting training areas, and landfills where PFAS-containing materials have been used and/or disposed of. The presence of PFAS in water can typically result in health risks when individuals are exposed to contaminated water. To address this concern, the EPA announced, a National Primary Drinking Water Regulation targeting six specific PFAS compounds. These include:

- Perfluorooctanoic acid (PFOA)
- Perfluorooctane sulfonic acid (PFOS)
- Perfluorononanoic acid (PFNA)
- Hexafluoropropylene oxide dimer acid (HFPO-DA, commonly known as GenX)
- Perfluorohexane sulfonic acid (PFHxS)
- Perfluorobutane sulfonic acid (PFBS)

Currently, there are no established PFAS regulations for concentrated brine, although some states like Michigan are developing discharge limits for wastewater that exceed federal drinking water standards. Implementing industrial or commercial PFAS limits separate from drinking water standards is an ongoing process. Unlike typical drinking water systems, the Brine Line handles wastewater with potentially higher PFAS concentrations, necessitating tailored regulations. There are both advantages and challenges in including PFAS removal as part of overall management of the Brine Line. Some of the advantages include mitigating health risks associated with exposure to these persistent compounds, help to mitigate long-term health risks, promote environmental protection, and enhance confidence in regulatory responses to PFAS contamination. However, challenges arise from the complexity of removing PFAS compounds in brine, the environmental footprint of treatment, and high costs. There are many treatment technologies on the market, ranging from GAC filtration, to emerging methods like electrochemical oxidation or engineered adsorbent media, which demonstrate efficacy in removing PFAS from water and wastewater.

Capital and operational costs for PFAS treatment of brine are presented in the following sections. Cost estimates are conservative due to the complexity of treating PFAS compounds in brine and the current, undefined regulatory environment for PFAS in wastewater discharges. Specialized methods and treatment processes are required to treat PFAS in brine, which adds to costs. In the absence of regulations for wastewater PFAS concentrations, drinking water regulations have been used herein as a guideline for treatment requirements. Given the scale of contamination, these regulatory requirements could further inflate costs, placing financial burdens on affected communities and industries. Despite these challenges, the costs of not addressing PFAS contamination can be even greater, considering the potential long-term health impacts and environmental consequences. Balancing the need for effective management with financial constraints requires careful consideration and innovative approaches to minimize costs while maximizing effectiveness.

6.4.1 Overview

As new and emerging constituents are required to be removed from wastewaters, new treatment facilities will be designed to help meet permit requirements. Management and treatment to remove PFAS from the Brine Line is not currently required. However, regulation of these substances continues to increase, requiring advancement of the technologies required to remove and eliminate these substances from our society. As a result, PFAS management is becoming more critical, for the following reasons:

1. **Health Risks:** PFAS, often referred to as "forever chemicals," are linked to serious health issues, including cancer, liver damage, immune system disruption, and developmental problems in children.
2. **Environmental Persistence:** These chemicals are incredibly persistent in the environment, meaning they do not break down easily and can accumulate over time in soil, water, and living organisms.
3. **Widespread Contamination:** PFAS are found globally in water supplies, food products, and various consumer goods due to their extensive use in industrial applications and consumer products like non-stick cookware, water-repellent fabrics, and firefighting foams.
4. **Regulatory Pressure:** Governments and regulatory bodies are increasingly recognizing the need to control and limit PFAS emissions and contamination. This includes setting limits for PFAS levels in drinking water and establishing guidelines for their management and cleanup.

5. **Public Awareness and Demand:** There is growing public concern and demand for safer products and cleaner environments, prompting industries and policymakers to adopt more stringent PFAS management practices.

Effective PFAS management involves monitoring and reducing their release into the environment, remediating contaminated sites, and developing safer alternatives to these harmful substances. Regulatory pressure for PFAS management is intensifying with rising awareness of the environmental and health risks associated with these chemicals. Key aspects of this regulatory pressure include:

- **Stricter Regulations and Guidelines.** Governmental agencies are implementing stricter regulations and guidelines to limit PFAS concentrations in the environment, particularly in drinking water. The EPA has established health advisory levels for certain PFAS, such as PFOA and PFOS, and is working towards setting enforceable drinking water standards. The EPA recently categorized PFAS as a hazardous material. The European Chemicals Agency has restricted the use of certain PFAS and has proposed further restrictions on their use in various products. Many countries, including Canada, Australia, and Japan, have set limits on PFAS concentrations in drinking water and are developing comprehensive management plans.
- **Mandatory Reporting and Monitoring.** Several jurisdiction agencies now require industries to report the use, emissions, and presence of PFAS in products and waste streams. In the U.S., certain PFAS must be reported under the Toxicity Release Inventory (TRI), providing data on their release and disposal. The EU's Industrial Emissions Directive includes PFAS among the pollutants to be monitored and controlled at industrial facilities.
- **Cleanup and Remediation Requirements.** Regulators are mandating the cleanup of PFAS-contaminated sites, often with strict timelines and performance criteria. In the U.S., the EPA is identifying PFAS as contaminants of concern at Superfund sites, requiring responsible parties to remediate contamination. Various countries have launched initiatives to identify and remediate contaminated sites, often prioritizing areas near industrial facilities, military bases, and airports where PFAS use has been historically high. To reduce the future release of PFAS, regulatory agencies are banning or restricting their use in specific products and applications. Several U.S. states, such as Washington and New York, have banned PFAS in food packaging. The EU has proposed restrictions on PFAS in textiles, firefighting foams, and other consumer goods, aiming to phase out their use wherever possible.
- **Research and Innovation Incentives.** Governments are also funding research to better understand PFAS, their impacts, and alternative solutions. Funding for academic and industrial research to develop safer alternatives to PFAS and innovative technologies for their detection and removal. Collaborations between governments, industries, and research institutions to advance PFAS management practices and technologies.
- **International Cooperation and Standards.** Global coordination is critical given the widespread nature of PFAS contamination. International bodies like the United Nations and the Organization for Economic Cooperation and Development (OECD) are working on global standards and frameworks to manage PFAS. Some PFAS are listed under the Stockholm Convention on Persistent Organic Pollutants, which aims to eliminate or restrict their production and use globally. Initiatives to harmonize PFAS management efforts across countries, promoting shared strategies and technologies for monitoring, regulating, and remediating PFAS.

Regulatory pressure is a driving force behind improved PFAS management, compelling industries to adopt safer practices and governments to protect public health and the environment. This pressure is leading to a more comprehensive approach to managing PFAS, from limiting their use and emissions to ensuring effective cleanup and encouraging the development of safer alternatives.

6.4.2 PFAS Treatment Processes

The goal of this section is to evaluate three (3) alternative treatment processes to reduce PFAS concentrations in the Brine Line. The first alternative removes PFAS through a Novel Adsorption System (NAS) manufactured by CycloPure. The second alternative removes PFAS via an Electro-oxidation (EOX) System manufactured by Aclarity. The third alternative removes PFAS via a Granular Activated Carbon (GAC) system, manufactured by Calgon. An average day treatment capacity of 15-mgd has been assumed for each alternative.

This section is organized as follows:

- PFAS Treatment Overview
- Water Quality
- Summary of Regulatory Permits
- PFAS Alternatives
- PFAS Treatment Cost Comparisons
- PFAS Treatment Costs Summary

6.4.3 PFAS Treatment Overview

Per- and polyfluoroalkyl substances (PFAS) are a group of synthetic organofluorine chemical compounds that are both widespread in use and persistent in the environment. Their occurrence in water bodies including wastewater, groundwater, or drinking water, is typically associated with military installations, airports, firefighting training areas, and landfills where materials containing PFAS have been used and/or disposed of. The occurrence of PFAS in water bodies can pose health risks when individuals are exposed to contaminated water.

6.4.3.1 Summary of Current Regulations

There are no specific regulations in California addressing the levels of PFAS in brine water. In the absence of dedicated regulations for brine water, this master plan assumed that federal drinking water standards would be applied as a baseline for PFAS treatment requirements. This conservative assumption corresponds to a limit of 4 parts per trillion (ppt) of PFAS in the treated brine line. This approach considers that federal drinking water standards are the prevailing regulations for PFAS and provide a benchmark for developing effective treatment strategies within the existing regulatory framework. Note that if regulatory requirements for PFAS treatment in brine water are introduced in the future, necessary adjustments to the master plan should be considered.

Some states, including Michigan, have begun developing discharge limits for wastewater of 170 ppt for PFOA, 12 ppt for PFOS, 670,000 ppt for PFBS, 210 ppt for PFHxS, and 30 ppt for PFNA, which are all higher concentrations than the federal drinking water limits.

Drinking Water PFAS Standards

The EPA has recently established enforceable Maximum Contaminant Levels (MCLs) for PFAS compounds in drinking water, including individual MCLs for PFOA, PFOS, PFHxS, PFNA, and HFPO-DA, and for mixtures containing at least two or more PFAS compounds using a Hazard Index (HI) MCL. The HI is a tool used to evaluate potential health risks from exposure to chemical mixtures of PFAS based on an assumption of dose additivity. To compute the HI, the concentration of each of the four (4) PFAS compounds are divided by their associated Health Based Water Concentration (HBWC), which is the level below which no health effects are expected for that PFAS compound. The normalized concentrations are then summed according to the equation below to calculate the HI. The EPA has set the target HI for these four PFAS compounds to be less than or equal to 1, which indicates that adverse effects are not likely to occur. Public water systems have five years (i.e. until 2029) to implement solutions that reduce these PFAS if monitoring shows that drinking water levels exceed these MCLs. MCLs for individual PFAS compounds are listed in **Table 6-3**.

$$HI = \frac{(PFHxS, ppt)}{9.0 ppt} + \frac{(PFNA, ppt)}{10.0 ppt} + \frac{(PFBS, ppt)}{2,000 ppt} + \frac{(HFPO-DA, ppt)}{10.0 ppt}$$

Table 6-3: Summary EPA Drinking Water Standards for PFAS Constituents

| Compounds | Maximum Contaminant Levels |
|-----------------|--|
| PFOS | 4 parts per trillion (4.0 ng/l) |
| PFOA | 4 parts per trillion (4.0 ng/l) |
| PFNA | 10 parts per trillion (10 ng/l) |
| HFPO-DA | 10 parts per trillion (10 ng/l) |
| PFHxS | 10 parts per trillion (10 ng/l) |
| PFBS | Included in HI ¹ |
| HI ¹ | Hazard Index = 1.0 (unitless) ¹ |

Notes:

1. $Hazard\ Index = \left(\frac{PFHxS}{9.0 ppt} + \frac{PFNA}{10 ppt} + \frac{PFBS}{2,000 ppt} + \frac{HFPO-DA}{10 ppt} \right)$

6.4.3.2 Future PFAS Requirements

Currently, there are no PFAS requirements for brine. Therefore, a treatment mass balance was estimated to understand how PFAS concentration and flow could change under future PFAS requirements. **Table 6-4** presents two scenarios for PFAS effluent limits and potential flow reduction. In Scenario 1, it is assumed that the effluent PFAS limit will be 5 times the drinking water PFAS MCL of 4 ppt, resulting in an effluent PFAS limit of 20 ppt. In the second scenario, the effluent PFAS limit will be 10 times the MCL, resulting in an effluent PFAS limit of 40 ppt. The influent PFAS and flow of 15-mgd remain the same.

Refer to Section 6.4.7 for construction and operation and maintenance (O&M) cost analysis.

Table 6-4: PFAS Effluent Scenarios

| Parameter | Unit | Current System | Scenario 1 | Scenario 2 |
|----------------|------|----------------|------------|------------|
| Influent Flow | MGD | 15 | | |
| Influent PFAS | ppt | 136 | | |
| Effluent PFAS | ppt | 4 | 20 | 40 |
| Treated Flow | MGD | 15 | 13 | 11 |
| Untreated Flow | MGD | 0 | 2 | 4 |

6.4.4 Brine Line Water Quality

An overview of Brine Line water quality is provided in **Table 6-5**. Data summarized in this section was captured between January 2010 through July 2022 and represents the initial baseline conditions for PFAS treatment. Long term average, maximum, and minimum values of monthly water quality parameters and flow conditions are provided as available, along with sample size for each measurement.

Table 6-5: Brine Line Water Quality Data

| Parameter | Units | Value | | |
|--------------------------------|-------|---------|---------|---------|
| | | Minimum | Average | Maximum |
| Flow | MGD | 8 | 11 | 15 |
| Biological Oxygen Demand (BOD) | mg/l | 17 | 50 | 240 |
| | lb/d | 1,416 | 4,573 | 21,056 |
| Total Suspended Solids (TSS) | mg/l | 48 | 138 | 413 |
| | lb/d | 4,800 | 12,673 | 36,228 |
| Total Dissolved Solids (TDS) | mg/l | 3,050 | 5,571 | 6,940 |
| | lb/d | 295,183 | 509,654 | 745,218 |

Note: MGD = million gallons per day; mg/l = milligrams per liter; lb/d = pounds per day

PFAS in the SAWPA Brine Line was studied by Trussell Technologies and reported in the Technical Memorandum, ‘Brine Line Monitoring results for PFAS’, in 2022. Trussell Technologies employed method “537 Modified” based on liquid chromatography with tandem mass spectrometry to measure the amount of 38 PFAS compounds in the Brine Line water. Composite samples were collected over a 24-hour sampling period. The analysis performed by Trussell Technologies detected concentrations above the reportable detection limit (RDL) for the following analytes: PFBA, PFPeA, PFHxA, PFHpA, PFOA, PFBS, PFPeS, PFHxS, PFHpS, PFOS, and 6:2 fluorotelomer sulfonate. A summary of these results is shown in **Table 6-6**, below.

Table 6-6: Brine Line Water PFAS Characteristics¹

| Parameter | Units | Value | | | MCL ² |
|-----------------------------|-------|---------|---------|---------|------------------|
| | | Minimum | Average | Maximum | |
| PFOS | ng/l | 97 | 136 | 170 | 4 |
| PFOA | ng/l | 89 | 106 | 130 | 4 |
| PFHxS | ng/l | 70 | 87 | 90 | 10 |
| PFNA | ng/l | NA | NA | NA | 10 |
| HFPO-DA | ng/l | NA | NA | NA | 10 |
| PFBA | ng/l | 30 | 50 | 59 | - |
| PFPeA | ng/l | 50 | 58 | 65 | - |
| PFHxA | ng/l | 57 | 69 | 84 | - |
| PFHpA | ng/l | 28 | 33 | 37 | - |
| PFBS | ng/l | 43 | 48 | 52 | - |
| PFPeS | ng/l | 16 | 18 | 21 | - |
| PFHpS | ng/l | 5.3 | 6.3 | 7 | - |
| 6:2 Fluorotelomer Sulfonate | ng/l | 15 | 41 | 84 | - |

Notes:

¹ ng/l = nanograms per liter; NA = not available. PFNA and HFPO-DA were not measured.

² MCL values listed are for drinking water.

Table 6-6 depicts brine water PFAS data. PFOA and PFOS concentrations range between 89-130 mg/l and 97-170 mg/l respectively. While there are no specific regulations in California addressing the treatment of PFAS in brine water, those concentrations are above the drinking water MCLs.

6.4.5 PFAS Treatment Alternatives

There are multiple technologies on the market to remove PFAS from water and wastewater, however only technologies suitable for use with a brine line were considered.

Typical RO treatment systems work by passing high-pressure water through a semi-permeable membrane, concentrating the impurities in the water on the upstream side of the membrane and passing water molecules through the membrane. This typically results in two streams; one treated water stream with lower concentrations of PFAS and a second stream of a lower volume of brine with higher concentrations of PFAS. This could potentially require additional treatment to remove or destroy the PFAS molecules in the remaining brine. Due to these reasons and the high costs associated with RO, this process was not considered as an alternative.

IX systems work by passing water through a vessel of small beads coated with a charged functional group, which attracts oppositely charged ions in the water, such as PFAS. The PFAS ions are then exchanged with the negatively charged ions on the resin, effectively removing them from the water. The high TDS in the brine would render PFAS removal by ion exchange highly ineffective. Due to this reason, IX was not considered as an alternative.

Supercritical water oxidation (SCWO) is an advanced and environmentally sustainable thermal treatment process employed in the field of chemical engineering. Operating at temperatures and pressures above the critical point of water (374 °C, 22.1 MPa), SCWO facilitates the rapid and efficient destruction of organic contaminants in aqueous waste streams. In this supercritical state, water exhibits unique properties, enhancing its ability to solubilize and react with a wide range of organic compounds, converting them into benign end products such as water, carbon dioxide, and mineral ash. The process's efficacy in eliminating persistent pollutants makes it a promising technology

for addressing complex industrial and hazardous waste challenges, aligning with the growing demand for cleaner and more sustainable engineering solutions. SCWO is currently being evaluated by OC San, however, cost projections for a full scale PFAS treatment system are unavailable. Due to this reason, SCWO was not considered as an alternative.

Three alternatives were evaluated as approaches to PFAS treatment of the Brine Line and are listed below. Each treatment technology, with pre-treatment, is estimated to produce PFAS concentrations at or below federal drinking water MCLs. However, actual PFAS removal would need to be tested with actual Brine Line wastewater.

- **Alternative 1:** Novel Adsorbent System (NAS) – This process utilizes engineered granular adsorptive particles which act like a sponge, attracting and binding PFAS molecules to the engineered media. This is an adsorptive process that concentrates PFAS on the engineered media. The PFAS is then desorbed and concentrated onsite into a concentration tank and the media is regenerated and ready to be reused.
- **Alternative 2:** Electro-oxidation (EOX) System – This process utilizes reactors fitted with multiple anodes that PFAS are adsorbed onto the surface of, when charged, the anodes produce free electrons that break the carbon-fluorine bonds in PFAS resulting in the constituents of carbon dioxide (CO₂), hydrogen fluoride (HF), and fluoride (F⁻).
- **Alternative 3:** Granular Activated Carbon (GAC) – This process utilizes activated carbon which acts like a sponge, attracting and binding PFAS molecules to the GAC-media's surface area. This is an adsorptive process that concentrates PFAS on the activated carbon particles. It is unclear at this time if GAC will be an efficient treatment method, as GAC may need to be changed out more frequently based on the pre-treatment provided and the brine line constituents. This treatment alternative is included for comparison purposes.

Each alternative treatment system capacity is 15-mgd. Each alternative will be capable of treating PFAS species to meet the EPA proposed drinking water quality standards. This analysis assumes that each treatment system will treat brine at one central location near Reach IV.

A specific site for the proposed alternatives is not identified in this section. Rather, the alternative treatment types are introduced, and site area requirements are developed. Each alternative discussed in this section could be constructed at any location, provided area requirements are satisfied. Alternative 1 (NAS) can be fit into 0.4 acres and Alternative 3 (GAC) can be fit to 0.52 acres with similar configurations. Alternative 2 (EOX) requires approximately seven (7) acres. Refer to Sections 6.4.5.1, 6.4.5.2, and 6.4.5.3 to see a schematic representation of the potential plant layouts.

A new lift station will be required. The pump station would be connected to the new treatment by a new force main. Treated water from the new proposed treatment system would be connected to the existing Brine Line by a new gravity pipe. The proposed pump station and force main will be discussed in further detail in a later section.

6.4.5.1 Novel Adsorbent System

A Novel Adsorbent System (NAS), manufactured by CycloPure, was evaluated as an alternative treatment method for treating PFAS from brine line. The NAS system, shown in **Figure 6-4** and **Figure 6-5**, consists of a skid with multiple treatment vessels. Each vessel contains an engineered adsorbent particle-based media for PFAS removal. The particles are small and cup-shaped, making them ideal for binding PFAS to the particle bodies. Over time, the media accumulate solids and the differential pressure across the vessel reaches 16 psi. At this point, a short backwash cycle (1.6 bed volumes) is initiated to remove the accumulated solids and reduce the differential pressure back down to less than 2 psi. NAS has demonstrated effective removal of PFAS in similar matrices with high TDS, such as metal-plating wastewater (~5,000 mg/L). Advantages of the NAS system typically include a smaller system footprint, lower media volume and longer operational life when compared to GAC treatment systems. A potential disadvantage of this system is the high cost associated with replacing media.




Figure 6-4 Novel Adsorbent Treatment System Example (courtesy of CycloPure)

Figure 6-5 illustrates the components and potential schematic layout of brine line treatment using the CycloPure treatment process. This is one potential layout which could be modified during the design process.

Brine from the Brine line is pumped via a new lift station to the NAS facility. At the NAS facility, the brine is pretreated to remove suspended solids (e.g., cartridge filtration, dissolved air flotation (DAF), or sand filtration). Pretreated brine then passes through the NAS vessels, configured in five parallel lead-lag systems, for PFAS removal. Each lead-lag system contains approximately 62.6 tons of dry granular engineered media, providing an empty bed contact time (EBCT) of approximately 15 minutes. The treated brine would then flow from the NAS vessels back out to the Brine line via a gravity pipeline.

Figure 6-5 Proposed NAS Site Layout



Based on the 15-mgd capacity of the proposed treatment system, it is estimated that a site of approximately 0.4 acres (120 ft x 150 ft) would be required. The vessels shown in Figure 6-5 would be at existing grade. The proposed system is designed in a lead-lag configuration consisting of five parallel systems for PFAS treatment, each vessel is 26 ft high and 12 ft diameter. Suspended solids pretreatment is required prior to the NAS treatment system. Refer to **Appendix B** for sizing and operational treatment plant performance.

6.4.5.2 Electro-oxidation System

Electro-oxidation (EOX) treatment system, manufactured by Aclarity, was evaluated as an alternative treatment method for treating PFAS from the brine line. The EOX system, shown in **Figure 6-6** and **Figure 6-7**, consists of a skid with multiple EOX vessels mounted to it. Each EOX vessel contains multiple titanium anodes. To ensure optimal efficiency, the EOX system is combined with a pre-treatment process to concentrate PFAS prior to treatment. These EOX systems work best with high concentration and low flows. A foam concentrator is typically used for pre-treatment in combination with 100-micron filtration units. The EOX system destroys PFAS based on a Watt-hour per gallon basis. Over time the anodes in the treatment vessels develop minor fouling, as the anodes foul, the amperage through the vessel drops and when this amperage reaches 90% of the baseline amperage the anodes must be cleaned. Cleaning at the point of reduced amperage requires the vessels to be run at reverse polarity. Additional, more in-depth cleaning is required monthly, where hydrochloric acid is run through the vessels in a flow-through method. Advantages of the EOX system include a potential ability to destroy PFAS with lower energy demands unlike NAS and GAC. Disadvantages of this system include the potential generation of toxic byproducts and incomplete destruction of some PFAS species. Moreover, the flow rate through each skid is low, therefore a large number of skids would be required. PFAS concentrations can be increased via preconcentration (e.g., foam fractionation), which would reduce the number of skids and the system footprint, however this is not cost effective. Currently there are no economically feasible concentration technologies on the market to reduce the required quantity of EOX skids.



Figure 6-6 Example of EOX Treatment System (courtesy of Aclarity)

Figure 6-7 illustrates the components and potential schematic layout of brine line treatment using the Aclarity treatment process. This is one potential layout which could be modified during the design process.

Brine from the Brine line is pumped via a new lift station to the EOX facility. At the EOX facility, the brine is passed through EOX skids for PFAS removal. Each EOX skid contains (8) parallel reactors, power supply, pumps, HMI, and controls. An influent flow meter is used upstream of the system to monitor incoming flow and to control the treatment level being applied. The treated brine would then flow from the EOX skids back out to the Brine line via a gravity pipeline.

Figure 6-7 Proposed EOX Site Layout



It is estimated that a site of approximately 7 acres (550 ft x 550 ft) would be required, based on the proposed treatment capacity of 15-mgd. The site will include a total 2,100 skids under the assumption that skids can be stacked on top of each other. Skids would be operated in parallel. If brine flow rates would increase to 30-mgd, the required area for AOX treatment would be approximately 14 acres. Refer to **Appendix C** for sizing and operational treatment plant performance.

The number of skids and site size can be decreased through brine concentration. Aclarity has identified an ideal concentration factor between 1,000 and 10,000. Existing concentration technologies include Foam Fractionation, Reverse Osmosis, Dissolved Air Flotation, and thermal concentration/evaporation. The recommended concentration technology from Aclarity is Foam Fractionation. Dudek reached out to multiple concentrator manufacturers and has confirmed that available foam fractionation systems on the market are not able to provide the desired level of concentration at the 15-mgd flow rate. This analysis assumes that the EOX treatment will not include a concentrator.

6.4.5.3 Granular Activated Carbon

A Granular Activated Carbon (GAC) system was evaluated as an alternative treatment method for treating PFAS from the brine line. The GAC system, shown in **Figure 6-8** and **Figure 6-9**, consists of multiple treatment vessels. Each vessel contains granular activated carbon. To ensure optimal efficiency, the GAC vessels are designed to provide adequate contact time at the given flow rate of 15-mgd. Over time the GAC performance decreases with the accumulation of soluble and particulate materials onto and into the media. As the media becomes saturated and the performance decreases, replacement of the media is required. Advantages of the GAC system include a potentially lower capital costs compared to other treatment processes. One of the major disadvantages is the high operating cost related to media replacement. A Calgon GAC system was evaluated in the analysis, however this equipment is available from multiple manufacturers with similar configurations.




Figure 6-8 Example of GAC Treatment System (courtesy of Calgon)

Figure 6-9 illustrates the components and potential schematic layout of brine line treatment using a GAC treatment process. This is one potential layout which could be modified during the design process.

Brine from the Brine line is pumped via a new lift station to the GAC facility. At the GAC facility, the brine is passed through pre-treatment filters to remove suspended solids. Effluent from the filters then passes through the GAC vessels, configured in five parallel lead-lag systems, for PFAS removal. Each lead-lag system contains approximately 479.5 tons of GAC, providing a contact time of approximately 10.6 min per vessel. The treated brine would then flow from the GAC vessels back out to the Brine line via a gravity pipeline.

Figure 6-9 Proposed GAC Treatment System Site Layout



Based on the 15-mgd capacity of the proposed GAC treatment system, it is estimated that a site of approximately 0.52 acres would be required. The GAC vessels shown in Figure 6-9 can be constructed at grade. Refer to **Appendix D** for sizing and operational GAC treatment performance.

6.4.6 PFAS Treatment Cost Comparisons

The purpose of this section is to compare three (3) alternative approaches to Brine Line treatment in the Inland Empire (Location Reach IV). The following opinion of probable cost serves to establish an order of magnitude cost for the 15-mgd project alternatives. The cost opinion is based on the quantities and unit price estimates of treatment process developed from planning level concepts and preliminary vendor quotes. A more detailed cost information analysis would be developed during preliminary design.

6.4.6.1 Cost Opinion Methodology and Assumptions

For the purposes of this analysis, the cost opinion is a Class 5 Association for the Advancement of Cost Engineering (AACE) Construction Cost Opinion, based on the concept screening analysis. A Class 5 Construction Cost Estimate is known as the rough order of magnitude (ROM) estimate. It is used for the initial screening projects for capital expenditure planning. The cost opinion makes use of quantity takeoffs, vendor/supplier/manufacture quotations, and recent data in the development of projected costs. Other general assumptions in construction cost analysis include:

- Escalation to Midpoint of 5% of construction subtotal per year
- Construction contingency of 40% of construction subtotal
- Cost of land acquisition is not included in the analysis
- O&M contingency of 40% of O&M costs
- Engineering soft costs is 25% of total construction cost
- Engineering easement and permitting is 25% of total construction cost
- General requirements are estimated to be 10% of total construction cost.
- Installation of civil piping is estimated to be 10% of total construction cost.
- Installation of electrical equipment is estimated to be 13% of total construction cost.
- Installation of instrumentation is estimated to be 3% of total construction cost.

6.4.6.2 Construction and Lifecycle Cost Analysis

A 10-year lifecycle cost model calculates capital and O&M costs for each alternative and expresses them in net present worth for comparison (see Section 6.4.7 for the costs summary). Unit O&M costs are escalated by an annual inflation rate of 3%. The present worth values of the annual loan payments and annual O&M costs are discounted at a rate of 5%, as summarized in **Table 6-7** below.

Table 6-7: Lifecycle Cost Model Input

| Parameter | Units | Value |
|--------------------|-------|-------|
| Starting Year | - | 2024 |
| Ending Year | - | 2033 |
| Load Duration | yr | 10 |
| Loan Interest Rate | %/yr | 3 |
| Discount Rate | %/yr | 5 |
| Inflation Rate | %/yr | 3 |

6.4.6.3 Novel Adsorbent System Costs

Alternative 1 evaluates NAS with a total brine wastewater treatment capacity of 15-mgd. Treated brine is estimated to contain PFAS concentrations at or below federal drinking water MCLs. This system includes: a lift station with a total of five (5) pumps (200 HP each), suspended solids pre-treatment, five parallel lead-lag vessels, interconnecting piping, as well as structural and electrical work. Refer to **Table 6-8** for detailed information about the Class 5 construction cost estimate.

Table 6-8: Novel Adsorbent System Construction Cost Range

| Cost Item Description | Alternative 1 Novel Adsorbent System |
|---|---|
| Total Capital Cost | \$100 million |
| AACE Class 5 Estimate, Low (-50% to -20%) | \$50 million to \$80 million |
| AACE Class 5 Estimate, High (+30% to +100%) | \$130 million to \$200 million |

Annual O&M costs were developed using a vendor quotation, engineering judgment, and proposed vendor budgetary Service Agreement services as a baseline. Major assumptions include:

- Cost of power is \$0.2 per kilowatt-hour (kWh).
- Cost of media is \$38.56 per pound, including spent media handling and PFAS waste disposal by destruction technologies.
- A total mass of 313 tons of engineered media is required, with 31.3 tons of engineered media in each vessel to provide a 15-minute EBCT at a flow rate of 2,083 gpm (3-mgd) per lead-lag system.
- Assumed media replacement frequency for the lead vessel in each parallel lead-lag system (5 vessels in total) is estimated to be every 4 months to remove PFAS below EPA drinking water MCLs. PFOS can be removed to < 4 ng/L for 67 weeks and PFOA can be removed to < 4 ng/L for 17 weeks. In this scenario, media replacement frequency is driven by PFOA breakthrough estimates.
- Maintenance and labor costs are estimated to be 10% of total equipment cost.
- Single point of responsibility for maintenance. Costs for PFAS sampling on bi-weekly basis are included.
- Standard maintenance services are included.
- 40% contingency for media cost, maintenance, and labor costs due to inherent uncertainties, potential market fluctuations, and unforeseen events that may impact the operation and maintenance costs associated with the system.

Table 6-9 lists O&M for Novel-Adsorbent System below.

Table 6-9: O&M Cost Estimate for Novel Adsorbent System

| O&M Cost Item Description | Quantity | | Engineering Estimate | |
|---|-----------|--------------------------|----------------------|----------------------|
| | Number | Unit | Unit Cost | Total |
| Power, Year 2024 | 5,300,000 | kWh | \$0.20 | \$1,060,000 |
| Media Cost, Year 2024 | 626,000 | Total lbs/vessels/change | \$38.56 | \$72,400,000 |
| Maintenance + Labor, Year 2024 | 1 | - | \$2,100,600 | \$2,110,000 |
| Contingency | 1 | - | 40% | \$30,228,000 |
| Total Annual O&M Cost, Year 2024 | | | | \$105,110,000 |
| 10-Year Present Worth O&M Cost | | | | \$915,100,000 |

The annual O&M unit cost for a NAS was identified as approximately \$0.02 per gallon, which is a total cost of \$290,000 per day at 15-mgd. The total annual O&M cost is equivalent to \$105,400,000 per year while a ten-year present worth O&M cost is approximately \$915,100,000.

6.4.6.4 Electro-Oxidation System Costs

Alternative 2 evaluates EOX with a total brine wastewater treatment capacity of 15-mgd. Treated brine is estimated to contain PFAS concentrations at or below federal drinking water MCLs. Aclarity operates on a leasing model for its equipment, and there is no purchasing option available. Therefore, the construction cost estimate for this alternative includes cost of a lift station with a total of four (4) pumps (35 HP each), interconnecting piping, shade structure, and new electrical service. Refer to Table 6-10 for detailed information about the Class 5 construction cost estimate.

Table 6-10: Electro-Oxidation System Construction Cost Range

| Cost Item Description | Alternative 2 Electro-Oxidation System |
|---|--|
| Total Capital Cost | \$156 million |
| AACE Class 5 Estimate, Low (-50% to -20%) | \$78 million to \$125 million |
| AACE Class 5 Estimate, High (+30% to +100%) | \$203 million to \$313 million |

Note: All pricing is based on site conditions and desired results.

Annual O&M cost estimate includes a present worth of leasing equipment, anode replacement (7-10 year), financing, labor, engineering support, and \$0.2 per kWh power cost.

Table 6-11 lists O&M for EOX System below.

Table 6-11: O&M Cost Estimate for Electro-Oxidation System

| O&M Cost Item Description | Quantity | | Engineering Estimate | |
|---|-----------|--------|----------------------|------------------------|
| | Number | Unit | Unit Cost | Total |
| Power, Year 2024 ¹ | 5,300,000 | kWh/yr | \$0.20 | \$140,000 |
| Equipment Lease, Year 2024 | 1 | LS | - | \$542,100,000 |
| Total Annual O&M Cost, Year 2024 | | | | \$542,240,000 |
| 10-Year Present Worth O&M Cost | | | | \$4,396,100,000 |

Note: All pricing is based on site conditions and desired results.

¹ Estimated cost of power for lift station.

The annual O&M unit cost for EOX was identified as approximately \$0.01 per gallon, which is a total cost of \$1,485,000 per day at 15-mgd. The total annual O&M cost is equivalent to \$542,170,000 per year while a ten-year present worth O&M cost is approximately \$4.4 billion.

6.4.6.5 Granular Activated Carbon Costs

Alternative 3 evaluates GAC with a total brine wastewater treatment capacity of 15-mgd. Treated brine is estimated to contain PFAS concentrations at or below federal drinking water MCLs. This system includes: a lift station with a total of five (5) pumps (200 HP each), suspended solids pre-treatment, six parallel lead-lag systems, interconnecting piping, as well as structural and electrical work. Refer to Table 6-12 for detailed information about the Class 5 construction cost estimate.

Table 6-12: Granular Activated Carbon System Construction Cost Range

| Cost Item | Alternative 2 Granular Activated Carbon |
|---|---|
| Total Capital Cost | \$55 million |
| AACE Class 5 Estimate, Low (-50% to -20%) | \$28 million to \$44 million |
| AACE Class 5 Estimate, High (+30% to +100%) | \$72 million to \$110 million |

- Annual O&M costs were estimated using vendor quotations, engineering judgment, and proposed vendor budgetary Service Agreement services as a baseline. Major assumptions include:
 - Cost of power is \$0.2 per kWh.
 - Assumed media replacement frequency is estimated to be every 4 months to remove PFAS below EPA drinking water MCLs.
 - Cost of media is \$3.00 per pound including cost for Resource Conservation and Recovery Act (RCRA) Hazardous and CA Hazardous waste fee for spent carbon that can be potentially reactivated.
 - Maintenance and labor costs are estimated to be 10% of total equipment cost.
 - Costs include return freight of the spent carbon to a reactivation facility.
 - 40% contingency for media cost, maintenance, and labor costs due to inherent uncertainties, potential market fluctuations, and unforeseen events that may impact the operation and maintenance costs associated with the system.

Table 6-13 lists O&M for GAC System below.

Table 6-13: O&M Cost Estimate for Granular Activated Carbon System

| O&M Cost Item Description | Quantity | | Engineering Estimate | |
|---|-----------|--------------------------|----------------------|---------------------|
| | Number | Unit | Unit Cost | Total |
| Power, Year 2024 | 3,920,000 | kWH/yr | \$ 0.20 | \$784,000 |
| Media Cost, Year 2024 | 48,000 | Total lbs/vessels/change | \$3.25 | \$4,680,000 |
| Maintenance + Labor, Year 2024 | 1 | LS | \$1,401,900 | \$1,410,000 |
| Contingency | 1 | LS | 40% | \$2,750,000 |
| Total Annual O&M Cost, Year 2024 | | | | \$9,640,000 |
| 10-Year Present Worth O&M Cost | | | | \$83,600,000 |

The annual O&M unit cost for GAC was identified as approximately \$0.002 per gallon, which is a total cost of \$20,000 per day at 15-mgd. The total annual O&M cost is equivalent to \$9.6 million per year while a ten-year present worth O&M cost is approximately \$83.6 million.

6.4.7 PFAS Treatment Costs Summary

The treatment cost summary, including life cycle costs in terms of present worth, is presented below in Table 6-14. Life cycle cost assumptions are provided in Section 6.4.6.2. These costs assume that each treatment technology will meet or exceed federal drinking water limits for PFAS.

Table 6-14: PFAS Treatment Costs Summary

| Item | Alternative 1: Novel Adsorbent Media | Alternative 2: EOX System ³ | Alternative 3: Granular Activated Carbon |
|--|--|--|--|
| 10-Year Capital Net Present Worth ^{1,2} | \$95 million | \$149 million | \$52 million |
| 10-Year O&M Net Present Worth | \$918 million | \$4.4 billion | \$84 million |
| Total 10-Year Net Present Worth | \$1 billion | \$4.5 billion | \$136 million |
| Key non-monetary considerations | Smaller system footprint and longer operation life when compared to other alternatives | Provides flexibility, continuous support, and the latest technology upgrades without the financial commitment of equipment ownership | Proven conventional treatment for PFAS |

Notes:

- ¹ Present worth based on 10-years at discount rate of 5%.
- ² Construction Cost includes 10-year loan at 3%.
- ³ Construction Cost includes 10-year loan at 3%.

6.4.8 Potential for PFAS Treatment Cost Reduction

This section provides construction and O&M cost estimates based on assumed higher effluent PFAS limits of 5 (Scenario 1) to 10 (Scenario 2) times the current drinking water PFAS MCLS of 4 ppt. Smaller, side-stream PFAS treatment systems would produce non-detect treated PFAS concentrations. The PFAS-free treated stream would

be blended with untreated brine to achieve the assumed higher PFAS limits. **Table 6-15** represents a compilation of the 10-year capital net present worth, 10-year O&M net present worth, and the total (capital and O&M) net present worth for the three treatment facilities.

Table 6-15: PFAS Treatment Costs Reduction Summary¹

| Item | Alternative 1: Novel Adsorbent Media | Alternative 2: EOX System ² | Alternative 3: Granular Activated Carbon |
|--|--|---|--|
| 10-Year Capital Net Present Worth ^{3,4} | \$70 - 83 million | \$109 - 129 million | \$39 - 46 million |
| 10-Year O&M Net Present Worth | \$674 - 796 million | \$3.3 - 3.9 billion | \$62 - 73 million |
| Total 10-Year Net Present Worth | \$744 - 879 million | \$3.4 - 4 billion | \$100 - 118 million |

Notes:

- ¹ Ranges in costs based on values for Scenario 1 (PFAS limit of 5x the drinking water MCL) to Scenario 2 (PFAS limit of 10x the drinking water MCL).
- ² Construction Cost includes 10-year loan at 3%.
- ³ Present worth based on 10-years at discount rate of 5%.
- ⁴ Construction Cost includes 10-year loan at 3%.

Key Findings: For the two assumed scenarios, the construction unit cost of a 15-mgd novel adsorbent media treatment facility was estimated to be approximately \$6 million per-mgd. Therefore, the total 10-year capital present worth cost is estimated to be between \$70 million and \$83 million. Compared to previous analysis, this could potentially decrease costs between 13% and 26%. The 10-year O&M net present worth cost is estimated to be approximately \$61 million per-mgd, resulting in a total cost of approximately \$674 million to \$790 million.

For the two assumed scenarios, the construction unit cost of a 15-mgd EOX treatment facility was estimated to be approximately \$9.9 million per-mgd. Therefore, the total 10-year capital present worth cost is estimated to be between \$109 million and \$129 million. Compared to previous analysis, this could potentially decrease costs between 13% and 27%. The 10-year O&M net present worth cost is estimated to be approximately \$293 million per-mgd, resulting in a total cost of approximately \$3.3 billion to \$3.9 billion.

For the two assumed scenarios, the construction unit cost of a 15-mgd granulated activated carbon treatment facility was estimated to be approximately \$3.5 million per-mgd. Therefore, the total 10-year capital present worth cost is estimated to be between \$39 million and \$46 million. Compared to previous analysis, this could potentially decrease costs between 12% and 25%. The 10-year O&M net present worth cost is estimated to be approximately \$5.6 million per-mgd, resulting in a total cost of approximately \$62 million to \$73 million.

6.4.9 PFAS Management Recommendations

Given the complexities associated with removing PFAS species in the brine line, limited availability of detailed water quality data, and the uncertainties surrounding PFAS regulations in brine, it is recommended to:

- Collect wastewater samples from individual dischargers to identify relative contributions of PFAS to the Brine Line. It may be more economical to remove PFAS from a few select dischargers rather than treating the entire Brine Line flow at a centralized treatment facility.
- Evaluate the viability of point source PFAS treatment using a smaller scalable system, after performing PFAS sampling from individual dischargers.

- Conduct a pilot study to better inform estimates of full scale PFAS treatment requirements and costs. This approach is considered the most effective means to estimate long-term consumption rates, including factors such as rapid kinetics, high treatment capacity, resistance to fouling, media lifetime, and concentration of PFAS waste. Additionally, it is important to note that equipment sizing depends on various factors, e.g., hydraulic rates, and a pilot study is essential to assess these specific needs for optimal equipment selection, performance, and cost.
- Continue to monitor PFAS regulations as they pertain to wastewater disposal and operations at OC San.

INTENTIONALLY LEFT BLANK

7 Brine Line Multi-Use Benefits

7.1 Overview

As part of this Master Plan effort, SAWPA has maintained an interest and desire to conduct its regional activities in a manner that supports both the Santa Ana Watershed and the people that live and work within its boundaries. The One Water One Watershed (OWOW) program illustrates this concept. The purpose of the OWOW program is to encourage integrated management of water resources and provide funding for multi-benefit projects that support watershed sustainability. OWOW has been part of the California Department of Water Resources Integrated Regional Water Management (IRWM) Program and now part of the California’s Integrated Climate Adaptation and Resiliency Program (ICARP), which promotes collaborative planning and water resource management. The OWOW program integrates different disciplines such as: water supply, water quality, recycled water, stormwater management, water use efficiency, land use, energy use, climate change, and habitat, while Disadvantaged Communities and Native American tribal community water issues receive special focus. Through this integration, regional participants conduct planning and produce shared goals and integrated projects. When it comes time to implement projects, because the plan was crafted together, those projects have multiple benefits that reflect the interests of the entire community.



California's ICARP is an initiative designed to address the impacts of climate change through coordinated and comprehensive adaptation and resilience strategies. Established by the state, ICARP aims to integrate climate adaptation planning and implementation efforts across different levels of government and sectors, fostering collaboration among state agencies, local governments, and other stakeholders. The ICARP program facilitates coordination among various state agencies to ensure a unified approach to climate adaptation and resilience, as well as providing guidance and support to local governments for development and implementation of their own climate adaptation plans. ICARP also provides tools and resources to help local governments and communities develop effective adaptation strategies, with a council of experts and practitioners that provides guidance and recommendations on climate adaptation policies and practices. ICARP includes grant programs to fund local and regional adaptation projects, helping communities enhance their resilience to climate impacts, while encouraging leveraging of state and federal funds to maximize the impact of adaptation investments. ICARP represents California's commitment to proactive and integrated climate adaptation, recognizing that effective resilience planning requires collaboration, innovation, and a comprehensive approach to addressing the complex challenges posed by climate change.

SAWPA Roundtables, also known as Task Forces, provide a forum for joint water resource management to address watershed issues and regulatory compliance. The SAWPA Roundtables operate under formal and informal agreements, often with the Santa Ana Regional Water Quality Control Board as a member and are designed to work cooperatively with the regulated community to address water quality issues. The Roundtables have a long and

strong track record of partnerships with organizations with shared interests pursuing overall watershed sustainability. The Roundtables create shared value between regulators, regulated parties, and SAWPA Member Agencies by facilitating stakeholder collaboration, producing significant savings through joint efforts that address water management issues.

Climate change, extended periods of drought, and other weather extremes occur more frequently. Recent research released by the University of California, Los Angeles, identified recent drought conditions in the American West to be the worst 22-year dry-period in at least 1,200 years. The typical response to worsening drought conditions are declared a water shortage emergency and orders for outdoor usage restrictions. SAWPA's work in the Santa Ana River Watershed advances projects and programs that build water resiliency and promote collaborative, innovative responses to water planning, all of which help address drought conditions.

In an effort to further benefit the Santa Ana Watershed, SAWPA conducted a feasibility study in 2020 to assess the potential benefits of cloud seeding in increasing water supply in the Santa Ana River Watershed. SAWPA is conducting a pilot program to investigate these potential regional benefits. Cloud seeding is used to increase the amount of precipitation, including snow or rain, during the storm season. The process works through releasing particles of silver iodide into clouds, which increase the chances of droplet condensation. The effort is an example of SAWPA's commitment to multi-use benefits for the watershed and the Southern California region.

7.2 Brine Line is a Multi-Use Benefit System

The Brine Line is a significant example of a multi-use benefit system that integrates water management and environmental stewardship with economic efficiency. The Brine Line transports brine from inland desalination and water recycling facilities, as well as regional industrial discharges. The Brine Line exemplifies the concept of multi-use benefits in several ways, as discussed in the subsequent sections.

7.2.1 Brine Management

A primary goal of the Brine Line System is to provide a cost-effective and environmentally responsible solution for disposing of brine generated by inland dischargers. By transporting brine to the ocean, the Brine Line relieves the need for inland disposal operations that would be costly and potentially harmful to local ecosystems. In this manner, the Brine Line helps mitigate environmental impact associated with brine disposal throughout the Santa Ana River Watershed, including potential groundwater contamination or soil salinization. By exporting brine from the watershed, the Brine Line System minimizes regional risk, while promoting water management and production for regional consumers.

7.2.2 Stormwater Capture

Rain and snowmelt wash pollutants from streets, construction sites, and other lands into storm drains and ditches. Eventually, these stormwater facilities discharge directly into streams and rivers, typically with no treatment. The Riverside County Flood Control and Water Conservation District (Flood Control District) developed a Stormwater Resource Plan (SWRP) for the Riverside County portion of the Santa Ana River Watershed. The SWRP development process included involvement from various stakeholders. The State Water Resources Control Board provided their consensus letter to the Flood Control District, approving its SWRP. The SWRP leverages ongoing cooperative water management planning efforts in the Planning Area, including the Integrated Regional Water Management (IRWM) Program. The IRWM Program, administered in the Santa Ana River Watershed (SARW) Region by SAWPA, supports a regional understanding of water resources, advances regional water projects, and maximizes project benefits

through agency collaboration and integration. The SARW IRWM Program's OWOW Plan is a key document referenced in this SWRP.

Recommended stormwater management strategies developed by stakeholders and included in the OWOW Plan recognize the importance of stormwater as a watershed resource and highlight the potential to preserve areas for open space, habitat, and natural hydraulic functions through floodplain management. Several nonprofit organizations participated in the OWOW Plan, particularly through identification of habitat restoration and water quality improvement strategies and projects. Environmental stewardship organizations in the SARW are identified in Table 2.1-6 of the OWOW Plan, several of which are working on stormwater and dry weather resource planning. Capture of dry weather runoff, often referred to as "urban drool," from urban communities offers several positive benefits, including:

- **Water Quality Improvement:** Capturing low flow runoff helps reduce the quantity of pollutants, such as oils, heavy metals, and nutrients, entering natural water bodies, leading to improved water quality in rivers, lakes, and coastal areas.
- **Flood Mitigation:** Capturing and managing runoff, reduces the risk of flooding in urban areas, thereby protecting infrastructure, property, and natural habitats.
- **Groundwater Recharge:** Capturing runoff allows for the water to infiltrate into the ground, which helps replenish groundwater supplies.
- **Ecosystem Support:** Reducing the flow of pollutants and sediments into natural water bodies protects and supports aquatic ecosystems, maintaining biodiversity and ecological balance.
- **Urban Heat Island Mitigation:** Properly managed runoff can be used in green infrastructure projects, such as green roofs and urban green spaces, to help reduce the urban heat island effect and improve overall urban climate conditions.
- **Sustainable Water Management:** Capturing and reusing runoff can contribute to sustainable water management practices by reducing the reliance on potable water for non-potable uses, such as irrigation and industrial processes.
- **Economic Benefits:** Reducing flood damage, improving water quality, and enhancing urban environments lead to economic benefits, including increased property values and savings on water treatment and flood control infrastructure.
- **Aesthetic and Recreational Improvements:** Properly managed runoff creates attractive urban landscapes, parks, and recreational areas, enhancing the local quality of life.

Overall, capturing dry weather runoff from urban communities is a crucial component of integrated water management strategies aimed at creating more resilient, sustainable, and livable urban environments. The Flood Control District and SAWPA project approximately 2,000,000 gpd of dry weather flow diverted to the Brine Line system, thereby protecting the Santa Ana River Watershed from potential dry weather pollutants. The County of Riverside has identified these potential flows as high in TDS, and removal is proposed to protect the environment.

7.2.3 Water Reuse (Recharge, IPR, DPR)

Water reuse and conservation play critical roles in sustainable water management, particularly in regions facing water scarcity and increasing demands from growing populations and economic activities. Types of water reuse include treating wastewater to levels suitable for irrigation, industrial processes, groundwater recharge, or now potable (drinking) water production (DPR). Augmentation of regional water supplies using treated wastewater expands available water resources, reducing reliance on imported or local freshwater sources and mitigating the diverse impacts of water scarcity. During droughts or periods of reduced water availability, water reuse provides a dependable and drought-resistant water supply for non-potable applications. Water reuse has been shown to be a cost-effective alternative to development of new water sources or expanding existing infrastructure, especially in southern California where demand for water is high. Water reuse also reduces discharge of treated effluent to natural water bodies, minimizing potential pollution and protecting aquatic ecosystems.

Water reuse and conservation can be implemented in many forms. Many municipalities and other regional agencies implement water reuse to meet non-potable water demand, such as landscape irrigation, street cleaning, and other industrial processes. Treated wastewater is also used for agricultural irrigation, reducing the need for potable water importation or potential depletion of regional surface or ground water resources. Many industries use recycle and reuse process water to decrease operational cost and their perceived environmental footprint. Recycled water, when injected into aquifers for groundwater replenishment, helps sustain groundwater levels and prevent saltwater intrusion in coastal regions. The Brine Line system, as a regional facility, supports a variety of water recycling and desalination activities throughout the Santa Ana River Watershed, and therefore is a multi-use benefit facility to many regional and local communities.

7.2.4 Water Conservation

Water conservation focuses on reducing water consumption through efficient technologies, practices, and regional water use changes. Conserving water reduces overall demand, preserving water resources for future uses and minimizing need for costly infrastructure expansions. Pumping, treating, and distributing water requires energy. By conserving water, energy consumption associated with water supply and treatment processes is reduced. Furthermore, conserving water protects aquatic habitats, sustains natural river flow, and reduces the carbon footprint associated with regional water management activities.

Water conservation activities include a wide variety of regional and local actions. Membrane filtration (e.g., reverse osmosis, ultrafiltration), ultraviolet disinfection, and advanced oxidation processes are used to treat wastewater to high-quality standards suitable for reuse, as well as for desalination of impaired groundwater resources. Use of water-efficient fixtures (e.g., low-flow toilets, faucets, and showerheads), implementing smart irrigation systems, and promoting water-wise landscaping techniques contribute to water conservation efforts. Governmental agencies implement policies and regulations to promote water reuse and conservation, such as water recycling mandates, water-use efficiency standards, and incentives for adopting water-saving technologies. The Brine Line System provides a means of producing needed regional water supplies, with SAWPA's focus on regional water management makes them a leader in the area of water management and conservation.

7.2.5 Public Awareness and Education

SAWPA, through its operation and management of the Brine Line System conduct many public awareness and educational activities. Public outreach and education campaigns raise awareness about the importance of water reuse and conservation, encouraging individuals and businesses to adopt water-saving practices. Collaboration among stakeholders including governmental agencies, water utilities, industries, and non-profit organizations

fosters innovation and implementation of effective water reuse and conservation strategies. Water reuse and conservation are integral components of sustainable water management strategies aimed at enhancing water security, protecting the environment, and promoting resilience in the face of climate change and population growth (multi-use benefit).

7.2.6 Environmental Protection & Regulatory Compliance

The Brine Line System enables the construction of regional desalination facilities, as well as assisting these plants in complying with environmental regulations governing brine disposal, ensuring that ultimate disposal of the brine meets stringent quality standards and assuring the regional community of needed water resources. By removing salt loading from the Santa Ana River Watershed, the SAWPA minimizes impacts on inland water bodies and ecosystems, preserving local habitats and biodiversity.

Facility management of the Brine Line System involve collaboration among many governmental agencies, water utilities, private companies, and environmental organizations. This multi-stakeholder approach ensures that the system is managed in a sustainable and socially responsible manner. The Brine Line exemplifies the concept of a multi-use benefit system by addressing complex water management challenges while fostering economic development and environmental stewardship. The existence of the Brine Line underscores the potential of integrated approaches to water infrastructure that maximize resource efficiency, sustainability, and regional water management in water-stressed southern California region.

7.3 Multi-Use Benefits in Water Projects

In June 2020, the Pacific Institute issued a guidebook focused specifically on the integration of multiple benefits into water projects. The following discussions are excerpts from the Pacific Institutes guidebook, provided to broaden understanding and integration of multi-benefit thinking into various components of water management practices.

There is general agreement that climate change, our aging water infrastructure, and population growth require investment into water systems, as well as the environment. Typically, such investments can include infrastructure repair, replacement and rehabilitation, watershed restoration, overall energy and efficiency improvements, and stormwater management addressing flood risk, water quality, and water supply needs. Many of these strategies provide important community benefits, in the form of reducing energy use or greenhouse gas emissions, as well as providing improved habitat and enhanced community benefit. While the importance of multi-benefit projects is understood, these benefits are typically added at the end of projects. Integrating multi-benefit components into the decision-making process allows development of partnerships that can leverage resources and garner public support. The Pacific Institute's workbook identifies the following multi-benefit process that can benefit a water agency:

- Provide an objective and transparent basis for comparison of water management options
- Identify opportunities for shared cost between project beneficiaries
- Identify design improvements that leverage added value and benefit
- Engage stakeholders to improve public and community support
- Optimize investment of time, money, and other resources
- Increase investment in communities, while identifying and managing unintended consequences

7.3.1 Multi-Benefit Framework

To increase consideration of multi-benefits, the Pacific Institute collaborated with various partners to define a framework that promotes incorporation of co-benefits into water infrastructure and management decisions. In turn, water managers identify potential project partners and/or opportunities, thereby enhancing project design to maximize value. This framework is outline in **Figure 7-1** and includes four steps:

Step 1: Envision the Project. Define the project vision and determine potential project options, including identifying goals and potential alternatives, as well as identifying relevant stakeholders.



Figure 7-1 Multi-Benefit Framework Steps to Inform Water Management Decisions (Pacific Institute, 2020)



Figure 7-2 Benefit Themes (Pacific Institute, 2020)

Step 2: Identify Benefits & Trade-Offs. Determine potential benefits and trade-offs, even if outcomes can't be quantified. To facilitate the process, Pacific Institute defined five benefit themes as shown on **Figure 7-2**.

Step 3: Characterize Key Benefits & Trade-Offs. Characterize benefits and trade-offs toward greatest interest to stakeholders, including methods of evaluating the benefits/trade-offs, as well as setting the baseline for project comparison and uncertainty.

Step 4: Inform Decision Making. Inform decision making by communicating results to stakeholders. As a result of effectively communicating, decision makers are equipped to make more informed and transparent decisions.

Investments in water management provide multiple benefits to communities, the economy, and the environment. However, those benefits are realized when water managers actively incorporate them into a project design and implementation. Identifying and evaluating multi-benefit solutions is just the beginning. Figure 7.2 highlights the interconnectivity of various benefit themes.

Scaling these strategies into sustained effort toward multiple benefit results and developing long-term policy and program level decision making is the ultimate goal. For a project, multiple benefits can be used to evaluate the “business case” for a project or provide insight into project design to maximize the benefit. At a program level, water managers may prioritize funding among various projects. At a policy level, multiple benefits help determine strategic direction that provides benefit to customers and community members.

7.4 Multi-Use Benefit Considerations

Considering multi-use benefits in water systems involves recognizing and leveraging the interconnected nature of water resources for various purposes, beyond their traditional uses. This approach acknowledges that water is a resource that can simultaneously support multiple needs and activities, including agricultural irrigation, domestic water supply, industry, hydropower generation, ecosystem services, recreation, and environmental conservation. The principles of multi-use benefits are also directly applicable to brine management and transport systems, particularly in the context of desalination plants and industries that produce concentrated non-reclaimable waste streams (brine). Brine management presents unique challenges as a result of its high salinity and potential environmental impacts. With respect to the Brine Line System, the following considerations are identified:

1. **Resource Optimization:** Brine management benefits from integrated approaches that optimize resource utilization. For instance, instead of treating brine as a waste product, it can be viewed as a resource for various applications, such as mineral recovery, energy production, or other industrial processes.
2. **Multi-Industry Collaboration:** Collaboration among industries that generate and use brine unlocks innovation and reduces cost. For example, sharing brine infrastructure (e.g., pipelines, storage facilities) among desalination plants and other brine producing activities can maximize efficiency and minimize environmental impact.
3. **Environmental Considerations:** Adopting multi-use benefits in brine management involves minimizing environmental impact. This consideration includes reducing the volume and salinity of brine discharged into water bodies, implementing brine treatment technologies, and exploring alternative disposal methods, such as deep-well injection or evaporation ponds.
4. **Circular Economy Approaches:** Embracing circular economy principles can transform brine management into a resource recovery process. By extracting valuable components (e.g., minerals, metals) from brine, the economic and environmental value of brine is maximized.
5. **Innovation and Technology:** Research and development of innovative technologies for brine treatment, reuse, and disposal are critical. This consideration includes membrane processes, crystallization techniques, and electrochemical facilities that can improve brine management efficiency and reduce energy consumption.
6. **Policy and Regulation:** Regulatory frameworks can encourage the adoption of sustainable brine management practices, which involve setting discharge limits, incentivizing resource recovery from brine, and promoting collaboration among stakeholders.
7. **Ecosystem Services:** Considering the potential impacts of brine discharge on aquatic ecosystems is necessary. Protecting ecosystem such as water quality, habitat preservation, and biodiversity can then be integrated into brine management strategies.
8. **Public Engagement and Awareness:** Engaging communities and stakeholders in discussions about brine management can foster support for sustainable practices. Public awareness campaigns can highlight the importance of responsible brine disposal and the potential benefits of resource recovery.

By applying the principles of multi-use benefits to brine management and transport systems, stakeholders work towards more sustainable and efficient utilization of saline resources while minimizing environmental impact. This approach requires collaboration, innovation, and an understanding of the interconnected nature of water and industrial discharges. Beyond brine management considerations, multi-use benefits throughout the community are enhanced through additional water management actions, including:

1. **Integrated Water Resources Management (IWRM):** Multi-use benefits align with the community principles of IWRM, which emphasize the approach to managing water resources across different sectors and stakeholders. IWRM promotes coordination and cooperation among various agencies to optimize water allocation and achieve sustainable goals.
2. **Synergies and Trade-offs:** Identifying synergies and trade-offs among different water uses is crucial. For example, a reservoir managed for irrigation can also be used for hydropower generation or flood control. However, these uses may have competing demands during dry or wet seasons, requiring careful planning to optimize benefits without compromising sustainability.
3. **Ecosystem Services:** Water systems provide essential ecosystem services, such as maintaining water quality, supporting biodiversity, and regulating flows. Incorporating these considerations into water management decisions ensures that natural processes are sustained.
4. **Stakeholder Engagement:** Engaging diverse stakeholders, including communities, businesses, governments, and environmental organizations, is assist in identifying and prioritizing multi-use benefits. Participation fosters collaboration, builds consensus, and identifies competing interests.
5. **Infrastructure Planning and Design:** Designing water infrastructure with multi-use benefits in mind enhances efficiency and resilience. For instance, constructing multipurpose infrastructure that integrates compatible services can maximize benefits and minimizing impacts.
6. **Policy and Regulatory Frameworks:** Developing flexible and adaptive policy frameworks is promotes multi-use benefits. Policies can incentivize integrated approaches, provide clear guidelines for resource allocation, and address potential conflicts.
7. **Climate Resilience:** Considering climate change ensures the sustainability of multi-use water systems. Climate-resilient facilities include incorporating adaptive measures like water recycling, rainwater harvesting or enhancement, and enhancing water use efficiency.
8. **Data and Information Systems:** Robust data collection, monitoring, and modeling are essential for understanding complex water systems and predicting future need. Information systems that integrate hydrological, ecological, and socio-economic data support informed decision making.
9. **Capacity Building and Knowledge Sharing:** Investing in capacity advancement and knowledge sharing among water managers, policymakers, and communities enhances adoption of innovative solutions.

In summary, embracing multi-use benefits throughout a brine management or water system promotes an integrated and sustainable management strategy. By adopting the perspective of considering social, economic, and environmental consequences, water resources and facilities can be effectively managed to meet diverse need while preserving long-term viability.

7.4.1 Energy Production

7.4.1.1 Power Generation

While the primary purpose of the Brine Line is brine management and environmental protection, SAWPA has been interested in opportunities to incorporate power generation technologies within the overall conveyance system, if viable. Various technologies existing for power production from water conveyance systems. The salinity of brine flows complicates these efforts, in that operation and maintenance of such systems can be labor and cost intensive.

As part of this master plan effort, the use of in-pipe hydroelectric facilities as a source of renewable energy. LucidPipes was investigated, by Lucid Energy, installed a \$1.3 million system in Portland, Oregon, producing renewable energy to power about 150 homes, as well as revenues to help pay for needed infrastructure upgrades. Up to four LucidPipe units can produce as much as three megawatts of electricity, depending on the hydraulic conditions. The lift based vertical axis spherical turbines generate electricity by extracting excess pressure head in larger diameter (24" to 96"), gravity water pipelines and effluent streams. The Brine Line System could potentially accommodate in-pipe hydroelectric facilities. Brine scaling of hydroelectric facilities, as well as open manholes that exist throughout the Brine Line System, may negatively impact implementation of these facilities.

Micro-hydro power refers to the generation of electricity using small-scale hydroelectric systems that harness energy of flowing water. While micro-hydro power is not directly related to brine transport systems, exploring the integration of renewable energy technologies with water infrastructure for overall sustainability and energy efficiency has merit. In the context of the Brine Line System, micro-hydro power could potentially be integrated at pumping stations (which are not present in the system) or along the pipeline route if suitable hydraulic conditions exist. The potential for micro-hydro power generation was evaluated based on the general hydraulic characteristics of the Brine Line facilities. **Figure 7-3** illustrates the results of that analysis.

As illustrated on Figure 7.3, the production of power is primarily associated with the available water flow and the available hydraulic head within the pipeline system. The Brine Line does not have reaches of significant hydraulic grade variations, under which hydraulic energy can be harnessed. For the purposes of the analysis, flows of 11.06-mgd and 30.0-mgd were assumed, representing the current and ultimate flow conditions. Hydraulic head was varied between 5 and 80 feet. Based on these parameters, power generation within the Brine Line System might vary between 5 and 120 kW, with a value of between \$3,000 and \$140,000. Considering the cost of implementing a project of this magnitude, the payback period for such a project would not make the project economically viable.




Figure 7-3 Projected Micro-Hydro Power Capabilities

Other power generation options exist. Research and development in the future may make power generation more viable. Therefore, focusing on exploring innovative technologies that are specifically tailored to extract energy from high-salinity brine streams should be maintained. Such efforts could involve collaborations between water utilities,

technology developers, and research institutions to identify and deploy suitable power generation solutions. However, before implementing power generation technologies within the Brine Line System, feasibility studies would be necessary to assess the technical, economic, and environmental viability of such facilities. Factors such as energy efficiency, capital costs, and regulatory considerations would be evaluated to determine the practicality of integrating power generation with SAWPA's brine transport operations.

While the primary function of the Brine Line is brine management and environmental protection, there are currently limited opportunities to explore power generation technologies. However, further research, planning, and investment would be required to assess and implement such opportunities effectively.

7.4.1.2 Green Hydrogen

Producing green hydrogen from brine flows involves using a process that leverages renewable energy to split water into hydrogen and oxygen. Brine presents an interesting opportunity for this operation because it is typically a byproduct of certain industrial processes, such as desalination or resource extraction, and can have a higher salt content than seawater.

To produce green hydrogen, brine is collected from industrial operations like desalination plants or from natural salt deposits. The brine may be purified and diluted to remove impurities and adjust the salt concentration to optimal levels for electrolysis. Electrolysis is used to split water molecules (H_2O) into hydrogen (H_2) and oxygen (O_2) using electricity. In the case of brine, the process involves using an electrolyzer that can handle the higher salinity levels. The choice of electrolysis technology is crucial. Some advanced electrolyzers are specifically designed to handle brine solutions. These systems must be resistant to corrosion caused by the salt content. To ensure the process is truly green, renewable energy sources such as solar, wind, or hydroelectric power are used to provide the electricity needed for electrolysis. This process ensures that the hydrogen produced is environmentally friendly and does not contribute to greenhouse gas emissions. Once produced, the hydrogen is purified to remove any remaining impurities before it can be used as a clean fuel source.

Challenges with the green hydrogen process include the corrosive nature of brine that may require specialized materials and maintenance. The cost of electrolysis, especially using brine, needs to be competitive with other hydrogen production methods to be economically viable. Optimizing the efficiency of the electrolysis process, especially with brine, is critical for cost-effectiveness and overall environmental impact. Green hydrogen production from brine flows is an innovative pathway towards sustainable hydrogen production.

7.4.2 Water Production

Brine discharged to the Brine Line System varies considerably in total dissolved solids (TDS). Considering the current discharge limitation of 30.0-mgd to the OC San system and the projected ultimate brine flow of approximately 33.5-mgd, brine concentration and/or management effort will likely be required to avoid regulatory restrictions. Figure 3.3 projects, based on current information, that the Brine Line will exceed the 30.0-mgd limitation in approximately 2065. While this date is over 40 years in the future, other regulatory challenges (e.g., PFAS) may accelerate the need for advanced treatment of brine discharges, which may result in reaching the regulatory threshold sooner. Despite having significant time before brine concentration is required, SAWPA may selectively implement brine management where opportunities may exist.

The opportunity to extract water from the existing Brine Line flow will be highly dependent on location within the system. For example, extracting additional water from the brine flow along Agua Mansa Road would provide an opportunity to discharge the recovered water to the RIX facility, thereby creating a multi-use benefit for the community through increased groundwater replenishment. Similarly, if an industrial use of recycled water were available adjacent to a brine concentration facility, the water could be used for that industrial use, thereby creating a community benefit, while reducing the brine volume for ultimate disposal. It will be necessary to weigh the cost, operation, and maintenance of such a facility against the magnitude of the overall benefit. During the agency workshops conducted for this master plan, the agencies operating existing groundwater desalters identified that brine concentration was not cost effective beyond what they are already doing. Therefore, the driving factor for brine concentration and management activities will be the regulatory discharge limitation, and not the multi-use benefit that can be attained.

INTENTIONALLY LEFT BLANK

8 Future Facilities, Improvements & Expansion

The following section summarizes the recommended Brine Line improvement projects related to pipeline capacity, operations and maintenance (O&M), and data collection developed throughout this Master Plan. The recommended improvement projects are intended to improve the performance of the existing Brine Line or address anticipated future needs of the system based on results of the capacity analysis, discussion with SAWPA staff, and review of historical data and studies.

The advanced monitoring and real time data collection, included as a recommendation in the following discussion, will optimize the timing of improvements. The primary recommendation is for SAWPA to reconsider the market analysis and infrastructure improvements identified herein periodically, with the first review in five years.

Furthermore, decentralized PFAS treatment is a likely option and, as such, it is recommended that SAWPA evaluate the future economics of this approach further. OC San is in the process of developing Local Limits to regulate the discharge of PFAS to their treatment facilities, which may require dischargers to limit the amount of PFAS discharged to the Brine Line System.

This Master Plan is intended to inform the process of rate setting but does not set rates in and of itself. Exploration of funding strategies, including state and federal grants, will certainly be required on many fronts to implement many of the identified recommendations. The Brine Line Master Plan is intended to provide a solid framework for managing future infrastructure needs. Discussions of funding through grants, reserves and/or rate increases introduce dynamics that are beyond the scope of this master plan and should be carefully reviewed and managed.

8.1 Recommended Improvement Projects

The following recommendations include those to correct identified capacity deficiencies, improve facility management and perform system monitoring. Additionally, potential laterals for expanded Brine Line service as well as recommendations for future project evaluations are included within this section.

8.1.1 Pipeline Capacity Improvement Projects

Based on the results of the Brine Line capacity analysis presented in Section 5, projects summarized in **Table 8-1** are recommended for consideration by SAWPA. **Figure 8-1** illustrates the approximate location of Projects CAP-1 and CAP-2. It is noted that these projects are defined to be needed within the Near- (2024-2034) and Long-Term (2034-2058) planning horizon, as these challenges become evident as brine flows increase in the future.

Table 8-1: Recommended Pipeline Capacity Improvement Projects Summary

| Project ID | Planning Scenario | Project Description |
|------------|---------------------------------|--|
| CAP-1 | Long-Term (2035-2059) | <u>Reach IV-A Lower (Prado Inundations Area) Pipeline Replacement and Relocation</u> : Replace 18,000 LF of existing 36-inch pipe with 48-inch pipe in Reach IV-A, west of Prado Dam. |
| CAP-2 | Near-Term (2024-2034) | <u>Smart Manhole Cover Installation</u> : Install smart manhole covers at five (5) locations (Locations 2 through 6 per Table 5.4) to monitor water levels during maximum flow conditions. |
| CAP-3 | Build-Out Term (Beyond 2048) | <u>Reach 4D – Parallel</u> : Construct a 2,100-LF, 36-inch parallel line along the stretch of Reach 4D anticipated to be capacity deficient in the Buildout scenario. |
| CAP-4 | Build-Out Term (Beyond 2048) | <u>Reach 4 – Parallel</u> : Construct a 10,200-LF, 30-inch parallel line along the stretch of Reach 4 anticipated to be capacity deficient in the Buildout scenario. |
| CAP-5 | Near-Term (2024-2034) | <u>Future Study on Green Hydrogen</u> : Evaluate the feasibility of Green Hydrogen for the Brine Line system. This project provides capacity management when in operation by removing flow from the Brine Line |
| CAP-6 | Near-Term (2024-2034) | <u>Future Study on Brine Minimization and PFAS</u> : Conduct future studies and pilot programs on Brine Minimization (commence in approximately 2034) |




Figure 8-1 Recommended Brine Line Capacity Improvement Projects

8.1.2 Facility Management (FM) Projects

The physical condition of pipelines throughout the Brine Line system varies based on installation date, material, and other characteristics throughout the service area. SAWPA has historically focused on facility management (FM) projects, including targeted inspection or condition assessment of the existing Brine Line system. **Table 8-2** summarizes one (1) recommended O&M project, resulting from the master planning effort. The table also identifies several projects currently included in SAWPA’s existing Capital Improvement Program (CIP). The newly recommended O&M Project (FM-2) is associated with proposed off-line storage facilities discussed in Section 6.1.2, intended to facilitate dewatering of the Brine Line during planned shutdowns lessening impact to existing dischargers. SAWPA will need to complete preliminary studies prior to final design and construction of the off-line storage facilities. It is assumed that SAWPA will implement these facilities in a phased approach, constructing facilities as funding permits.

Brief descriptions of Projects FM-1 through FM-21 are provided in Table 8-2, based on current information provided by SAWPA staff.

Table 8-2: Recommended Facility Management Projects Summary

| Project ID | Planning Scenario | Project Description |
|------------|-------------------------------|---|
| FM-1 | Near-Term (2024-2034) | <u>Reach IV-E Mainline Valve</u> : Installation of a new MAS within the Brine Line downstream of existing MAS 4E-0040 to facilitate newly constructed Agua Mansa Lateral to be used as a low flow bypass, thereby allowing dewatering of the existing siphon section. |
| FM-2 | Near- & Long-Term (2025-2034) | <u>Off-Line Storage</u> : Install six (6) 2-MG and one (1) 0.5-MG off-line storage reservoirs (locations TBD); Project to be phased over 10 years. |
| FM-3 | Long-Term (2034-2045) | <u>Reach IV Pipeline Inspection & Condition Assessment/Rehabilitation</u> : A complete inspection and condition assessment of the Reach to identify existing structural or maintenance issues. Based on recommendations from the 2024 Condition Assessment. |
| FM-4A | Near-Term (2024-2034) | <u>Reach IV-B Ductile Iron Pipe (DIP) Pipeline Inspection & Condition Assessment/Rehabilitation</u> : Heavy cleaning, CCTV and Sonar inspection of 8,600 LF of pipe. Perform Joint repairs and spot repairs. Based on recommendations from the 2024 Condition Assessment. |
| FM-4B | Long-Term (2035-2059) | <u>Reach IV-B Ductile Iron Pipe Rehabilitation Project</u> : Rehabilitate approximately 8,600 feet of 36-inch DIP with CIPP Liner. Based on recommendations from the 2024 Condition. Reevaluate after mid-term condition assessment. |
| FM-5A | Near-Term (2024-2034) | <u>Reach IV-D Corrosion Rehabilitation</u> : Cleaning, CCTV and Concrete and liner repairs in the near term. Reinspecting entire 7 miles including siphons in the mid-term. Based on recommendations from the 2024 Condition Assessment. |
| FM-5B | Long-Term (2034-2045) | <u>Reach IV-D Corrosion Rehabilitation, Phase 1 and 2</u> : Lining of 7-miles of 42-inch pipeline. |
| FM-6 | Near-Term (2024-2034) | <u>Reach V MAS Condition Assessment</u> : Approximately 15 miles of Reach V is currently not accessible due to the lack of an adequate number of MAS. Access to Reach V is critical for performing routine inspections, cleaning of the pipeline, and mitigating operational issues. A catastrophic failure of the Brine Line in 2013 initiated the rehabilitation of about 5 miles of Reach V, including access points for future monitoring and flow bypasses in the event of another failure. Additional study is necessary to identify a suitable number and placement of MAS within Reach V. |

| Project ID | Planning Scenario | Project Description |
|------------|-----------------------|---|
| FM-7 | Near-Term (2024-2034) | <u>Reach IV-B Pipeline Inspection & Condition Assessment/Rehabilitation:</u> Approximately 30,000 LF of Reach IV-B, constructed between 1981 and 1996, will be inspected and evaluated. |
| FM-8 | Near-Term (2024-2034) | <u>Reach IV-B DIP Section Additional MAS Structures:</u> Construct additional MAS on Reach IV-B. Based on recommendations from the 2024 Condition Assessment. |
| FM-9 | Near-Term (2024-2034) | <u>Reach IV-E Inspection / Repairs:</u> Perform an investigation and assessment to understand the reliability and performance of Reach IVE and identify potential issues and actions needed to extend the remaining useful life of the system. |
| FM-10 | Near-Term (2024-2034) | <u>Reach V - Temescal Canyon Rd (El Cerrito Segment) Widening:</u> Relocate existing Air Release Valves and protect Brine Line during street widening project. |
| FM-11 | Near-Term (2024-2034) | <u>Reach V Air Vac Modifications:</u> Relocations or modification to place the Air Vacuum Valves in vaults will protect them from damage and uncontrolled spills. |
| FM-12 | Near-Term (2024-2034) | <u>Reach IV-D Inspection / Repairs - Project 1:</u> Perform an assessment to identify potential issues and actions needed to extend the remaining useful life of the system. Project 1 includes approximately 38,000 feet of pipe. |
| FM-13 | Near-Term (2024-2034) | <u>Reach V Indian Truck Trail Protection:</u> A portion of the Reach V Brine Line on Indian Truck Trail in Temescal Valley is subject to erosion due to stormwater. This project would provide protection of the Brine Line to prevent further erosion and impact to the Brine Line. |
| FM-14 | Near-Term (2024-2034) | <u>Reach IV-D Inspection / Repairs - Project 2:</u> Perform an assessment to identify potential issues and actions needed to extend the remaining useful life of the system. Project 1 includes approximately 38,000 feet of pipe. |
| FM-15 | Near-Term (2024-2034) | <u>Reach IV-D Inspection / Repairs - Project 3:</u> Perform an assessment to identify potential issues and actions needed to extend the remaining useful life of the system. Project 1 includes approximately 38,000 feet of pipe. |
| FM-16 | Near-Term (2024-2034) | <u>Reach V Baker St Protection:</u> Protect approximately 2 miles of Reach V on the unpaved portion of Baker Street from erosion and human activity. |
| FM-17 | Near-Term (2024-2034) | <u>Prado Access Road Improvements:</u> This project would improve about 3 to 6 miles of the Brine Line access road giving access to critical Brine Line facilities immediately once the reservoir has drained. Protect the Brine Line from erosion and scouring due to the Santa Ana River and tributaries. |
| FM-18 | Near-Term (2024-2034) | <u>Capacity Management:</u> Project involves planning for future discharges and understanding and controlling peak flows. Capacity management projects could include flow stabilization and peak discharge elimination and concentration of brine flows. |
| FM-19 | Near-Term (2024-2034) | <u>Reach IV-D Mission Tunnel:</u> Correct an existing joint lead on Reach IV-D in the Mission Tunnel. |
| FM-20A | Near-Term (2024-2034) | <u>Alcoa Dike Protection Relocation (Raise 2 MAS upon completion of project):</u> Raise two new MAS upon completion of project. |
| FM-20B | Near-Term (2024-2034) | <u>Prado Reservoir (below 556") MAS Projection:</u> Modify 1 - 3 MAS below 556' to be watertight. |
| FM-21 | Near-Term (2024-2034) | <u>OC San Future CIP:</u> SAWPA, through the cost sharing agreement for the Facility management of the SARI in Orange County, is obligated to pay a portion of the costs for this CIP. Annual contribution of \$400,000 for future OC San CIP. SAWPA is working with OCSD to further define their future CIP. |

8.1.3 System Monitoring Projects

As described in detail in Section 6.2, it is recommended that within the next 10 years, SAWPA implement a SCADA-based program intended to collect real-time flow and quality data throughout the Brine Line system. Data collected by the proposed SCADA system will aid in continuous monitoring of the myriad individual dischargers to the Brine Line, while reducing manual data compilation and management efforts by SAWPA staff.

Section 6.2 presented a preliminary phasing plan for the proposed SCADA system, beginning with initial setup and programming, followed by a phased approach to installing data collection devices at each discharger site and culminating in the installation of several flow monitors within the main Brine Line itself.

The following **Table 8-3** organizes the proposed SCADA system phasing plan into several improvement projects that should be completed in order. While implementation of a SCADA system at the individual sites as described in Projects MON-1, MON-2, and MON-3 will provide SAWPA with discharger-specific data, the in-line flow monitoring program in Project MON-4 will assist in more accurate estimation of overall Brine Line capacity and condition.

Table 8-3: Recommended SCADA Projects Summary


| Project ID | Planning Scenario | Project Description |
|------------|-----------------------|---|
| MON-1 | Near-Term (2024-2034) | <u>SCADA System</u> : Construct Master Station, operation workstation; initial set-up, integration of programming and automation. Install SCADA system at twelve (12) existing discharger sites that currently produce highest flows. |
| MON-2 | Near-Term (2024-2034) | <u>SCADA System</u> : Install SCADA system at twelve (12) existing discharger sites that currently produce next highest flows, after those included in Project MON-1. |
| MON-3 | Near-Term (2024-2034) | <u>SCADA System</u> : Install SCADA system at remaining twelve (12) existing discharger sites that currently produce lowest flows, after those included in Project MON-1 and MON-2. |
| MON-4 | Near-Term (2024-2034) | <u>SCADA System</u> : Install Brine Line for in-line flow monitoring stations #1 through #5 with monitoring program (locations TBD) (Phased over 5 years) |

8.1.4 Potential Expansion Laterals

In 2009, the State Water Resources Control Board adopted the Recycled Water Policy encouraging public agencies to recycle municipal wastewater as an increasingly valuable water resource. The Recycled Water Policy requires management of salt and nutrient loading to groundwater resulting from basin-wide recycled water use. The Recycled Water Policy also requires Antidegradation Analysis (State Water Resources Control Board Resolution 68-16) for groundwater recharge projects to identify assimilative capacity available for salt and nutrient loading, with projects permitted to consume up to 10% of available assimilative capacity in a basin, while multiple projects may consume up to 20% of available assimilative capacity.

The Brine Line system provides substantial brine management facilities to assist local agencies in achieving these mandates. However, within the Santa Ana River Watershed, there are areas that do not have convenient access to the Brine Line system, thereby making desalter and recycled water demineralization more costly to implement. **Figure 8.2** illustrates areas of potential future need that require significant cooperation and planning to facilitate economical brine management opportunities. The projects discussed were identified during the Agency Workshops, with the understanding that future projects, including significant industrial dischargers, may be identified. The following discussion highlight potential facilities that would benefit from extension of the Brine Line system.

Figure 8-2 Expansion Areas for Potential Brine Line Service



8.1.4.1 Eastern MWD Northeast Service Area

During the workshop held between SAWPA and Eastern Municipal Water District (EMWD) staff on March 8, 2023, EMWD identified the potential for future facilities within the northern and eastern portions of their service area, including the following facilities:

- EMWD identified the Perris North project to be a groundwater contamination and remediation project within the Moreno Valley area. The project is proposed to use evaporators to reduce brine volume by a factor of up to eight times.
- EMWD identified a potential new plant location for the District's Purified Water Replenishment (PWR) program, to be located in the San Jacinto area. The PWR program will improve the quality and quantity of local groundwater supplies through replenishment of purified recycled water. As the distance to the Brine Line is substantial, the District has been evaluating up to 21 acres of evaporation ponds for brine management.
- In the Lakeview Nuevo Area, EMWD is conducting hydrogeological evaluations for siting a new desalter, which was identified to be operational in the 20+ year time frame.
- Within the San Jacinto area, EMWD recharges up to 7,500 afy of local tribal settlement water. with excess recharge in years of with surplus water.
- EMWD has plans to construct additional recycled water plants in the Moreno Valley and Hemet areas. Current evaluations include providing effluent desalinization at the individual plant locations versus a basin-wide concept.

Based on EMWD planning within its northern and eastern service areas, exploring new opportunities to extend the Brine Line system into these areas may assist SAWPA with its brine management requirements. Yucaipa Valley Water District and the City of Beaumont constructed extended brine laterals similar to that needed for service to these EMWD areas. Alternative options have involved identification of potential abandoned pipelines (i.e., oil, petroleum, gas, other) that could be repurposed to transport brine to the Brine Line system. Ongoing discussions between SAWPA and EMWD are recommended to identify opportunities to extend Brine Line service to these areas. Service to these areas is projected to require up to 20 miles of new pipeline lateral, between 12 and 16 inches in diameter, at an approximate cost between \$30,000,000 and \$40,000,000, depending on the flow and alignment of the lateral.

8.1.4.2 San Bernardino Valley MWD Service Area

San Bernardino Valley MWD (Valley District), in conjunction with East Valley WD and the cities of Redlands and San Bernardino, is currently constructing the Regional Recycled Water Facilities Project. This project includes a recycled water conveyance system and groundwater recharge facility (Weaver Basins and Redlands Basins). These facilities allow recycled water from the San Bernardino WRF and Sterling Natural Resource Center to be conveyed from to the Weaver Basins, and from the Redlands WRF to the Redlands Basins.

East Valley WD constructed the Sterling Natural Resource Center to recycle wastewater from its service area and recharge via Weaver Basins.

San Bernardino is developing a Tertiary Treatment System to produce recycled water from the San Bernardino WRF for general plant use and irrigation. Valley District's recycled conveyance system will convey recycled water for recharge via the Weaver Basins.

Redlands has existing Waste Discharge Requirements for treatment and discharge of recycled water from its service area into Bunker Hill-B Groundwater Management Zone. Phase 2 expansion of the Redlands WRF will increase recycled water discharges via the Redlands Basins. Recycled water replenishment of the Bunker Hill-B Groundwater Management Zone provides a drought tolerant water supply, improving supply reliability and a drought buffer in the event of a prolonged drought.

These agencies are working to develop a collaborative regional plan (Upper Santa Ana River Watershed Salt & Nutrient Management Plan) supporting increasing recycled water use for groundwater replenishment, while managing groundwater quality. The agencies developed an MOU intended to implement salt mitigation including regional groundwater quality monitoring, brine line discharge for high-TDS water, optimized chemical use at wastewater treatment and reclamation facilities, a regional recycled water desalter, and enhanced upstream recharge of low-TDS water. There may be potential for additional industrial dischargers in the event that Brine Line extensions or laterals are constructed.

Reach 4E of the Brine Line terminates at the San Bernardino WRF, providing access for brine management operations. However, the Sterling Natural Resources Center and Redlands WRF facilities would require lateral extensions to provide brine disposal service. Considering the extensive impact the Regional Recycled Water System project will have, cooperation and ongoing discussions of potential Brine Line extension or other connection opportunities is warranted. The Redlands WRF, for example, could negotiate connection to the Yucaipa Valley WD brine lateral, thereby taking advantage of that laterals existing crossing of the Santa Ana River. Such a lateral is projected to be approximately 2.75 miles of 8-inch pipe, at a cost of approximately \$4,000,000 to \$5,000,000 depending on the alignment of the lateral. The other two facilities are located north of the Santa Ana River and are proposing regional recycled water pipelines that could be paralleled during construction with brine conveyance facilities at an incremental increase in cost.

8.1.4.3 Inland Empire Utilities Agency Service Area

Within the Inland Empire Utilities Agency's (IEUA's) service area, the agency owns and operates a non-reclaimable wastewater system (North Brine System). The North Brine System has approximately 34 active dischargers, mainly high TDS industrial dischargers. IEUA has stated that the North Brine System has sufficient capacity for additional dischargers.

During the recent agency workshops, it was discussed whether the possibility of emergency interconnections between the North Brine System and the Brine Line would be advantageous to allow bi-direction flow for emergency situations. From preliminary investigations, the North Brine System is constructed at an elevation higher than the Brine Line system. Therefore, gravity flow from the IEUA system to the SAWPA system would be possible, but a pump station may be required to convey flow in the opposite direction.

In the event that an emergency interconnect would be implemented, two advantageous locations for the interconnect are identified. One connects to the existing IEUA lateral, while the other connects to the mid-point of the North system. These connections would be approximately 3.0 to 3.5 miles of 12- to 16-inch pipeline, at a cost of approximately \$10,500,000.

8.1.4.4 Rancho California Water District

During discussions with Rancho California Water District (RCWD), RCWD identified that they have a need to dispose of approximately 2.0-mgd of brine from the Santa Rosa WRF, consisting of both demineralization reject water and

local industrial brine dischargers. Previous analysis indicated that RCWD proposed to convey brine to the Fallbrook Land Outfall through a newly constructed brine line. However, during our discussion, RCWD was interested in further evaluation of a new brine lateral connection to the Brine Line.

Based on preliminary analysis, the RCWD brine lateral would traverse north along Washington Avenue, Palomar Street, Mission Trail Road, East Lakeshore Drive, South Main Street, and Collier Avenue, connecting to the Brine Line at approximately Callier Avenue and Chaney Street. Additional discussions are required between SAWPA and RCWD before such a connection can be established. The proposed lateral would be a maximum of 8-inches in diameter at a length of approximately 14.75 miles, with an approximate cost of \$22,000,000.

8.1.4.5 City of Riverside and Western Municipal Water District

During the recent agency workshop, the City of Riverside expressed a future requirement for approximately 1.0-mgd of Brine Line capacity associated with future recycled water desalination efforts. The City indicated that their recent Salinity Study evaluated discharging brine to Reach IV-D of the Brine Line system. The City also identified a need for future Brine Line capacity, based on its existing plant being configured to support anticipated Direct Potable Reuse (DPR) requirements. Also, PFAS regulations may result in increased need for Brine Line capacity, as RO is most likely means of removal. The same systems are anticipated for TDS and PFAS control.

It is noted that Rubidoux Community Services District (RCSD) discharges to the Riverside system, constituting approximately 10 percent of the City's high TDS flow. RCSD has also requested a direct connection to the Brine Line system in the future, which may reduce the City's brine discharge. Additional industrial dischargers may be identified along the proposed brine lateral, depending on its alignment.

The projected Riverside Lateral, at a length of 3.5 miles and a diameter of 8 inches, would have a construction cost of approximately \$7,500,000. The lateral could also be increased in size to effectively provide service to additional industrial discharges along the pipeline alignment, as may be appropriate.

8.1.5 Ongoing or Future Project Evaluations

As presented In Chapter 6 of this Master Plan, there are a variety of projects proposed to meet future Brine Line contractual (i.e., brine minimization), regulatory (i.e., PFAS Control), or other community benefits (i.e., Green Hydrogen). Each of these proposed projects, while currently conceptual in nature, require significant additional study prior to conceptualization of a specific project for implementation. The following discussion outline future evaluation needed to support proposed future SAWPA projects. Funding for these additional studies are not addressed in this Master Plan, as specific definition of each evaluation is not defined.

8.1.5.1 Brine Line Criticality Analysis

Conducted in 2021, the Brine Line Criticality Analysis identifies and prioritizes critical components of the Brine Line system, which influences the prioritization of Capital Improvement Projects (CIP) for both operational and capacity-based needs. Update of this analysis on a 5- to 10-year basis will assist SAWPA with focusing its efforts on the most critical components of the Brine Line system, as well as prioritizing its CIP appropriately.

8.1.5.2 Off-Line Storage Analysis

During Brine Line outages or improvements, SAWPA needs to be able to manage and/or stop brine flow. The proposed solution involves constructing off-line storage reservoirs to store diverted brine, avoiding disruption to dischargers' operations. Seven reservoirs throughout the system are proposed, with preliminary sizing and siting criteria. These reservoirs are also capable of capturing first-flush dry weather stormwater flows, supporting brine minimization efforts, and potentially supporting green hydrogen production. Additional studies related to off-line storage operational concepts, specific reservoir siting, land acquisition, and other project details are required prior to development and implementation of these facilities.

8.1.5.3 Data Collection & Real Time System Management

For enhanced monitoring, operation, and control of the Brine Line system, this Master Plan proposes implementing a SCADA-based system for data collection and management. The concept includes a variety of system components, as well as the overall integration of field and office system components, coordination with existing and future Brine Line dischargers and other key system considerations, SAWPA will need a conceptual analysis of this proposed system to specifically design the project architecture prior to implementation.

8.1.5.4 Brine Minimization

Based on the information developed in this Master Plan, SAWPA is not projected to exceed the 30-mgd OC San flow limitation until approximately 2065. Prior to that time, AWPA will need to complete an evaluation of existing and emerging brine management processes, with associated preliminary site identification, operational details, and other information critical to the implementation of such a project. This evaluation will allow SAWPA to identify the monetary challenges of such a project. It is noted that secondary RO processes located at groundwater desalters, or other recycled water facilities were identified as more cost-effective than a centralized treatment concept. Furthermore, emerging technologies such as Flow Reversal Reverse Osmosis (FRRO), ceramic membrane with electrodialysis reversal (EDR), Membrane Distillation (MD), Forward Osmosis (FO), EDR, and potential solar-driven systems offer potential for improved brine concentration. Ongoing evaluation of these and other potential processes will be needed to effectively identify a preferred project, as well as define the information needed for its implementation.

8.1.5.5 PFAS Management

While PFAS management is not currently required, current regulatory actions have identified PFAS as a hazardous substance, and many ongoing efforts target elimination of PFAS from our society, Addressing emerging contaminants like PFAS, with potential treatment methods including Novel Adsorbent Systems (NAS), Electro-oxidation (EOX), and Granular Activated Carbon (GAC) will require additional study with respect to how these processes can and would be implemented. Identification of the PFAS contributions from individual dischargers will be required, as well as consideration of small scalable systems and pilot studies to accurately estimate full-scale PFAS treatment requirements and costs. Continue monitoring PFAS regulations relevant to groundwater recharge, and wastewater disposal will be required.

8.1.5.6 Green Hydrogen

Producing green hydrogen from brine flows involves using a process that leverages renewable energy to split water into hydrogen and oxygen. Brine presents an interesting opportunity for this operation because it is typically a

byproduct of certain industrial processes, such as desalination or resource extraction, and can have a higher salt content than seawater. Challenges with the green hydrogen process include the corrosive nature of brine that may require specialized materials and maintenance. The cost of electrolysis, especially using brine, needs to be competitive with other hydrogen production methods to be economically viable. Optimizing the efficiency of the electrolysis process, especially with brine, is critical for cost-effectiveness and overall environmental impact. Green hydrogen production from brine flows is an innovative pathway towards sustainable hydrogen production.

Additional studies necessary for the implementation of a Green Hydrogen project would include a comprehensive analysis of the costs associated with implementation, including capital expenditure, operation, and maintenance costs versus the expected revenue. While this analysis would be borne by a third party, SAWPA would be required to undertake parallel studies to define its abilities to meet the potential requirements of such an agreement. Other studies might include environmental impact evaluations, regulatory compliance reviews, and community education efforts. Collaboration between various stakeholders, SAWPA Member Agencies, and other affected parties would be needed.

8.2 Identified Project Cost Summaries

Probable planning-level costs were developed for the identified improvement projects. A summary of these costs, as well as the detailed planning level cost options, are included in **Appendix E**. Note: the Engineering News Record Construction Cost Index (ENR CCI) for Los Angeles at the time of the development of this cost estimate is 15315.12 for July 2024. It is anticipated that more detailed cost opinions will be developed during preliminary design each project.

8.3 Project Prioritization

Prioritization of capital improvement projects involves evaluating and balancing multiple factors to determine which projects are to be implemented first. Contributing key factors include:

- **Urgency and Necessity:** Projects addressing critical infrastructure needs, safety concerns, or compliance with regulatory requirements receive higher priority.
- **Cost and Budget Impact:** The total cost of the project, availability of funding, and potential impact on the budget are crucial considerations. Projects that provide the most value or have secured funding would likely receive higher priority.
- **Benefit to the Community:** Projects that offer significant benefits to the community, such as improved public services, economic development, or enhanced quality of life, are often prioritized.
- **Risk Management:** Projects that mitigate high risks, such as natural disaster preparedness or critical infrastructure failures, are typically given precedence. The previously completed Brine Line Criticality Analysis provides significant insight into the risk associated with various Brine Line reaches.
- **Alignment with Strategic Goals:** Projects that align with the organization's long-term strategic goals and plans are prioritized to ensure consistency with overall objectives.

- **Stakeholder Support and Political Will:** Projects with strong support from stakeholders, including the public, government officials, SAWPA Member Agencies, and other influential groups, are more likely to be prioritized.
- **Feasibility and Readiness:** The readiness of the project for implementation, including the availability of designs, permits, and other preparatory work, can influence its prioritization.
- **Sustainability and Environmental Impact:** Projects that promote sustainability, reduce environmental impact, or improve resilience to climate change are increasingly prioritized. Also, completion of necessary environmental documentation affect project prioritization.
- **Economic Impact:** The potential for economic benefits, such as job creation, increased property values, or economic development, can elevate a project's priority.
- **Operational Efficiency:** Projects that enhance the efficiency or effectiveness of existing operations, such as upgrading outdated systems or infrastructure, are often prioritized.
- **Regulatory Requirements:** Projects that are necessary to meet existing or projected regulatory requirements are often prioritized to assure implementation prior to or in conjunction with permit requirements or restrictions.

Through consideration of these factors, decision-makers can effectively prioritize capital improvement projects to assure that resources are allocated to the most impactful and necessary initiatives. For this master plan, prioritization was evaluated and incorporated into the Year Capital Improvement Project (CIP) schedule, discussed in the following section.

8.4 Capital Improvement Program

Appendix E provides an overview of the proposed Inland Empire Brine Line Capital Improvement Program (CIP), incorporating projects identified by the 2024 Inland Empire Brine Line Master Plan. The table illustrates the distribution of proposed projects over the Near-Term (2025 to 2034), Long-Term (2035 to 2048), and Build-Out (beyond 2049) planning horizons. It is important to note that specific timing of required projects will be impacted by budget availability, ongoing Brine Line operational investigations, and other factors as time progresses.

The initial 10 years of the CIP (10-YR CIP) are the primary focus for SAWPA, concentrating on known operational challenges and near-term system initiatives. Revisions to the 10-YR CIP are also anticipated over time. Future updates of this master plan will undoubtedly identify new or updated projects and initiatives, as well as reschedule those projects within the 10-YR CIP and beyond.

9 Policy Considerations

SAWPA has expressed its mission of focusing on protecting and enhancing the water resources of the Santa Ana River Watershed. Their mission is to develop and maintain regional plans, programs, and projects that maximize the beneficial uses of the watershed in an economically and environmentally responsible manner. This mission includes addressing water supply reliability, water quality improvement, recycled water, wastewater treatment, groundwater management, brine disposal, and integrated regional planning.

This mission is supported by a strategic plan that includes goals such as promoting solutions to manage waterways, supporting invasive species removal, building public understanding and support for watershed sustainability, facilitating the incorporation of water resources management into land use planning, and securing external funding for watershed initiatives.

SAWPA has consistently and effectively met this mission through ongoing service to its Member Agencies and the various community dischargers that currently use the Inland Empire Brine Line today. As Brine Line discharges increase over time, SAWPA will be challenged to maintain the Brine Line system while increasing system use through the watershed. To achieve these goals, SAWPA will need to consider a range of potential policy measures or changes to improve brine management efficiency.

SAWPA could consider policy improvements to manage brine more effectively in the Santa Ana River Watershed. These policies could address environmental, economic, and social considerations to ensure sustainable and equitable brine management. The following discussions identify potential policy considerations recommended for ongoing discussion between SAWPA management, the SAWPA Commission, and its Member Agencies.

9.1 Environmental Policies

While SAWPA and its Member Agencies have a long track record of excellent stewardship throughout the Santa Ana River Watershed, enhanced monitoring and reporting capabilities would provide continuous monitoring of brine discharge points (i.e., SCADA-based Brine Line system data collection). At present, SAWPA requires regular reporting of brine composition and volumes from dischargers but lacks a means of continuous monitoring to assure that all dischargers adhere to prescribed permit requirements. With increase regulatory requirements and the potential for emerging constituents of concern, SAWPA will likely be faced with the need to establish stricter limits on concentration and/or constituents in brine discharges. The emergence of PFAS treatment and control could result in the development and enforcement of Total Maximum Daily Loads (TMDLs) for critical pollutants.

Over time, SAWPA will be charged with a variety of environmental challenges, which will require policies that promote projects that restore and protect natural habitats potentially affected by brine discharge, as well as potential implementation of conservation easements or other land-use controls to protect sensitive areas. Elsewhere, SAWPA may be required to encourage or mandate the use of advanced brine treatment technologies to minimize environmental impact or seek incentives or grants for upgrade of existing brine treatment systems. Development of an enhanced permitting process may be necessary to support stricter permitting processes for industries discharging brine, thereby ensuring compliance with existing and future environmental standards. The establishment of a robust monitoring and reporting system will assist SAWPA in ensuring adherence to regulations.

9.2 Economic Policies

At present, dischargers are required to incur the cost of any and all pipeline, treatment, or other facilities necessary to convey brine to the Brine Line system for disposal and continue to maintain ownership of those facilities separate from SAWPA. Many public agencies and local businesses have expressed that construction of the necessary facilities can be cost prohibitive, necessitating that alternative planning be implemented. SAWPA and its Member Agencies may consider future mechanisms for cost-sharing and/or funding of facilities that provide a regional benefit to the Santa Ana River Watershed. SAWPA could develop cost-sharing frameworks that support infrastructure upgrades and/or maintenance. Establishing a dedicated fund or financial assistance program for brine management projects could be discussed with the emphasis on expanding the regional brine pipeline network to ensure adequate pipeline capacity and coverage. Such a fund may be similar to the existing Capacity Leasing Program, with the new fund providing for Capacity Buy-Back that allows SAWPA and its Member Agencies to balance capacity distribution based on discharger location.

SAWPA and its Member Agencies might consider methods of infrastructure investment to upgrade treatment capabilities or invest in upgrading existing brine treatment facilities to improve efficiency and/or capacity. Other economic incentives may be reasonable, including potential incentives or subsidies for companies adopting improved/sustainable brine management practices. SAWPA might consider revised fee structures that encourage reduction in brine discharge volumes and/or emerging pollutant loads, thereby incentivizing Brine Line system improvements from dischargers. Public-Private Partnerships may be useful to facilitate partnerships between public agencies and private companies to develop and implement increased brine management solutions or encourage collaborative research and development initiatives.

9.3 Regulatory and Legal Policies

Based on the analyses completed under this master plan, it is clear that SAWPA and its Member Agencies will be faced with considerable challenges in management of both conveyance and treatment capacity in the future. While these challenges remain distant at this time, discussion of potential policy revisions that will ultimately support the needs of future growth and expansion is prudent. Updating current permitting processes to include stricter requirements for brine management can assist SAWPA with ongoing control of Brine Line flows, assuring that the 30-mgd limitation by OC San is not exceeded.

Improvements in Inter-agency collaboration between SAWPA and other regulatory agencies can foster the promulgation of improved brine management policies. While SAWPA effectively fills this role currently, a potential consideration may be the establishment of a regional task force to coordinate efforts and share best management practices. These collaborative efforts may enhance compliance and strengthen potential enforcement requirements. Collaboration will support implementation of new and innovative salinity control measures to enhance salinity levels in the watershed and facilitate advanced desalination technologies in the future.

9.4 Social and Community Policies

SAWPA and its Member Agencies maintain high marks with respect to stakeholder engagement. SAWPA may consider establishment of regular forums for stakeholder engagement, including public meetings and community consultations, as well as developing outreach programs to educate the community about brine management issues and solutions. Such community engagement strengthens environmental justice and equity perceptions by ensuring that policies consider the impact on disadvantaged communities and implement measures to mitigate disproportionate impacts on vulnerable populations. Discussions should increase transparency and accountability in decision-making processes and policy implementations.

9.5 Research and Development Policies

Research and development of new technical approaches to brine management, brine concentration, and other challenges with facility management of the Brine Line system are critical to the long-term viability of the Brine Line. SAWPA and its Member Agencies can promote policies that support innovation by funding or cost-sharing research on innovative brine management technologies and practices. In addition, SAWPA may partner with academic institutions and researchers to advance solutions to brine challenges, with policy statements that explain established goals to the public. SAWPA could discuss policies for the investment into data collection infrastructure to support evidence-based policy making, using data analytics to identify trends, predict impacts, and optimize management strategies. The proposed SCADA-based monitoring system greatly enhances data collection for these purposes. Research grants and support of ongoing pilot testing efforts can be discussed, with supporting policy statements. SAWPA should leverage new technologies, such as remote sensing and real-time monitoring systems, to enhance brine management. Implementing these policies may help SAWPA ensure sustainable brine management, protect the watershed's ecological health, and support the region's long-term water quality goals.

INTENTIONALLY LEFT BLANK

Appendix A

Brine Line Discharger Information

Santa Ana Watershed Project Authority
Inland Empire Brine Line Master Plan

APPENDIX A - Summary of Brine Line Discharger Flow Information

Dudek
March 2024

| | Reach | Maximum Discharge Allowed (gpd) | Existing Discharge | | Near-Term Projected Discharge | | | Long-Term Projected Discharge | | | Build-Out Projected Discharge | | |
|---|-------|---------------------------------|------------------------------------|-------------------------|------------------------------------|-------------------------|-------------------------|------------------------------------|-------------------------|-------------------------|------------------------------------|-------------------------|-------------------------|
| | | | 2023 Avg Discharge (gpd) | Maximum Discharge (gpd) | Avg Discharge Increment (gpd) | Average Discharge (gpd) | Maximum Discharge (gpd) | Avg Discharge Increment (gpd) | Average Discharge (gpd) | Maximum Discharge (gpd) | Avg Discharge Increment (gpd) | Average Discharge (gpd) | Maximum Discharge (gpd) |
| Western Municipal Water District | | | | | | | | | | | | | |
| Anita B. Smith Treatment Facility | IV-D | 30,000 | 5,000 | 60,000 | 0 | 5,000 | 30,000 | 0 | 5,000 | 30,000 | 0 | 5,000 | 30,000 |
| Aramark Uniform & Career Apparel, LLC | IV-D | 330,000 | 198,000 | 375,804 | 0 | 198,000 | 330,000 | 0 | 198,000 | 330,000 | 0 | 198,000 | 330,000 |
| Dart Container Corporation | IV-B | 60,000 | 29,000 | 75,081 | 0 | 29,000 | 60,000 | 0 | 29,000 | 60,000 | 0 | 29,000 | 60,000 |
| Frutarom USA, Inc. | IV-B | 5,000 | 6,000 | 28,800 | 0 | 6,000 | 28,800 | (1,000) | 5,000 | 5,000 | 0 | 5,000 | 5,000 |
| Pyrite Canyon Treatment Facility (Stringfellow) | IV-D | 259,000 | 135,000 | 198,855 | 0 | 135,000 | 198,855 | 40,832 | 175,832 | 259,000 | 0 | 175,832 | 259,000 |
| Wellington Foods, Inc. (International Foods) | V | 30,000 | 14,500 | 74,037 | 0 | 14,500 | 30,000 | 0 | 14,500 | 30,000 | 0 | 14,500 | 30,000 |
| Magnolia Foods, LLC <i>[included in Etiwanda discharge]</i> | IV-D | 3,560 | <i>E Flow incl. at Etiwanda MS</i> | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | |
| Metal Container Corporation <i>[included in Etiwanda discharge]</i> | IV-D | 165,000 | <i>E Flow incl. at Etiwanda MS</i> | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | |
| Del Real, LLC <i>[included in Etiwanda discharge]</i> | IV-D | 190,164 | <i>E Flow incl. at Etiwanda MS</i> | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | |
| JCSD Roger D. Teagarden Ion Exchange WTP <i>[included in Etiwanda discharge]</i> | IV-D | 225,000 | <i>E Flow incl. at Etiwanda MS</i> | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | |
| JCSD Wells 17 & 18 Ion Exchange Treatment Facility <i>[included in Etiwanda discharge]</i> | IV-D | 225,000 | <i>E Flow incl. at Etiwanda MS</i> | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | | <i>E Flow incl. at Etiwanda MS</i> | | |
| JCSD - Etiwanda Metering Station ^E <i>[multiple discharge capacities]</i> | IV-D | 854,500 | 846,200 | 1,184,680 | 0 | 846,200 | 1,184,680 | 8,300 | 854,500 | 854,500 | 0 | 854,500 | 854,500 |
| JCSD - Hamner Metering Station | IV-D | 49,000 | 33,000 | 92,994 | 0 | 33,000 | 92,994 | 16,000 | 49,000 | 49,000 | 0 | 49,000 | 49,000 |
| SCE Mira Loma Peaker Plant | IV-D | 2,500 | 2,500 | 0 | 0 | 2,500 | 2,500 | 0 | 2,500 | 2,500 | 0 | 2,500 | 2,500 |
| JCSD - Wineville Metering Station | IV-D | 249,000 | 149,000 | 323,926 | 0 | 149,000 | 323,926 | 100,000 | 249,000 | 249,000 | 0 | 249,000 | 249,000 |
| WMWD Arlington Desalter | IV-B | 1,400,000 | 1,268,000 | 1,275,608 | 0 | 1,268,000 | 1,268,000 | 132,000 | 1,400,000 | 1,400,000 | 0 | 1,400,000 | 1,400,000 |
| Temescal Desalter (City of Corona) | IV-B | 2,150,000 | 1,883,000 | 2,159,801 | 0 | 1,883,000 | 1,883,000 | 267,000 | 2,150,000 | 2,150,000 | 0 | 2,150,000 | 2,150,000 |
| Rubidoux CSD | IV-D | 2,000,000 | 0 | 0 | 0 | 0 | 0 | 1,000,000 | 1,000,000 | 1,000,000 | 1,000,000 | 2,000,000 | 2,000,000 |
| Riverside County Flood Control | IV-D | 2,000,000 | 0 | 0 | 1,000,000 | 1,000,000 | 1,000,000 | 1,000,000 | 2,000,000 | 2,000,000 | 0 | 2,000,000 | 2,000,000 |
| Elsinore Valley MWD | V | 1,200,000 | 0 | 0 | 650,000 | 650,000 | 650,000 | 150,000 | 800,000 | 800,000 | 400,000 | 1,200,000 | 1,200,000 |
| Temescal Valley Water District | V | 225,000 | 0 | 0 | 0 | 0 | 0 | 225,000 | 225,000 | 225,000 | 0 | 225,000 | 225,000 |
| JCSD Future Desalter <i>[Future Etiwanda discharge]</i> | IV-D | 4,000,000 | 0 | 0 | 0 | 0 | 0 | 3,000,000 | 3,000,000 | 3,000,000 | 1,000,000 | 4,000,000 | 4,000,000 |
| Riverside Future Recycled Water Desal Collection Station (Waste Haulers) | IV-D | 1,000,000 200,000 | 0 41,000 | 0 566,497 | 0 59,000 | 0 100,000 | 0 100,000 | 1,000,000 50,000 | 1,000,000 150,000 | 1,000,000 150,000 | 0 50,000 | 1,000,000 200,000 | 1,000,000 200,000 |
| Leased Capacity | | 666,000 | | | | | | | | | | | |
| Western Water Ownership Allocated (gpd) | | 16,044,000 | 4,610,200 | 6,416,083 | 1,709,000 | 6,319,200 | 7,182,755 | 6,988,132 | 13,307,332 | 13,594,000 | 2,450,000 | 15,757,332 | 16,044,000 |
| Western Water Ownership Capacity (gpd) | | 11,084,000 | 11,084,000 | | | 11,084,000 | | | 11,084,000 | | | 11,084,000 | |
| Remaining Ownership Capacity (gpd) | | (4,960,000) | 6,473,800 | 4,667,917 | | 4,764,800 | 3,901,245 | | (2,223,332) | (2,510,000) | | (4,673,332) | (4,960,000) |
| Remaining Ownership (%) | | -44.7% | 58.4% | | | 43.0% | | | -20.1% | | | -42.2% | |
| Inland Empire Utilities Agency | | | | | | | | | | | | | |
| California Institution for Men | IV-A | 194,000 | 24,000 | 152,376 | 0 | 24,000 | 152,376 | 0 | 24,000 | 152,376 | 38,000 | 62,000 | 194,000 |
| California Institution for Women | IV-D | 400,000 | 116,000 | 679,528 | 0 | 116,000 | 400,000 | 0 | 116,000 | 400,000 | 61,000 | 177,000 | 400,000 |
| Green River Golf Club | IV | 7,000 | 4,000 | 4,340 | 0 | 4,000 | 4,340 | 0 | 4,000 | 4,340 | 2,452 | 6,452 | 7,000 |
| Mission Linen Supply | IV-A | 713,000 | 168,000 | 360,024 | 0 | 168,000 | 360,024 | 0 | 168,000 | 360,024 | 175,550 | 343,550 | 713,000 |
| In-N-Out Burger, Chino Distribution Center | IV-D | 86,000 | 58,000 | 62,582 | 0 | 58,000 | 62,582 | 0 | 58,000 | 62,582 | 28,000 | 86,000 | 86,000 |
| OLS Energy | IV-A | 130,000 | 6,000 | 51,996 | 0 | 6,000 | 51,996 | 0 | 6,000 | 51,996 | 24,000 | 30,000 | 130,000 |
| Repet, Inc. | IV-A | 64,800 | 42,000 | 61,404 | 22800 | 64,800 | 64,800 | 0 | 64,800 | 64,800 | 0 | 64,800 | 64,800 |
| Chino Eastside WTP | IV-D | 65,500 | 10,000 | 10,000 | 55,500 | 65,500 | 65,500 | 0 | 65,500 | 65,500 | 0 | 65,500 | 65,500 |
| Collection Station | IV-A | 200,000 | 55,000 | 224,015 | 45000 | 100,000 | 100,000 | 50000 | 150,000 | 150,000 | 50,000 | 200,000 | 200,000 |
| Leased Capacity | | 350,000 | | | | | | | | | | | |
| IEUA Total Discharge (gal) | | 1,860,300 | 483,000 | 1,606,265 | | 606,300 | 1,261,618 | | 656,300 | 1,311,618 | | 1,035,302 | 1,860,299 |
| IEUA Ownership Capacity (gal) | | 4,130,000 | 4,130,000 | | | 4,130,000 | | | 4,130,000 | | | 4,130,000 | |
| Remaining Ownership Capacity (gal) | | 2,269,700 | 3,647,000 | 2,523,735 | | 3,523,700 | 2,868,382 | | 3,473,700 | 2,818,382 | | 3,094,698 | 2,269,701 |
| Remaining Ownership (%) | | 55.0% | 88.3% | | | 85.3% | | | 84.1% | | | 74.9% | |
| Chino Basin Desalter Authority | | | | | | | | | | | | | |
| Chino I Desalter | IV-D | 2,370,000 | 2,391,200 | 2,651,841 | 0 | 2,391,200 | 2,391,200 | (21,200) | 2,370,000 | 2,370,000 | 0 | 2,370,000 | 2,370,000 |
| Chino II Desalter (east) <i>[included in Etiwanda discharge]</i> | IV-D | 650,000 | 479,400 | 479,400 | 0 | 479,400 | 479,400 | 170600 | 650,000 | 650,000 | 0 | 650,000 | 650,000 |
| Chino II Desalter (west) <i>[included in Wineville discharge]</i> | IV-D | 650,000 | 479,400 | 479,400 | 0 | 479,400 | 479,400 | 170600 | 650,000 | 650,000 | 0 | 650,000 | 650,000 |
| CDA Total Discharge (gal) | | 3,670,000 | 3,350,000 | 3,610,641 | | 3,350,000 | 3,350,000 | | 3,670,000 | 3,670,000 | | 3,670,000 | 3,670,000 |
| CDA Ownership Capacity (gal) | | 3,670,000 | 3,670,000 | | | 3,670,000 | | | 3,670,000 | | | 3,670,000 | |
| Remaining Ownership Capacity (gal) | | 0 | 320,000 | 59,359 | | 320,000 | 320,000 | | 0 | 0 | | 0 | 0 |
| Remaining Ownership (%) | | 0.0% | 8.7% | | | 8.7% | | | 0.0% | | | 0.0% | |
| San Bernardino Valley Municipal Water District | | | | | | | | | | | | | |
| Agua Mansa Power Plant | IV-E | 62,000 | 14,000 | 92,820 | 0 | 14,000 | 62,000 | 0 | 14,000 | 62,000 | 0 | 14,000 | 62,000 |
| Mountainview Generating Station | IV-E | 432,000 | 410,000 | 478,880 | 0 | 410,000 | 432,000 | 0 | 410,000 | 432,000 | 22,000 | 432,000 | 432,000 |
| Rialto Bioenergy Facility, LLC | IV-E | 250,000 | 79,000 | 141,173 | 50,000 | 129,000 | 230,523 | 0 | 129,000 | 230,523 | 121,000 | 250,000 | 250,000 |
| YVWD - Henry Wochholz Regional Water Recycling Facility | IV-E | 1,756,000 | 431,000 | 463,325 | 1,325,000 | 1,756,000 | 1,756,000 | 0 | 1,756,000 | 1,756,000 | 0 | 1,756,000 | 1,756,000 |
| Regional Recycled Water Facilities Project | IV-E | 1,550,000 | 0 | 0 | 1,550,000 | 1,550,000 | 1,550,000 | 0 | 1,550,000 | 1,550,000 | 0 | 1,550,000 | 1,550,000 |
| City of Beaumont Wastewater TP | IV-E | 580,000 | 532,000 | 604,884 | 30,000 | 562,000 | 562,000 | 18,000 | 580,000 | 580,000 | 0 | 580,000 | 580,000 |
| Collection Station | IV-E | 200,000 | 92,000 | 235,060 | 48,000 | 140,000 | 140,000 | 30,000 | 170,000 | 170,000 | 30,000 | 200,000 | 200,000 |
| Leased Capacity | | (250,000) | | | | | | | | | | | |
| Valley District Total Discharge (gal) | | 4,830,000 | 1,558,000 | 2,016,142 | | 4,561,000 | 4,732,523 | | 4,609,000 | 4,780,523 | | 4,782,000 | 4,830,000 |
| Valley District Ownership Capacity (gal) | | 7,738,000 | 7,738,000 | | | 7,738,000 | | | 7,738,000 | | | 7,738,000 | |
| Remaining Ownership Capacity (gal) | | 2,908,000 | 6,180,000 | 5,721,858 | | 3,177,000 | 3,005,477 | | 3,129,000 | 2,957,477 | | 2,956,000 | 2,908,000 |
| Remaining Ownership (%) | | 37.6% | 79.9% | | | 41.1% | | | 40.4% | | | 38.2% | |
| Eastern Municipal Water District | | | | | | | | | | | | | |
| EMWD Perris & Menifee Desalination Facility | V | 3,998,000 | 3,529,600 | 4,097,866 | 468,400 | 3,998,000 | 3,998,000 | 0 | 3,998,000 | 3,998,000 | 0 | 3,998,000 | 3,998,000 |
| Perris II Expansion (Future) | V | 900,000 | 0 | 0 | 0 | 0 | 0.000 | 900,000 | 900,000 | 900,000 | 0 | 900,000 | 900,000 |
| Rancho California Water District | V | 2,000,000 | 0 | 0 | 1,000,000 | 1,000,000 | 1,000,000 | 0 | 1,000,000 | 1,000,000 | 1,000,000 | 2,000,000 | 2,000,000 |
| Collection Station <i>[included in Menifee discharge]</i> | V | 200,000 | 0 | 0 | 50,000 | 50,000 | 50,000 | 100,000 | 150,000 | 150,000 | 50,000 | 200,000 | 200,000 |
| Leased Capacity | | (500,000) | | | | | | | | | | | |
| EMWD Total Discharge (gal) | | 7,098,000 | 3,529,600 | 4,097,866 | | 5,048,000 | 5,048,000 | | 6,048,000 | 6,048,000 | | 7,098,000 | 7,098,000 |
| EMWD Ownership Capacity (gal) | | 5,946,000 | 5,946,000 | | | 5,946,000 | | | 5,946,000 | | | 5,946,000 | |
| Remaining Ownership Capacity (gal) | | (1,152,000) | 2,416,400 | 1,848,134 | | 898,000 | 898,000 | | (102,000) | (102,000) | | (1,152,000) | (1,152,000) |
| Remaining Ownership (%) | | -19.4% | 40.6% | | | 15.1% | | | -1.7% | | | -19.4% | |
| | | | | | | | | | | | | | |
| | Reach | Maximum Discharge (gpd) | Existing Discharge | | Near-Term Projected Discharge | | | Long-Term Projected | | | | | |

Appendix B

Novel Adsorbent Treatment System Sizing and Performance Information

Preliminary Full-Scale Design
January 11, 2024

Using DEXSORB® Adsorbents for Per- and Polyfluoroalkyl Substances (PFAS) Treatment in Brine Wastewater

Prepared for:
DUDEK
San Diego, CA



Table of Contents

- SAWPA PFAS TREATMENT OVERVIEW 3**
- 1. OVERVIEW..... 4**
- 2. SITE INFORMATION..... 5**
- 3. DEXSORB SYSTEM DESIGN AND CONSTRUCTION 5**
- 4. DEXSORB WASTE HANDLING ADVANTAGES 6**
- 5. COST ESTIMATE 6**
- APPENDIX. DEXSORB SYSTEM PROCESS FLOW DIAGRAM AND LAYOUT 7**

SAWPA PFAS Treatment Overview



Santa Ana Watershed Project Authority (SAWPA), based in Riverside, CA, addresses various regional water resource issues surrounding the Santa Ana River watershed, including brine disposal. Orange County Water District (OCWD) wastewater treatment plant is downstream of SAWPA’s brine discharge line.

General Water Quality. The brine line currently measures maximum values for Total Suspended Solids (TSS) at 400 mg/L, Biochemical Oxygen Demand (BOD) at 250 mg/L, and Total Dissolved Solids (TDS) at 5,500 mg/L.

PFAS Background. Maximum PFAS levels detected in the brine line are provided in [Table 1](#). A total of 11 PFAS are detected at total peak concentration of 840 ng/L. PFOA and PFOS are detected at 130 ng/L and 170 ng/L respectively.

PFAS Treatment Target. The US EPA has proposed Maximum Contaminant Levels (MCLs) of 4 ng/L for PFOA and PFOS in drinking water. Per DUDEK’s input in January 2024, this design specifies full-scale DEXSORB treatment to meet PFAS discharge limit of PFOA and PFOS at 4 ng/L.

Table 1. PFAS Background Characterization

| Compound | Maximum Concentration (ng/L) |
|-------------------|------------------------------|
| PFBA | 60 |
| PFPeA | 70 |
| PFHxA | 90 |
| PFHpA | 40 |
| PFOA | 130 |
| PFBS | 60 |
| PFPeS | 30 |
| PFHxS | 90 |
| PFHpS | 10 |
| PFOS | 170 |
| 6:2 FTS | 90 |
| Total PFAS | 840 |

1. Overview

This proposal details the a preliminary full-scale system design with cost estimates for Cyclopure’s DEXSORB packed bed filtration (PBF) system to remove PFAS from the Santa Ana Watershed Authority (SAWPA) brine discharge line. DEXSORB is a novel cyclodextrin adsorbent, designed for use in engineered applications to remove PFAS in diverse water sources. The media features rapid kinetics, high treatment capacity, and resistance to fouling by natural organic matter (NOM).

DEXSORB provides superior PFAS adsorption capacity over traditional adsorbents such as GAC and ion exchange resins. Notably, the high treatment capacity of DEXSORB for PFAS is consistent across different water qualities and diverse water matrices including drinking water, groundwater, surface water, and more complex matrices such as wastewater and landfill leachate.

DEXSORB Full-Scale System.

DEXSORB has demonstrated effective removal of PFAS in similar matrices with high TDS, such as metal-plating wastewater (~5,000 mg/L). With DEXSORB’s high treatment capacity and selectivity for PFAS, DEXSORB PBF systems are characterized by smaller system footprint, lower media volume and significantly longer operation life when compared to GAC treatment systems.

The proposed DEXSORB system is designed in a lead-lag PBF configuration consisting of five parallel systems for PFAS treatment. **Suspended solids treatment (i.e. sand filter, dissolved air flotation (DAF) unit) is required prior to the DEXSORB system.**

Based on the PFAS levels in [Table 1](#) and the PFAS treatment target, a system design summarized in [Table 2](#). The design consists of ten vessels in total, configured in five parallel lead-lag systems. Each lead-lag system contains approximately 56.8 metric tons (mT) of dry granular DEXSORB to provide an empty bed contact time (EBCT) of 15 minutes. Backwash capabilities are incorporated into each vessel.

Table 2. DEXSORB System Design

| Parameters | | Unit |
|--|--------------|---------------------|
| Overall System | | |
| Vessels | 10 | # |
| Lead-Lag Systems | 5 | # |
| Empty Bed Contact Time | 15 | min |
| Flow Rate | 10417 | gpm |
| Total DEXSORB Loading | 283.9 | mT |
| Per Lead-Lag Vessel Combination | | |
| Empty Bed Contact Time | 15 | min |
| Flow Rate | 2083.3 | gpm |
| DEXSORB Loading | 56.8 | mT |
| Per Vessel | | |
| Hydraulic Loading Rate | 18.4 | gpm/ft ² |
| Vessel ID | 144 | inch |
| Vessel Height | 26 | feet |
| Vessel Cross-section Area | 113.1 | ft ² |
| Packed Bed Depth | 18.5 | ft |
| Packed Bed Volume | 15626 | gallon |
| DEXSORB Loading | 28.4 | mT |
| Empty Space Ratio | 29.0 | % |
| Estimated Pressure Drop | <15 | psi |
| Media Replacement Frequency* | 4 | months |

* Per EPA MCL Targets

Media Replacement Frequency. In the SAWPA brine line, PFOA and PFOS are detected at peak concentrations of 130 ng/L and 170 ng/L respectively. US EPA has proposed MCLs of 4.0 ppt each for PFOA and PFOS in drinking water. DEXSORB PBF systems installed in Michigan to treat PFAS in similar matrices use Michigan Water Quality Value (WQV) discharge limits for surface water: 170 ppt for PFOA and 12 ppt for PFOS. Proposed media replacement criterion is to replace the lead vessel when PFAS is detected at 75% of the regulatory limit in the lag vessel effluent. To illustrate the impact of removal target goals, we show capacity estimations using EPA MCL and Michigan WQV values:

1. EPA MCLs for drinking water. Media replacement frequency for the lead vessel in each parallel lead-lag system (5 vessels in total) is estimated to be every **4 months** to remove PFAS below EPA drinking water MCLs. PFOS can be removed to < 4 ng/L for *67 weeks* and PFOA can be removed to < 4 ng/L for *17 weeks*. In this scenario, media replacement frequency is driven by PFOA breakthrough estimates.

2. MI WQVs for surface water. Media replacement frequency for the lead vessel in each parallel lead-lag system (5 vessels in total) is estimated to be every **30 months** to remove PFAS below MI WQVs for surface water. With PFOA concentration below the MI WQV limit, the treatment goal is to remove PFOS to below 12 ng/L. PFOS can be removed to < 12 ng/L for *119 weeks*.

This translates to a very large difference in annual media requirements. Over 3 years: EPA MCL target annual media requirements are estimated to average 473 metric tons per year; and MI WQV target annual media requirements are estimated to average 150 metric tons per year. That is roughly a 3X difference in media use based in removal targets.

2. Site Information

2.1 Brine Waste Treatment Operations

Currently, the facility processes a peak flow rate of 15 million gallons per day (i.e., 10417 gpm).

2.2 Site Preparation

The site should be equipped with the following items to accommodate the DEXSORB PBF system, consisting of ten 12-foot diameter vessels:

- (1) **Supply Pressure Requirement:** each parallel lead-lag system requires backpressure of 35 psi from the existing system at 2083 gpm flow rate.
- (2) **Space Requirement:** Adequate space for each DEXSORB PBF lead-lag system, 30 ft (Length) by 16 ft (Width) by 35 ft (Height) dimensions, including 2 ft of clearance on each side of the lead-lag system. The full system will require approximately 2,100 sqft of clearance. See [APPENDIX](#) for the system layout and footprint.
- (3) **Installation:** A crane is required to position the ten-vessel system. 28.4 mT of DEXSORB media will be slurried into each vessel after the system is positioned and plumbed in.

3. DEXSORB System Design and Construction

Table 2 details the proposed DEXSORB PBF system design parameters, consisting of ten 12-foot vessels in parallel lead-lag configuration. Each lead-lag system will be loaded with 56.8 mT of DEXSORB granules to operate at a flow rate of 2083 gpm and accommodate an EBCT of 7.5 minutes per vessel. To handle bed heterogeneity and backpressure, a backwash function is incorporated into the system.

At the time of each media changeout, spent DEXSORB media in the five lead vessels will be replaced with fresh DEXSORB media. The lag vessels will then operate as the lead vessels, and the vessels with fresh media will operate as the lag vessels. Replacement media will be loaded as a slurry and exhausted media will be removed from the vessels using a vacuum truck and suction hose.

4. DEXSORB Waste Handling Advantages

In addition to the effectiveness and high capacity for PFAS removal, a unique advantage of DEXSORB treatment is that spent media can be regenerated in a process that isolates and concentrates PFAS waste for full destruction.

Spent DEXSORB media will be picked up by a Cyclopure contractor during media change-outs for regeneration at an offsite facility. During the regeneration process, PFAS is desorbed from spent DEXSORB and further concentrated for full destruction – *terminating the environmental life of the chemical*. A certificate of PFAS destruction will be provided for every batch of spent DEXSORB taken from the SAWPA facility.

5. Cost Estimate

The DEXSORB PBF system for PFAS treatment of brine wastewater at SAWPA is designed to encompass five lead-lag systems in parallel, containing a total of 283.9 mT of DEXSORB media. The system will have the following associated costs:

5.1 CAPEX.

Suspended Solids Treatment. Suspended solids treatment (e.g., sand filter, dissolved air flotation (DAF) unit) is needed prior to the packed bed filtration system.

Vessels. Ten filtration vessels capable of PBF operations. System design in [Table 2](#) uses vessels with 12-foot diameter and 26-foot height. Pipe and valve connections to be attached to vessel system on a manifold. System will connect to existing effluent hook-ups. SAWPA to make any preparations necessary to accommodate system connection.

5.2 OPEX.

DEXSORB Media. DEXSORB media is priced at **\$85 per kg**, including spent media handling and PFAS waste disposal by destruction technologies. At the time of installation, 283.9 mT of DEXSORB media will be packed, with 28.4 mT of DEXSORB media in each vessel to provide a 15-minute EBCT at a flow rate of 2083 gpm per dual vessel. Media changeout frequency will determine annual costs for DEXSORB media. Annual costs may vary, and adjustments made, based on the actual changeout frequency.

O&M. DEXSORB has demonstrated effective removal of PFAS in complex matrices, with high PFAS adsorption capacity and resistance to biofilm formation or biofouling. With adequate suspended solids management prior to the system, DEXSORB PBF systems will demonstrate long-term operations with minimal O&M efforts. Backwash capability is incorporated in the system.

It is recommended to keep a weekly log of flow rate and pressure readings. Cyclopure offers to perform PFAS analysis of system water samples at no charge on a bi-weekly basis.

Appendix. DEXSORB System Process Flow Diagram and Layout.

The proposed DEXSORB PBF system design uses a total of ten 12-foot vessels, constituting five parallel lead-lag systems. The process flow diagram and system layout and estimated footprint are detailed in [Figure A1](#) and [Figure A2](#).




Figure A1. DEXSORB PBF System Process Flow Diagram.




Figure A2. DEXSORB PBF System Layout and Estimated Footprint.



Appendix C

Aclarity Octa Sizing and Performance Information

Aclarity Octa™

The Aclarity OCTA is a skidded system consisting of eight (8) reactors, eight (8) power supplies, pumps, HMI, and controls. Each reactor is plumbed in parallel and skids are deployed in parallel to handle higher flows and concentrations. Depending on the plant's hydraulic profile, wastewater influent to the Aclarity system can either be pumped into the system by external pumps or the systems internal pumps can pull the water into the system. An influent flow meter is used upstream of the Aclarity system to monitor incoming flow and to control the treatment level being applied. The Aclarity system is capable of operating with a variety of water qualities and chemical concentrations.

PFAS destruction occurs in the system reactors. Unlike other PFAS mitigation technologies, Aclarity chemically destroys PFAS, rather than concentrating for disposal.



Aclarity will be available 24/7 for remote support with scheduled site visits for standard operations and to perform maintenance.

Training: Aclarity will provide a qualified trainer to conduct a safety training course for site staff.

Octa Specifications

The Aclarity Octa™ system destroys PFAS compounds using a proprietary electrochemical process to break down contaminants. We work with waste treatment facilities, municipalities, landfills and other organizations to solve large, cost prohibitive water problems. Each Aclarity Octa is outfitted with 8 reactors, and can treat up to 16 gallons per minute. The system is modular and additional skids are installed in parallel when flow rates or concentrations of PFAS increase. Other alternatives, such as removal and disposal, move the problem around, wasting more resources along the way. Aclarity's technology destroys PFAS on-site, eliminating PFAS from our environment and preventing the chemicals from migrating and contaminating downstream.

Aclarity's solution is robust enough to treat concentrated leachate without worries of performance decrease or fouling of electrodes. Our Octa incorporates reverse polarity for on-line cleaning as well as a Clean-In-Place (CIP) system for periodic cleaning of the reactors.

Octa Dimensions & Weight

- Installed Dimension: 6' wide x 20' long x 8.5' tall
- The skid is designed with forklift pockets for on site handling.

Facility Requirements

- Required minimum footprint, including service and operational access is 11ft x 26ft. Octas may be mounted with overlapping service corridors.

- Diluting air equivalent to 7.5 cfm or 60 air changes per hour per 7.5 ft³/0.213m³ are required.

Influent/Effluent Connections & Requirements

- 2" Male Camlock connections for feed and effluent
- 2" Male Camlock for main drain (piping)
- 1" Male Camlock for secondary drain (piping)
- 1" Male NPT for pan drain

Environmental Requirements

- Designed to be operated between 40°F to 122°F (4°C to 50°C)
- Dry storage between -20F and 122F (-29°C and 50°C)
- Wiring is all contained in corrosion resistant solid wire duct for protection from rodents and other environmental hazards.

Electrical Requirements

- Each Octa requires 400A 240VAC/3 Phase power.
- Connection is through a fused disconnect switch with provision for connecting up to 4 separate 5 wire, 3 phase feeder circuits.
- Each Octa is provided with a single equipment ground point to avoid ground loops.

Safety & Environmental Features

Fluid Containment

- Octa includes integrated secondary containment for 125% of the system fluid volume, with drain provisions for connection to recovery tanks or other containment control systems.

Seismic

- Octa includes foundation tie downs for seismic restraint.
- Rack structure meets California requirements for non-structural seismic bracing for floor mounted equipment.

Ventilation

- The system produces hydrogen, oxygen, chlorine, and hydrogen sulfide gases which are vented through an activated carbon filter. System requires operation in a well-ventilated area.

Electrical

- All electrical cabinets are designed in compliance with the NFPA 70 National Electrical Code and NFPA 79 Electrical Standard for Industrial Machinery and have provision for lock out/tag out.
- E-stops provided at both ends of the skid. All wiring and bus bars are either enclosed or guarded.
- All electrical enclosures & junction boxes are NEMA 3R/IP54 enclosures.

Trailer Specs

Electrical

- Power requirements: 240v - 3 phase w/ 60 amp service via pin and sleeve receptacle
- Service powered locally or by generator
- Ethernet port or Wi-Fi access

Space Configuration & Housing

- Trailer dimensions: 8.5' wide x 20' long x 11' tall
- Weight of trailer: 4,000lbs
- Work bench and storage areas inside trailer

Plumbing & Ventilation

- 1" influent and effluent male coupler
- 2" ventilation exhaust port
- Trailer includes sink with self contained water source and disposal

Safety

- Trailer is equipped with gas monitor, eye wash station, first aid kit, AED, and fire extinguisher

Site Requirements

- Flat surface that can accommodate the load and size of trailer
- Minimum of three (3) 275 gallon totes required on site
- If trailer must be parked in an enclosed space a 2" FNPT will need to be routed out to a ventilated area

Note: Aclarity will provide secondary containment and generator as needed

References

Aclarity has several customers. Many of whom remain confidential. Aclarity has worked closely with Xylem. Let us know if you would like us to arrange a reference call with Kyle Schoenheit, a manager at Xylem, so you can learn more about what it is like to work with Aclarity.

Aclarity was awarded Frost & Sullivan's North American PFAS Treatment Industry Company of the Year for 2023.

<https://www.aclaritywater.com/newsroom/frost-sullivan-award/>

Summary

Aclarity looks forward to addressing PFAS contamination challenges for this project with our innovative destruction technology. We anticipate the opportunity to collaborate, contributing to a cleaner, safer environment. For any further inquiries, please don't hesitate to contact us. Together, let's shape a PFAS-free future.




Appendix D

GAC Treatment System Sizing and Performance Information

MODEL 12-40

Modular Carbon Adsorption System



Description

The Calgon Carbon MODEL 12-40 is an adsorption system designed for the removal of dissolved organic contaminants, including disinfection byproducts (DBP) or natural organic matter (NOM) from liquids using granular activated carbon (GAC). The vessels are sized to hold 40,000 pounds of GAC, which provides the additional contact time required to remove either compounds at low concentrations or poorly adsorbing compounds. The standard design (MODEL 12-40 SYSTEM) consists of two vessels combined with a centralized pipe manifold to allow for series operation. Many of the DBP installations utilize multiple vessels operated in parallel. For these cases, an optional offering is the single vessel concept (MODEL 12-40 SINGLE). This flexibility of configurations allows the engineer to select the alternative that best meets the requirements of the site and treatment objectives.

The MODEL 12-40 SYSTEM is delivered as two adsorbers, a centrally located valve manifold and interconnecting piping requiring minimal space and field assembly. The process piping network for the MODEL 12-40 SYSTEM accommodates operation of the adsorbers in series (with either adsorber placed in first stage) or parallel. The valve manifold can be configured to isolate either adsorber from the flow, which permits carbon exchange or backwash operations to be performed on one adsorber without interrupting treatment. Each vessel is provided with GAC fill and discharge pipe including appropriate quick connect fittings for connection to water and compressed air sources. All valves and accessories are located at low elevations for ease of operation and maintenance.

The MODEL 12-40 SINGLE is delivered as a single adsorber with process pipe extending to grade. The single vessel is typically provided for systems consisting of multiple units operated in parallel. Process valves are not part of the standard package but

can be supplied as an option. The vessel is provided with GAC fill and discharge pipe including appropriate quick connect fittings for connection to water and compressed air sources. All valves and accessories are located at low elevations for ease of operation and maintenance.

The MODEL 12 vessels – either systems or single vessels – are provided with features common in either configuration:

- The unique internal cone under-drain design provides for the efficient collection of treated water and the distribution of backwash water. The internal cone also insures efficient and complete discharge of spent carbon from the adsorber without the need to open the manway to manually wash out the residual spent carbon.
- In bed sample ports. The MODEL 12 vessel is provided with three (3) nozzles located along the straight side of the vessel. These nozzles can be fitted with in-bed sample assemblies which allow the operator to monitor the progress of the adsorbent as it flows through the bed. For the MODEL 12-40 SYSTEM in-bed sample assemblies are an option. For the MODEL 12-40 SINGLE in-bed sample assemblies are standard.
- The MODEL 12 vessel is provided with one (1) GAC fill line and two (2) GAC discharge lines. The multiple discharge lines are positioned to each extract 20,000 pounds of spent carbon. This feature minimizes the time required for GAC exchanges by eliminating the guesswork of loading the spent to the trailers. The one (1) side mounted discharge nozzle is provided with a stainless steel insert which has two functions. The stainless nozzle projects into the vessel and protects the lining during carbon exchange. Also, since GAC can vary in density depending on starting material and activity, the discharge nozzle inserts can be rotated 360 degrees to accommodate the differing densities. If the nozzle insert wears away, it is designed to be easily removed and replaced.
- The MODEL 12 vessel is sized to contain 40,000 lbs of GAC and to allow for backwash expansion of approximately 25% contained within the straight side of the vessel.

The pre-engineered MODEL 12-40 design assures that all adsorption system functions can be performed with the system as provided. Standard designs have the benefit of Calgon Carbon's extensive expertise and have been proven in numerous applications. The engineering package can be provided quickly and the system expedited through Calgon Carbon's production capabilities.

Safety Message

Wet activated carbon can deplete oxygen from air in enclosed spaces. If use in an enclosed space is required, procedures for work in an oxygen deficient environment should be followed.

1.800.4CARBON calgoncarbon.com

© Copyright 2015 Calgon Carbon Corporation, All Rights Reserved
DS-MODEL124015-EIN-E1

The MODEL 12-40 system is designed for use with Calgon Carbon's closed loop carbon exchange service. Using specially designed carbon transport trailers, the spent carbon can be removed from the adsorber via pressurized carbon-water slurry and fresh carbon refilled in the same manner. This closed loop transfer is accomplished without exposure of personnel to either spent or fresh carbon. Calgon Carbon can also manage the disposition of the spent carbon, which is typically returned to Calgon Carbon for reactivation – avoiding the need for the site to arrange for disposal.

| Carbon Adsorbers | System Single | |
|--|---------------|---|
| Carbon Steel ASME code pressure vessels | ✓ | ✓ |
| Internal vinyl ester lining (nominal 35 to 45 mil) where GAC contacts steel for potable water and most liquid applications | ✓ | ✓ |
| Polypropylene slotted nozzles for water collection and backwash distribution | ✓ | ✓ |
| Standard Adsorption System Piping | ✓ | ✓ |
| Schedule 40 carbon steel process piping with cast iron fittings | ✓ | ✓ |
| Cast iron butterfly valves for process piping | ✓ | ● |
| Full bore stainless steel ball valves for GAC fill and discharge | ✓ | ✓ |
| PPL lined steel pipe for GAC discharge | ✓ | ✓ |
| Pressure relief using graphite rupture discs | ✓ | ✓ |
| Pressure gages to measure pressure drop across system and each adsorber | ✓ | ✓ |
| System External Coating | ✓ | ✓ |
| High solids epoxy paint system | ✓ | ✓ |
| System skid, shipped separately, upon which system components can be assembled | ● | ● |
| In-bed water sample collection probes | ● | ✓ |

✓ Included as Standard ● Available as Option



Dimensions and Field Conditions MODEL 12-40


| | |
|-----------------------------|---|
| Adsorber Vessel Diameter | 12' (3,660 mm) |
| Process and Backwash Pipe | 8" |
| Process Pipe Connection | 125# ANSI flange |
| Utility Water Connection | 3/4" hose connection |
| Utility Air Connection | 3/4" hose connection |
| Carbon Hose Connection | 4" Kamlock type |
| Backwash Connections | 8" flange |
| Drain/Vent Connection | 8" flange |
| Adsorber Maintenance Access | 20" round flanged man-way, 14" x 18" man-way below cone |
| Adsorber Shipping Weight | 25,400 lbs. empty (11,550 kg) |
| System Operating Weight | 385,000 lbs. (175,000 kg) |

Operating Conditions MODEL 12-40

| | |
|---------------------|---|
| Carbon per Adsorber | 40,000 lbs. (18,180 kg) |
| Pressure Rating | 125 psig (862 kPa) @ 140°F |
| Pressure Relief | Graphite rupture disk (125 psig) |
| Temperature Rating | 140°F maximum (60°C) |
| Backwash Rate | Typical 1,700 gpm (25% expansion) |
| Carbon Transfer | Air pressure slurry transfer |
| Utility Air | 100 scfm at 30 psig (reduce to 15 psig for trailer) |
| Utility Water | 100 gpm at 30 psig |
| Freeze Protection | None provided; enclosure or protection recommended |

Pressure Drop Model 12-40 System

with 40,000 lbs. 8x30 Mesh GAC per Vessel 8" Sch. 40 Pipe, 60°F



Safety Message

Wet activated carbon can deplete oxygen from air in enclosed spaces. If use in an enclosed space is required, procedures for work in an oxygen deficient environment should be followed.

1.800.4CARBON calgoncarbon.com

© Copyright 2015 Calgon Carbon Corporation, All Rights Reserved
DS-MODEL124015-EIN-E1

Appendix E

CIP Table Summary & Detailed Cost Estimates

Santa Ana Watershed Project Authority
 Inland Empire Brine Line Master Plan
APPENDIX E: Capital Improvement Cost Summary
 August 2024

| Project ID | Planning Scenario | Project Name | Description | Justification | Total Project Cost | Near-Term | | | | | | | | | | | | | Long-Term | | | | | | | | | | Build-Out 2049 to 2065 | | | |
|-------------------------------------|-----------------------------------|--|---|---|----------------------|-------------|-------------------|--------------|-------------|---------------|-------------------|-------------------|------------------|---------------|---------------|---------------|---------------|-----------------|---------------|-------------------|----------------------|----------------------|----------------------|---------------|---------------|-----------------|-----------------|---------------|---------------------------|---------------|----------------------|--|
| | | | | | | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 | 2036 | 2037 | 2038 | 2039 | 2040 | 2041 | 2042 | 2043 | 2044 | 2045 | 2046 | 2047 | | 2048 | | |
| Capacity Projects | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| CAP-1 | Long-Term (2035-2059) | Reach IV-A Lower (Prado Inundations Area) Pipeline | Replace 18,000 LF of existing 36-inch pipe with 48-inch pipe in Reach IV-A Lower, west of | Pipeline is under capacity and located adjacent to the Prado Dam. | \$ 55,114,000 | | | | | | | | | | | | | | \$ 500,000 | \$ 18,204,667 | \$ 18,204,667 | \$ 18,204,667 | | | | | | | | | | |
| CAP-2 | Near-Term (2024-2034) | Smart Manhole Cover Installation | Install smart manhole covers at five (5) locations to monitor water levels during maximum flow conditions. | Monitor the "choke points," including six (6) sections with d/D values anticipated to be between 0.75 and 1.0 identified in the capacity analysis. | \$ 172,000 | | | | | \$ 86,000 | \$ 86,000 | | | | | | | | | | | | | | | | | | | | | |
| CAP-3 | Build-Out Term (Beyond 2045) | Reach IV-D Parallel Line from MAS 4D | Construct a parallel 36" line. | Relieve anticipated buildout capacity deficiencies in Reach 4D. | \$ 4,825,000 | | | | | | | | | | | | | | | | | | | | | | | | | \$ 4,825,000 | | |
| CAP-4 | Build-Out Term (Beyond 2045) | Reach IV Parallel Line from MAS 4-0130 to MAS 4-0030 | Construct a parallel 30" line. | Relieve anticipated buildout capacity deficiencies in Reach 4. | \$ 19,520,000 | | | | | | | | | | | | | | | | | | | | | | | | | \$ 19,520,000 | | |
| CAP-5 | Near-Term (2024-2034) | Future Study on Green Hydrogen | Evaluate the feasibility of using green hydrogen technology using Brine Line water. | The use of green hydrogen technology in the future could significantly reduce overall Brine Line flows. | \$ 198,000 | | \$ 198,000 | | | | | | | | | | | | | | | | | | | | | | | | | |
| CAP-6 | Near-Term (2024-2034) | Future Studies on Brine Minimization | Evaluate various brine minimization strategies for the Brine Line system. | Minimize brine flows in order to increase the available capacity of the Brine Line. | \$ 263,000 | | | | | \$ 87,667 | \$ 87,667 | \$ 87,667 | | | | | | | | | | | | | | | | | | | | |
| Total Capacity Projects: | | | | | \$ 80,092,000 | \$ - | \$ 198,000 | \$ - | \$ - | \$ - | \$ 173,667 | \$ 173,667 | \$ 87,667 | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ 500,000 | \$ 18,204,667 | \$ 18,204,667 | \$ 18,204,667 | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ 24,345,000 | |
| Facility Management Projects | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| FM-1 | Near-Term (2024-2034) | Reach IV-E Siphon Mainline Valve | Installation of a new MAS within the Brine Line downstream of existing MAS 4E-0040 to facilitate newly constructed Agua Mansa Lateral. | To be used as a low flow bypass, thereby allowing dewatering of the existing siphon section. | \$ 970,000 | | | \$ 485,000 | \$ 485,000 | | | | | | | | | | | | | | | | | | | | | | | |
| FM-2 | Near-Term / Long-Term (2025-2045) | Off-Line Storage System | Install six (6) 2-MG and one (1) 0.5-MG off-line storage reservoirs (locations TBD); Project to be phased over 10 years. | To dewater the Brine Line system for necessary repairs/rehabilitation. | \$ 109,278,000 | | | | \$ 200,000 | | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | \$ 10,907,800 | | |
| FM-3 | Long-Term (2034-2034) | Reach IV Pipeline Inspection & Condition Assessment/Rehabilitation | A complete inspection and condition assessment of the Reach to identify existing structural or maintenance issues. Based on recommendations from the 2024 Condition Assessment. | Reach IV is the oldest portion of the Brine Line. The goal is a rehabilitation program intended to improve and extend the remaining useful life of the existing Reach. | \$ 9,100,000 | | | | | | | | | \$ 850,000 | | | | | | | | | | | \$ 1,250,000 | \$ 3,500,000.00 | \$ 3,500,000.00 | | | | | |
| FM-4A | Near-Term (2024-2034) | Reach IV-B Ductile Iron Pipe Mid-Term Condition Assessment | Heavy cleaning, CCTV and Sonar inspection of 8,600 LF of pipe. Perform joint repairs and spot repairs. Based on recommendations from the 2024 Condition Assessment | A portion of Reach IV-B (8,500 LF) was constructed with 36" cement-mortar lined DIP in the late 1990s and is now over 20 years old. Corrosion (both internal and external) can significantly impact the structural integrity of DIP pipe. | \$ 3,680,000 | | | \$ 3,680,000 | | | | | | | | | | | | | | | | | | | | | | | | |
| FM-4B | Long-Term (2035-2059) | Reach IV-B Ductile Iron Pipe Rehabilitation Project | Rehabilitate approximately 8,600 feet of 36 inch DIP with CIPP Lining. Based on recommendations from the 2024 Condition. Reevaluate after mid-term condition assessment. | A portion of Reach IV-B (8,500 LF) was constructed with 36" cement-mortar lined DIP in the late 1990s and is now over 20 years old. Corrosion (both internal and external) can significantly impact the structural integrity of DIP pipe. | \$ 8,790,000 | | | | | | | | | | | | \$ 4,395,000 | \$ 4,395,000.00 | | | | | | | | | | | | | | |
| FM-5A | Near-Term (2024-2034) | Reach IV-D Corrosion Rehabilitation | Cleaning, CCTV and Concrete and liner repairs in the near term. Reinspecting entire 7 miles including siphons in the mid-term. Based on recommendations from the 2024 Condition Assessment. | Approximately 7 miles of Reach IV-D is unlined along the pipeline invert so that the existing material has been exposed to corrosion. SAWPA performed a condition assessment of Reach IV-D in 2018 and 2024. | \$ 993,000 | | \$ 94,000 | | | | | | \$ 899,000.00 | | | | | | | | | | | | | | | | | | | |
| FM-5B | Long-Term (2035-2059) | Reach IV-D Corrosion Rehabilitation, Phase 1 and 2. | Lining of 7-miles of 42-inch pipeline | Approximately 7 miles of Reach IV-D is unlined along the pipeline invert so that the existing material has been exposed to corrosion. SAWPA performed a condition assessment of Reach IV-D in 2018 and 2024 concluded that all 7 miles will likely require structural rehabilitation in 7-10 years. | \$ 41,477,800 | | | | | | | | \$ 13,670,150 | \$ 13,670,150 | | | | | | | | | | | | | | \$ 7,068,750 | \$ 7,068,750 | | | |
| FM-6 | Near-Term (2024-2034) | Reach V MAS Condition Assessment | Perform condition assessment on Reach V to define and locate the adequate number of structures and develop an order of magnitude project cost. | Approximately 15 miles of Reach V is currently not accessible due to the lack of an adequate number of MAS. Access to Reach V is critical for performing routine inspections, cleaning of the pipeline, and mitigating operational issues. Additional study is necessary to identify a suitable number and placement of MAS within Reach V. | \$ 6,575,000 | | | | | \$ 575,000.00 | | | \$ 2,000,000 | \$ 2,000,000 | \$ 2,000,000 | | | | | | | | | | | | | | | | | |
| FM-7 | Near-Term (2024-2034) | Reach IV-B Pipeline Inspection & Condition Assessment/Rehabilitation | Approximately 30,000 LF of Reach IV-B, constructed between 1981 and 1996, will be inspected and evaluated for rehabilitation. | Maintain high level of system performance. | \$ 35,670,000 | | \$ 850,000 | | | | | \$ 850,000 | | | | | | | | | \$ 120,000.00 | \$ 16,000,000 | \$ 17,000,000 | | | | | | | | | |
| FM-8 | Near-Term (2024-2034) | Reach IV-B DIP Section Additional MAS Structures | Construct additional MAS on Reach IV-B. Based on recommendations from the 2024 Condition Assessment. | Maintain high level of system performance. | \$ 325,000 | \$ 325,000 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| FM-9 | Near-Term (2024-2034) | Reach IV-E Inspection / Repairs | Perform an investigation and assessment to understand the reliability and performance of Reach IV-E and identify potential issues and actions needed to extend the remaining useful life of the system. | Reach IV-E was constructed in 1995. A portion of the Reach IV-E is in a long siphon and access is limited. This inspection and subsequent repairs will extend the remaining useful life of the system. | \$ 1,200,000 | | \$ 450,000 | | | | | | | | \$ 750,000 | | | | | | | | | | | | | | | | | |
| FM-10 | Near-Term (2024-2034) | Reach V - Temescal Canyon Rd (E) Cerrito Segment Widening | Relocate existing Air Release Valves and protect Brine Line during street widening project. | Riverside County Transportation Department plans to widen Temescal Canyon Road from El Cerrito to Tom Barnes Road. | \$ 200,000 | | \$ 100,000 | \$ 100,000 | | | | | | | | | | | | | | | | | | | | | | | | |

CAP-1: HOBAS WEST PIPELINE REPLACEMENT AND RELOCATION

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---|------------------------------|-------------|---------------------------|-------------------|----------------------|
| 1 | 48-inch Pipeline Replacement | LF | 18,000 | \$1,680 | \$ 30,240,000 |
| Subtotal | | | | | \$ 30,240,000 |
| General Requirements (10%) | | | | | \$ 3,024,000 |
| Contingency (25%) | | | | | \$ 7,560,000 |
| Construction Total | | | | | \$ 40,824,000 |
| <i>Soft Costs:</i> | | | | | |
| Engineering (10%) | | | | | \$ 4,083,000 |
| Construction Mgmt, Environmental & ESDC (20%) | | | | | \$ 8,165,000 |
| Administration (5%) | | | | | \$ 2,042,000 |
| Project Total | | | | | \$ 55,114,000 |

CAP-2: Smart Manhole Cover Installation

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---------------------------|--------------------------------|-------------|---------------------------|-------------------|--------------------|
| 1 | Install 5 Smart Manhole Covers | EA | 5 | \$6,000 | \$ 30,000 |
| 1 | SCADA System Integration | EA | 5 | \$20,000 | \$ 100,000 |
| Subtotal | | | | | \$ 130,000 |
| Contingency (25%) | | | | | \$ 33,000 |
| Construction Total | | | | | \$ 163,000 |
| | | | | | <i>Soft Costs:</i> |
| Administration (5%) | | | | | \$ 9,000 |
| Project Total | | | | | \$ 172,000 |

CAP-3: Reach 4D Parallel Line from MAS 4D-150 to MAS 4D 0110

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---|-------------------------|-------------|---------------------------|-------------------|---------------------|
| 1 | Parallel 36-inch Line | LF | 2,100 | \$1,260 | \$ 2,646,000 |
| Subtotal | | | | | \$ 2,646,000 |
| General Requirements (10%) | | | | | \$ 265,000 |
| Contingency (25%) | | | | | \$ 662,000 |
| Construction Total | | | | | \$ 3,573,000 |
| | | | | | <i>Soft Costs:</i> |
| Engineering (10%) | | | | | \$ 358,000 |
| Construction Mgmt, Environmental & ESDC (20%) | | | | | \$ 715,000 |
| Administration (5%) | | | | | \$ 179,000 |
| Project Total | | | | | \$ 4,825,000 |

CAP-4: Reach 4 Parallel Line from MAS 4-0130 to MAS 4-0030

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---|-------------------------|-------------|---------------------------|-------------------|----------------------|
| 1 | Parallel 30-inch Line | LF | 10,200 | \$1,050 | \$ 10,710,000 |
| Subtotal | | | | | \$ 10,710,000 |
| General Requirements (10%) | | | | | \$ 1,071,000 |
| Contingency (25%) | | | | | \$ 2,678,000 |
| Construction Total | | | | | \$ 14,459,000 |
| <i>Soft Costs:</i> | | | | | |
| Engineering (10%) | | | | | \$ 1,446,000 |
| Construction Mgmt, Environmental & ESDC (20%) | | | | | \$ 2,892,000 |
| Administration (5%) | | | | | \$ 723,000 |
| Project Total | | | | | \$ 19,520,000 |

CAP-5: Future Study on Green Hydrogen

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---------------------------|----------------------|------|--------------------|------------|--------------------|
| 1 | Green Hydrogen Study | EA | 1 | \$150,000 | \$ 150,000 |
| Subtotal | | | | | \$ 150,000 |
| Contingency (25%) | | | | | \$ 38,000 |
| Construction Total | | | | | \$ 188,000 |
| | | | | | <i>Soft Costs:</i> |
| Administration (5%) | | | | | \$ 10,000 |
| Project Total | | | | | \$ 198,000 |

CAP-6: Future Studies on Brine Minimization

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---------------------------|--------------------------|-------------|---------------------------|-------------------|--------------------|
| 1 | Brine Minimization Study | EA | 1 | \$100,000 | \$ 100,000 |
| 1 | Pilot Study | EA | 1 | \$100,000 | \$ 100,000 |
| Subtotal | | | | | \$ 200,000 |
| Contingency (25%) | | | | | \$ 50,000 |
| Construction Total | | | | | \$ 250,000 |
| | | | | | <i>Soft Costs:</i> |
| Administration (5%) | | | | | \$ 13,000 |
| Project Total | | | | | \$ 263,000 |

FM-1: Reach IV-E Siphon Mainline Valve

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---|-----------------------------------|-------------|---------------------------|-------------------|--------------------|
| 1 | New MAS downstream of MAS 4E-0040 | EA | 2 | \$250,000 | \$ 500,000 |
| Subtotal | | | | | \$ 500,000 |
| General Requirements (10%) | | | | | \$ 50,000 |
| Contingency (25%) | | | | | \$ 125,000 |
| Construction Total | | | | | \$ 675,000 |
| | | | | | <i>Soft Costs:</i> |
| Engineering (17%) | | | | | \$ 119,000 |
| Construction Mgmt, Environmental & ESDC (20%) | | | | | \$ 135,000 |
| Administration (5%) | | | | | \$ 40,000 |
| Project Total | | | | | \$ 970,000 |

FM-2: OFFLINE STORAGE SYSTEM

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---|-------------------------------------|-------------|---------------------------|-------------------|-----------------------|
| 1 | Feasibility Study | EA | 1 | \$100,000 | \$ 100,000 |
| 2 | (6) 2-MG Underground Storage Tanks | Gal | 12,000,000 | \$4 | \$ 48,000,000 |
| 3 | (1) 0.5-MG Underground Storage Tank | Gal | 500,000 | \$4 | \$ 2,000,000 |
| 4 | Land Acquisition | Ac | 13 | \$750,000 | \$ 9,750,000 |
| Subtotal | | | | | \$ 59,850,000 |
| General Requirements (10%) | | | | | \$ 5,985,000 |
| Contingency (25%) | | | | | \$ 14,963,000 |
| Construction Total | | | | | \$ 80,798,000 |
| <i>Soft Costs:</i> | | | | | |
| Engineering (10%) | | | | | \$ 8,080,000 |
| Construction Mgmt, Environmental & ESDC (20%) | | | | | \$ 16,160,000 |
| Administration (5%) | | | | | \$ 4,040,000 |
| Project Total | | | | | \$ 109,078,000 |

MON-1: SCADA System Set up and High Discharger Install

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---|--|-------------|---------------------------|-------------------|---------------------|
| 1 | Construct Master Station, operation workstation, initial set up, integration of programming and automation | LS | 1 | \$200,000 | \$ 200,000 |
| 2 | Install SCADA system at twelve (12) existing discharger sitest that currently produce the highest flows | LS | 1 | \$350,000 | \$ 350,000 |
| Subtotal | | | | | \$ 550,000 |
| General Requirements (10%) | | | | | \$ 55,000 |
| Contingency (25%) | | | | | \$ 138,000 |
| Construction Total | | | | | \$ 743,000 |
| | | | | | <i>Soft Costs:</i> |
| Engineering (17%) | | | | | \$ 125,000 |
| Construction Mgmt, Environmental & ESDC (20%) | | | | | \$ 149,000 |
| Administration (5%) | | | | | \$ 38,000 |
| Project Total | | | | | \$ 1,055,000 |

MON-2 and MON-3: SCADA System Install

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|---|--|-------------|---------------------------|-------------------|--------------------|
| 1 | Install SCADA system at twelve (12) existing discharger sites that currently produce the highest flows | LS | 1 | \$350,000 | \$ 350,000 |
| Subtotal | | | | | \$ 350,000 |
| General Requirements (10%) | | | | | \$ 35,000 |
| Contingency (25%) | | | | | \$ 88,000 |
| Construction Total | | | | | \$ 473,000 |
| | | | | | <i>Soft Costs:</i> |
| Engineering (21%) | | | | | \$ 99,000 |
| Construction Mgmt, Environmental & ESDC (20%) | | | | | \$ 95,000 |
| Administration (5%) | | | | | \$ 24,000 |
| Project Total | | | | | \$ 691,000 |

MON-4: Inline Flow Metering Stations #1 through #5

| Item No. | Item Description | Unit | Estimated Quantity | Unit Price | Item Total |
|----------------------------|--------------------------------------|-------------|---------------------------|-------------------|--------------------|
| 1 | Install Inline Flow Metering Station | EA | 5 | \$8,500 | \$ 42,500 |
| 3 | SCADA System | LS | 1 | \$100,000 | \$ 100,000 |
| Subtotal | | | | | \$ 143,000 |
| General Requirements (10%) | | | | | \$ 15,000 |
| Contingency (25%) | | | | | \$ 36,000 |
| Construction Total | | | | | \$ 194,000 |
| | | | | | <i>Soft Costs:</i> |
| Administration (5%) | | | | | \$ 10,000 |
| Project Total | | | | | \$ 204,000 |

Page Intentionally Blank

PA 24 COMMITTEE MEMORANDUM NO. 2025.5

DATE: February 4, 2025

TO: Project Agreement 24 Committee
(Inland Empire Brine Line)

SUBJECT: City of Chino Euclid Bridge Project (Reach IV-A and IV-B)

PREPARED BY: David Ruhl, Executive Manager of Engineering and Operations

RECOMMENDATION

Receive and file.

DISCUSSION

The City of Chino is planning to construct a bridge along Euclid Avenue (State Hwy 83) between State Route 71 and Pine Avenue. The project location is within the Prado inundation area that tends to flood in above average wet years. The project will raise Euclid Avenue by constructing an elevated roadway to maintain access during flooding events.

The Brine Line Reach IV-A and Reach IV-D are located within the project limits. The bridge construction and location have the potential to impact approximately 200 feet of 27-inch pipe on Reach IV-A and approximately 5,000 feet of 42-inch pipe on Reach IV-D.

Due to the construction and various constraints in the location of the elevated roadway, the Brine Line is impacted due to interference with several concrete pilings that support the structure, increased fill and retaining walls over the brine line.

SAWPA staff is working closely with the City of Chino to gain an understanding of the impacts and to explore all alternatives to maintain the structural integrity of the Brine Line which may include protection measures and relocation of the Brine Line.

The proposed schedule for the project is to commence construction in mid-2026 in order to have the work completed in early 2028.

RESOURCE IMPACTS

SAWPA staff time for coordination with the City of Chino and to evaluate the impacts of the project on the Brine Line are included in the FY 2025 budget (Fund 240). Additional costs for protection and/or relocation of the Brine Line is being evaluated and will be included in the next two year Budget if necessary. A portion of the costs may be reimbursable by the City of Chino.

Attachments:

1. PowerPoint Presentation

Page Intentionally Blank



City of Chino Euclid Bridge Project Brine Line Reach IV-A and IV- D


David Ruhl, Executive Manager of Engineering and Operations

PA 24 Committee Meeting



February 4, 2025

Euclid Bridge Project - Location

- City of Chino is proposing to construct an elevated roadway along Euclid Avenue (State Hwy 83)
- Maintain access during flood events
- Potential impact to Reach IV-A and IV-D



P:\projects\id_ruhl\BrineLineReachesLaterals\BrineLineReachesLaterals.aprx LayoutBrineLine SW-2934




Questions?

**Santa Ana Watershed Project Authority
PA24 - Brine Line - Financial Report
October 2024**


Staff comments provided on the last page are an integral part of this report.

| | |
|-----------------|--|
| Overview | This report highlights the Brine Line’s key financial indicators for the Fiscal Year-to-Date (FYTD) through October 2024 unless otherwise noted. |
|-----------------|--|


Brine Line - Capital Projects

| Budget to Actual – Capital Projects | | |  | Favorable |
|-------------------------------------|--------------------|------------------|---|----------------------------------|
| | Annual Budget | FYTD Budget | FYTD Actual | Favorable (Unfavorable) Variance |
| Brine Line Protection | \$1,400,590 | \$466,863 | \$1,835 | \$465,028 |
| Reach IV-D Corrosion | 469,423 | 156,474 | 6,401 | 150,073 |
| Agua Mansa Lateral | - | - | 1,488 | (1,488) |
| Total Capital Costs | \$1,870,013 | \$623,337 | \$9,724 | \$613,613 |


Budget to Actual - Capital Projects



Brine Line – Operating

| Budget to Actual - Expenses by Type | | | |  On Track |
|-------------------------------------|---------------------|--------------------|--------------------|--|
| | Annual Budget | FYTD Budget | FYTD Actual | Favorable (Unfavorable) Variance |
| Labor | \$1,392,817 | \$464,272 | \$503,257 | (\$38,985) |
| Benefits | 507,443 | 169,148 | 183,185 | (14,037) |
| Indirect Costs | 2,278,716 | 759,572 | 823,328 | (63,756) |
| Education & Training | 15,225 | 5,075 | - | 5,075 |
| Consulting & Prof Svcs | 772,500 | 257,500 | 98,052 | 159,448 |
| Operating Costs | 3,041,939 | 1,013,980 | 990,685 | 23,295 |
| Repair & Maintenance | 553,558 | 184,519 | 2,070 | 182,449 |
| Phone & Utilities | 13,200 | 4,400 | 2,959 | 1,441 |
| Equip & Computers | 204,167 | 68,056 | 33,891 | 34,165 |
| Meeting & Travel | 7,700 | 2,567 | 1,126 | 1,441 |
| Other Admin Costs | 98,988 | 32,996 | 11,156 | 21,840 |
| Other Expense | 426,597 | 142,199 | 116,675 | 25,524 |
| Debt Service | 1,709,476 | - | - | - |
| Contribution to Reserves | 2,055,786 | 2,055,786 | 2,055,786 | - |
| Total | \$13,078,112 | \$5,160,070 | \$4,822,170 | \$337,900 |

Budget to Actual - Expenses by Type




Budget to Actual - Revenues by Source




Favorable

| | Annual Budget | FYTD Budget | FYTD Actual | Favorable (Unfavorable) Variance |
|--------------------------|---------------------|--------------------|--------------------|----------------------------------|
| BOD/TSS Fees | \$1,900,850 | \$633,617 | \$740,432 | \$106,815 |
| Volumetric Fees | 4,564,617 | 1,521,539 | 1,717,913 | 196,374 |
| Fixed Charges | 5,396,025 | 1,798,675 | 1,785,170 | (13,505) |
| Truck Dump Fees | 517,020 | 172,340 | 267,590 | 95,250 |
| Permit Fees | 26,600 | 7,900 | 7,900 | - |
| Sampling Surcharge | - | - | 3,761 | 3,761 |
| Emergency Discharge Fees | - | - | 201 | 201 |
| Lease Capacity Revenue | - | - | 116,362 | 116,362 |
| Other Revenue | - | - | 200 | 200 |
| Interest & Investments | 673,000 | 182,667 | 715,975 | 533,308 |
| Total | \$13,078,112 | \$4,316,738 | \$5,355,504 | \$1,038,766 |

Budget to Actual - Revenues by Source




Average Daily Flow by Month



Total Discharge by Agency (in million gallons)

| Discharger | Jul'24 | Aug'24 | Sep'24 | Oct'24 | Nov'24 | Dec'24 | Total |
|----------------------------------|-----------------|-----------------|-----------------|-----------------|--------|--------|-------------------|
| Chino Desalter Authority | 109.4633 | 99.5941 | 115.5658 | 112.7109 | | | 437.3341 |
| Eastern Municipal Water District | 104.3521 | 91.4534 | 115.7813 | 106.8580 | | | 418.4448 |
| Inland Empire Utilities Agency | 16.9394 | 14.3438 | 15.7094 | 14.2392 | | | 61.2318 |
| San Bernardino Valley MWD | 44.0789 | 45.0388 | 44.7654 | 45.5667 | | | 179.4498 |
| Western Municipal Water District | 88.9240 | 124.8091 | 124.5022 | 127.3453 | | | 465.5806 |
| SAWPA Adjustment | 0.0000 | 0.0000 | 6.5000 | 0.0000 | | | 6.5000 |
| Truck Discharge | 4.0942 | 3.9492 | 3.4518 | 3.3775 | | | 14.8727 |
| Total | 367.8519 | 379.1884 | 426.2759 | 410.0976 | | | 1,583.4138 |





Total Cash & Investments



Reserve Fund Balance

| | Amount |
|---|---------------------|
| Debt Retirement | \$3,043,856 |
| Pipeline Replacement & Capital Investment | 37,027,115 |
| OC San Pipeline Rehabilitation | 3,068,481 |
| Pipeline Capacity Management | 12,944,921 |
| OC San Future Treatment & Disposal Capacity | 1,981,909 |
| Brine Line Operating | 2,312,437 |
| Brine Line Operating Cash | 5,012,381 |
| Total Reserves | \$65,391,100 |

Legend

| | | <u>Compared to Budget</u> |
|---|--------------------|---|
|  | Ahead or Favorable | Above +5% Favorable Revenue or Expense Variance |
|  | On Track | +5% to -2% Variance |
|  | Behind | -3% to -5% Variance |
|  | Concern | Below -5% Variance |

Staff Comments

For this month's report, the item(s) explained below are either "behind", a "concern", or have changed significantly from the prior month.


Capital Projects are 98.4% below budget. Operating Expenses are 6.6% below budget and Revenues are 24.1% above budget.

**Santa Ana Watershed Project Authority
PA24 - Brine Line - Financial Report
November 2024**


Staff comments provided on the last page are an integral part of this report.

| | |
|-----------------|---|
| Overview | This report highlights the Brine Line’s key financial indicators for the Fiscal Year-to-Date (FYTD) through November 2024 unless otherwise noted. |
|-----------------|---|


Brine Line - Capital Projects

| Budget to Actual – Capital Projects | | |  | Favorable |
|-------------------------------------|--------------------|------------------|---|----------------------------------|
| | Annual Budget | FYTD Budget | FYTD Actual | Favorable (Unfavorable) Variance |
| Brine Line Protection | \$1,400,590 | \$583,579 | \$2,094 | \$581,485 |
| Reach IV-D Corrosion | 469,423 | 195,593 | 10,057 | 185,536 |
| Agua Mansa Lateral | - | - | 1,488 | (1,488) |
| Total Capital Costs | \$1,870,013 | \$779,172 | \$13,639 | \$765,533 |


Budget to Actual - Capital Projects



Brine Line – Operating

| Budget to Actual - Expenses by Type | | | |  Favorable |
|-------------------------------------|---------------------|--------------------|--------------------|---|
| | Annual Budget | FYTD Budget | FYTD Actual | Favorable (Unfavorable) Variance |
| Labor | \$1,392,817 | \$580,340 | \$600,170 | (\$19,830) |
| Benefits | 507,443 | 211,435 | 218,462 | (7,027) |
| Indirect Costs | 2,278,716 | 949,465 | 981,879 | (32,414) |
| Education & Training | 15,225 | 6,344 | - | 6,344 |
| Consulting & Prof Svcs | 772,500 | 321,875 | 119,996 | 201,879 |
| Operating Costs | 3,041,939 | 1,267,475 | 1,243,530 | 23,245 |
| Repair & Maintenance | 553,558 | 230,649 | 11,043 | 219,606 |
| Phone & Utilities | 13,200 | 5,500 | 3,515 | 1,985 |
| Equip & Computers | 204,167 | 85,070 | 42,974 | 42,096 |
| Meeting & Travel | 7,700 | 3,208 | 1,126 | 2,082 |
| Other Admin Costs | 98,988 | 41,245 | 18,223 | 23,022 |
| Other Expense | 426,597 | 177,749 | 144,127 | 33,622 |
| Debt Service | 1,709,476 | 1,044,273 | 1,044,273 | - |
| Contribution to Reserves | 2,055,786 | 2,055,786 | 2,055,786 | - |
| Total | \$13,078,112 | \$6,980,414 | \$6,485,104 | \$495,310 |

Budget to Actual - Expenses by Type




Budget to Actual - Revenues by Source




Favorable

| | Annual Budget | FYTD Budget | FYTD Actual | Favorable (Unfavorable) Variance |
|--------------------------|---------------------|--------------------|--------------------|----------------------------------|
| BOD/TSS Fees | \$1,900,850 | \$792,021 | \$879,282 | \$87,261 |
| Volumetric Fees | 4,564,617 | 1,901,924 | 2,141,465 | 239,541 |
| Fixed Charges | 5,396,025 | 2,248,344 | 2,231,462 | (16,882) |
| Truck Dump Fees | 517,020 | 215,425 | 325,366 | 109,941 |
| Permit Fees | 26,600 | 7,900 | 7,900 | - |
| Sampling Surcharge | - | - | 3,761 | 3,761 |
| Emergency Discharge Fees | - | - | 201 | 201 |
| Lease Capacity Revenue | - | - | 145,453 | 145,453 |
| Other Revenue | - | - | 200 | 200 |
| Interest & Investments | 673,000 | 197,083 | 773,000 | 575,917 |
| Total | \$13,078,112 | \$5,362,697 | \$6,508,090 | \$1,145,393 |

Budget to Actual - Revenues by Source




Average Daily Flow by Month



Total Discharge by Agency (in million gallons)

| Discharger | Jul'24 | Aug'24 | Sep'24 | Oct'24 | Nov'24 | Dec'24 | Total |
|----------------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|--------|-------------------|
| Chino Desalter Authority | 109.4633 | 99.5941 | 115.5658 | 112.7109 | 111.1550 | | 548.4891 |
| Eastern Municipal Water District | 104.3521 | 91.4534 | 115.7813 | 106.8580 | 111.8461 | | 530.2909 |
| Inland Empire Utilities Agency | 16.9394 | 14.3438 | 15.7094 | 14.2392 | 13.0521 | | 74.2839 |
| San Bernardino Valley MWD | 44.0789 | 45.0388 | 44.7654 | 45.5667 | 43.1998 | | 222.6496 |
| Western Municipal Water District | 88.9240 | 124.8091 | 124.5022 | 127.3453 | 105.6868 | | 571.2674 |
| SAWPA Adjustment | 0.0000 | 0.0000 | 6.5000 | 0.0000 | 0.0000 | | 6.5000 |
| Truck Discharge | 4.0942 | 3.9492 | 3.4518 | 3.3775 | 3.2437 | | 18.1164 |
| Total | 367.8519 | 379.1884 | 426.2759 | 410.0976 | 388.1835 | | 1,971.5973 |





Total Cash & Investments



Reserve Fund Balance

| | Amount |
|---|---------------------|
| Debt Retirement | \$3,043,856 |
| Pipeline Replacement & Capital Investment | 37,229,698 |
| OC San Pipeline Rehabilitation | 3,068,481 |
| Pipeline Capacity Management | 12,944,921 |
| OC San Future Treatment & Disposal Capacity | 1,981,909 |
| Brine Line Operating | 2,312,437 |
| Brine Line Operating Cash | 5,631,833 |
| Total Reserves | \$66,213,135 |

Legend

| | | <u>Compared to Budget</u> |
|---|--------------------|---|
|  | Ahead or Favorable | Above +5% Favorable Revenue or Expense Variance |
|  | On Track | +5% to -2% Variance |
|  | Behind | -3% to -5% Variance |
|  | Concern | Below -5% Variance |

Staff Comments

For this month's report, the item(s) explained below are either "behind", a "concern", or have changed significantly from the prior month.

Capital Projects are 98.2% below budget. Operating Expenses are 7.1% below budget and Revenues are 21.4% above budget.